UNITED STATES NUCLEAR REGULATORY COMMISSION OFFICE OF NUCLEAR REACTOR REGULATION WASHINGTON, D.C. 20555

December 21, 1993

NRC INFORMATION NOTICE 93-99: UNDERVOLTAGE RELAY AND THERMAL OVERLOAD SETPOINT PROBLEMS

Addressees

All holders of operating licenses or construction permits for nuclear power plants.

<u>Purpose</u>

The U.S. Nuclear Regulatory Commission (NRC) is issuing this information notice to alert addressees to continuing discoveries of undervoltage relay and thermal overload setpoints that are set too low. It is expected that recipients will review the information for applicability to their facilities and consider actions, as appropriate, to avoid similar problems. However, suggestions contained in this information notice are not NRC requirements; therefore, no specific action or written response is required.

Background

In August 1976, the NRC wrote generic letters to all LWR licensees regarding the need 'for licensees to evaluate any generic implications of several events at the Millstone site involving episodes of sustained degraded grid voltage. On June 2, 1977, as part of multiplant action MPA-23, the staff stated its position that all licensees must have a second level of undervoltage protection with a time delay. (During degraded grid voltage episodes, undervoltage relays and thermal overload protective relays protect the safety equipment.) In a generic letter dated August 8, 1979, the NRC requested all licensees to determine the capability of the offsite power system to operate all required loads within their voltage ratings under all conditions within their design basis. The licensees reviewed their undervoltage relay setpoints on each of these occasions. In 1981, the NRC issued Branch Technical Position, Power System Branch-1, "Adequacy of Station Electric Distribution System Voltages," which discussed, among other things, the addition of a second undervoltage relay with an associated time delay. Between 1981 and 1992, the NRC issued two information notices, in which it discussed undervoltage relay setpoints and other concerns:

- 1. IN 84-02, "Operating a Nuclear Power Plant at Voltage Levels Lower than Analyzed," issued January 10, 1984.
- 2. IN 91-29, "Deficiencies Identified During Electrical Distribution System Functional Inspections," issued April 15, 1991.

| 9312150073 | PDR | ΙĘΕ | Notice | 93-099 | 93122 |
|--------------|-----|-----|--------|--------|-------|
| updated on 1 | | | | | 93122 |

Į

3. IN 91-29, Supplement 1, "Deficiencies Identified During

•

Brian K. Grimes, Director

Division of Operating Reactor Support Office of Nuclear Reactor Regulation

Technical contact: C. Morris, NRR (301) 504-2778

Attachments:

ζ.

- Representative List of Undervoltage Relay Setpoint Revisions 1988-1993
 List of Recently Issued NRC Information Notices

Attachment 1 IN 93-99 December 21, 1993 Page 1 of 2

Representative List of Undervoltage Relay Set Point Revision Notifications and Technical Specification Change Proposals for 1988-1993

| Event Notification | <u>Licensee</u> | Event Notification Date | <u>Class</u> |
|---|--|---|---|
| 11374 | Pilgrim 1 | January 30, 1988 | 1 |
| 14043 | Pilgrim 1 | November 18, 1988 | 5 |
| 00000 | Pilgrim 1 | June 30, 1988 | 1 |
| 14780 | Cooper 1 | February 17, 1989 | 5 |
| 16540 | Crystal River 3 | September 8, 1989 | 1 |
| 17121 | Robinson 2 | November 16, 1989 | 1 |
| 18322 | Oconee 1, 2 and 3 | April 24, 1990 | 5 |
| 18466 | McGuire 1 and 2 | May 14, 1990 | 1 |
| 18892 | St. Lucie 2 | July 14, 1990 | 2 |
| 19023 | Haddam Neck 1 | August 2, 1990 | 5 |
| 20021 | Calvert Cliff 1 and 2 | December 6, 1990 | 1 |
| 20435 | Ft. Calhoun | February 12, 1991 | 1 |
| 20503 | Kewaunee 1 | February 20, 1991 | 5 |
| 20542 | Salem 2 | February 27, 1991 | 2 |
| 21691 | Dresden 2 and 3 | August 23, 1991 | 5 |
| 22281 | Dresden 2 | November 20, 1991 | 1 |
| 22498 | Zion 1 and 2 | December 19, 1991 | 5 |
| 22580 22658 22847 (TOL) 22918 23148 23191 23338 23365 23385 23439 (TOL) 23452 23576 23784 23932 00000 24229 24384 | Indian Point 3 Dresden 3 Washington Nuclear 2 Washington Nuclear 2 Vermont Yankee Quad Cities 1 and 2 LaSalle 1 and 2 LaSalle 2 Crystal River 3 Grand Gulf Comanche Peak 2 Crystal River 3 Zion 1 and 2 Byron 1 and 2 Callaway Crystal River 3 Dresden 2 and 3 | January 9, 1992 January 22, 1992 February 19, 1992 March 1, 1992 April 1, 1992 April 7, 1992 April 27, 1992 April 29, 1992 May 1, 1992 May 11, 1992 May 13, 1992 June 4, 1992 July 2, 1992 July 24, 1992 July 23, 1992 September 14, 1992 October 6, 1992 | 5 5 5 1 4 5 1 1 5 3 1 1 5 1 1 5 5 1 5 5 5 5 1 4 5 1 5 5 1 4 5 1 5 5 5 1 4 5 5 5 1 5 5 1 5 5 1 5 5 1 5 5 1 5 5 1 5 5 1 5 5 1 5 5 1 5 5 1 5 5 1 5 5 1 5 5 1 5 5 1 5 5 1 5 5 1 5 5 1 5 5 1 5 5 1 5 5 5 1 5 5 5 1 5 |

***TOL = Thermal Overload**

•.

× .

.

Attachment 1 IN 93-99 December 21, 1993 Page 2 of 2

| Event Notification | <u>Licensee</u> | Event Notification Date | <u>Class</u> |
|--------------------|-----------------------|-------------------------|--------------|
| 00000 | Prairie Island 1 & 2 | November 6, 1992 | 1 |
| 00000 | St. Lucie 1 | November 30, 1992 | 1 |
| 24757 | Maine Yankee | December 15, 1992 | 5 |
| 00000 | Diablo Canyon 1 and 2 | December 22, 1992 | 1 |
| 24845 | Point Beach 1 and 2 | January 7, 1993 | 1 |
| 25248 (TOL) | Pilgrim | March 29, 1993 | 5 |
| 25362 | South Texas | April 6, 1993 | 5 |

Events Notification Number-00000 Licensees whose undervoltage relay setpoint notifications to the NRC were reported by LERs, licensee letter, etc., and event notification numbers if any, were not known.

<u>Class Definitions</u>:

• .

- 1. Undervoltage Relay setpoints were found to be incorrect because of design errors.
- 2. Undervoltage Relay setpoints, as found, were not the same as required by the technical specification.
- 3. Safety load circuit breaker thermal overloads or other trip setpoints were too low because of design errors.
- 4. Safety load circuit breaker thermal overload, or other trip setpoints, as found, were not the same as required by the technical specification.
- 5. Membership in one of the preceding four classes could not be definitely established because of incomplete information in the event notification.

Attachment 2 IN 93-99 December 21, 1993 Page 1 of 1

LIST OF RECENTLY ISSUED NRC INFORMATION NOTICES

| Information Notice No. | Subject | Date of Issuance | Issued to |
|---------------------------|---|---------------------|---|
| 93-98 | Motor Brakes on Valve Actuator Motors | 12/20/93 | All holders of OLs and CPs for nuclear power reactors. |
| 93-97 | Failures of Yokes Installed on Walworth Gate and Globe Valves | 12/17/93 | All holders of OLs or CPs for nuclear power reactors. |
| 93-96 | Improper Reset Causes Emergency Diesel Generator Failures | 12/14/93 | All holders of OLs or CPs for nuclear power reactors. |
| 93-95 | Storm-Related Loss of Offsite Power Events due to Salt Buildup on Switchyard Insulators | 12/13/93 | All holders of OLs or CPs for nuclear power reactors located close to a large body of salt water. |
| 93-94 | Unauthorized Forced Entry into the Pro- tected Area at Three Mile Island Unit 1 on February 7, 1993 | 12/09/93 | All holders of OLs or CPs for nuclear power reactors. |
| 93-93 | Inadequate Control of Reactor Coolant System Conditions During Shutdown | 12/08/93 | All holders of OLs or CPs for nuclear power reactors. |
| 93-92 | Plant Improvements to Mitigate Common Depend- encies in Component Cooling Water Systems | 12/07/93 | All holders of OLs or CPs for nuclear power reactors. |
| 91-21, Supp. 1 | Inadequate Quality Assurance Program of Vendor Supplying Safety-Related Equipment | 12/07/93 | All holders of OLs or CPs for nuclear power reactors and all recipients of NUREG-0040, "License Con- tractor and Vendor Inspec- tion Status Report" (White Book). |

OL = Operating License CP = Construction Permit

•

.

> Original signed by Brian K. Grimes

Brian K. Grimes, Director Division of Operating Reactor Support Office of Nuclear Reactor Regulation

Technical contact: C. Morris, NRR (301) 504-2778

Attachments:

- 1. Representative List of Undervoltage
- Relay Setpoint Revisions 1988-1993
- 2. List of Recently Issued NRC Information Notices

Exception: The stress laid by the initial reviewer on the degree of concern that licensees and the staff should feel for such a widespread and persistent preblem, viz. low UVR set points, has been all but eliminated from the present IN.

> *C.MORRIS (S/D) (SEE PREVIOUS CONC.) 15 NOV. 93

***SEE PREVIOUS CONCURRENCES** D/DORS:NRR *DORS/OGCB * C/OGCB:DORS:NRR NCampbell Grines GHMarcus 07/30/93 08/10/93 12//5/93 ***D/DE:NRR** *RPB:ADM ***SC/EELB:DE:NRR *C/EELB:DE:NRR** *EELB:DE:NRR Tech Ed CMorris CHBerlinger JTWiggins EWWeiss 07/13/93 05/19/93 07/23/93 04/28/93 **05/19/93**

Concurred in electronically by JMain. DOC NAME: 93-99.IN

IN 93-XX November XX, 1993 Page 3 of 3

This information notice requires no specific action or written response. If you have any questions about the information in this notice, please contact the technical contact listed below or the appropriate Office of Nuclear Reactor Regulation (NRR) project manager.

> Brian K. Grimes, Director Division of Operating Reactor Support Office of Nuclear Reactor Regulation

Technical contact: C. Morris, NRR (301) 504-2778

Attachments:

- 1. Representative List of Undervoltage Relay Setpoint Revisions 1988-1993
- 2. List of Recently Issued NRC Information Notices

Exception:

The stress laid by the initial reviewer on the degree of concern that licensees and the staff should feel for such a widespread and persistent problem, viz. low UVR set points, has been all but eliminated from the present IN. \frown

C.MORRIS 15 NOV. 93

Document Name: G:\SHARED\R3UNRELS.IN

| *SEE PREVIOUS | CONCURRENCES | | <pre>electronically by *C/OGCB:DORS:NRR</pre> | JMain. *OGCB:DORS:NRR |
|---------------|------------------------|-------------------------|---|--------------------------|
| | | BKGrimes 11/ /93 mlm |) GHMarcus | NCampbell |
| | | 11/ /93 MUC | 08/10/93 | 07/30/93 |
| *EELB:DE:NRR | *SC/EELB:DE:NRR | *C/EELB:DE:NRR | *D/DE:NRR | *RPB:ADM |
| CMorris | EWWeiss | CHBerlinger | JTWiggins | Tech Ed |
| 04/28/93 | 05/19/93 | 05/19/93 | 07/23/93 | 07/13/93 |

Callup: UNRELSET. IN

IN 93-XX November XX, 1993 Page 3 of 3

This information notice requires no specific action or written response. If you have any questions about the information in this notice, please contact the technical contact listed below or the appropriate Office of Nuclear Reactor Regulation (NRR) project manager.

> Brian K. Grimes, Director Division of Operating Reactor Support Office of Nuclear Reactor Regulation

Technical contact: C. Morris, NRR (301) 504-2778

Attachments:

.

- Representative List of Undervoltage Relay Setpoint Revisions 1988-1993
 List of Recently Issued NRC Information Notices

Document Name: G:\SHARED\R3UNRELS.IN

| *SEE PREVIOUS | CONCURRENCES | <pre># Concurred in D/DORS:NRR BKGrimes</pre> | electronically by *C/OGCB:DORS:NRR GHMarcus | *OGCB:DORS:NRR NCampbell |
|-------------------------|----------------------------|---|---|-----------------------------|
| | | 11/ /93 | 08/10/93 | 07/30/93 |
| *EELB:DE:NRR CMorris | *SC/EELB:DE:NRR EWWeiss | *C/EELB:DE:NRR CHBerlinger | *D/DE:NKR JTWiggins | *RPB:ADM Tech Ed |
| 04/28/93 | 05/19/93 | 05/19/93 | 07/23/93 | 07/13/93 |

> Brian K. Grimes, Director Division of Operating Reactor Support Office of Nuclear Reactor Regulation

Technical contact: C. Morris, NRR (301) 504-2778

Attachments:

1. Representative List of Undervoltage

Relay Setpoint Revisions 1988-1993

2. List of Recently Issued NRC Information Notices

| *SEE PREVIOUS CONCURRENCES Document Name: UNRELSET.IN | | DORS/OGCB NCampbell 07/30/93 | D/DORS:NRR BKGrimes JU 08/ /93 | C/OGCB:DORS:NRR GHMarcus <i>GHM</i> 08/10/93 |
|--|-----------------|------------------------------------|--------------------------------------|--|
| *EELB:DE:NRR | *SC/EELB:DE:NRR | *C/EELB:DE:N | RR *D/DE:NRI | |
| CMorris | EWWeiss | CHBerlinger | JTWiggin: | |
| 04/28/93 | 05/19/93 | 05/19/93 | 07/23/93 | |

Concurred in electronically by JMain.

#5-120

> Brian K. Grimes, Director Division of Operational Events

Assessment

Office of Nuclear Reactor Regulation

Technical contact: C. Morris, NRR (301) 504-2778

Attachments:

1. Representative List of Undervoltage Relay Setpoint Revisions 1988-1993

2. List of Recently Issued NRC Information Notices

| *SEE PREVIOUS Document Name: | | DORS/OGCB NCampbell 07/8•/93 | ダ D/DORS:NRR BKGrimes 07/ /93 | C/OGCB GHMa 07/ | :DORS:NRR rcus /93 |
|---------------------------------|-----------------|------------------------------------|--|-----------------------|--------------------------|
| *EELB:DE:NRR | *SC/EELB:DE:NRR | *C/EELB:DE:N | RR *D/DE: | ins | *RPB:ADM |
| CMorris | EWWeiss | CHBerlinger | JTWigg | | Tech Ed |
| 04/28/93 | 05/19/93 | 05/19/93 | 07/23/ | | 07/13/93 |

Concurred in electronically by JMain.

Brian K. Grimes, Director **Division of Operational Events**

Assessment

Office of Nuclear Reactor Regulation

Technical contact: C. Morris, NRR (301) 504-2778

Attachments:

Representative List of Undervoltage Relay Setpoint Revisions 1988-1993
 List of Recently Issued NRC Information Notices

| *SEE PREVIOUS | CONCURRENCES | | | |
|-----------------------|-------------------|---------------|------------------|---------------|
| Document Name: | UNRELSET.IN | DORS/OGCB | D/DORS:NRR C/ | OGCB:DORS:NRR |
| | | NCampbell | | GHMarcus |
| | | 07/ /93 | 07/ /23 | 07/ /93 |
| *EELB:DE:NRR | *SC/EELB:DE:NRR | *C/EELB:DE:NR | R DIDEANRE | *RPB:ADM |
| CMorris | EWWeiss | CHBerlinger | UTWiggins | Tech Ed |
| 04/28/93 | 05/19/93 | 05/19/93 | 07/27/93 | 07/13/93 |
| # Concurred in | electronically by | JMain. | #5-nb. | |
| | | | Cop | |