

6.8.4.f Primary Containment Leakage Rate Testing Program

A program shall be established, implemented, and maintained to comply with the leakage rate testing of the containment as required by 10CFR50.54(o) and 10CFR50, Appendix J, Option B, as modified by approved exemptions. This program shall be in accordance with the guidelines contained in Regulatory Guide 1.163, "Performance-Based Containment Leak-Test Program", dated September 1995, as modified by the following exception:

- a. NEI 94-01-1995, Section 9.2.3: The first Type A test performed after April 12, 1994 shall be performed no later than April 12, 2009.

The peak calculated containment internal pressure for the design basis loss of coolant accident, P_a , is 48.1 psig.

The maximum allowable primary containment leakage rate, L_a , at P_a , shall be 0.5% of primary containment air weight per day.

Leakage Rate Acceptance Criteria are:

- a. Primary containment leakage rate acceptance criterion is less than or equal to $1.0 L_a$. During the first unit startup following testing in accordance with this program, the leakage rate acceptance criteria are less than or equal to $0.6 L_a$ for Type B and Type C tests and less than or equal to $0.75 L_a$ for Type A tests;
- b. Air lock testing acceptance criteria are:
 - 1) Overall air lock leakage rate is less than or equal to $0.05 L_a$ when tested at greater than or equal to P_a ,
 - 2) Door seal leakage rate less than or equal to 5 scf per hour when the gap between the door seals is pressurized to greater than or equal to 10.0 psig.

The provisions of Specification 4.0.2 do not apply to the test frequencies specified in the Primary Containment Leakage Rate Testing Program.

The provisions of Specification 4.0.3 are applicable to the Primary Containment Leakage Rate Testing Program.

6.8.4.g. Radioactive Effluent Controls Program

A program shall be provided conforming with 10 CFR 50.36a for the control of radioactive effluents and for maintaining the doses to MEMBER(S) OF THE PUBLIC from radioactive effluents as low as reasonably achievable. The program (1) shall be contained in the ODCM, (2) shall be implemented by operating procedures, and (3) shall include remedial actions to be taken whenever the program limits are exceeded. The program shall include the following elements: