

UNITED STATES  
NUCLEAR REGULATORY COMMISSION  
OFFICE OF NUCLEAR REACTOR REGULATION  
WASHINGTON, D.C. 20555

September 16, 1993

NRC INFORMATION NOTICE 93-74: HIGH TEMPERATURES REDUCE LIMITORQUE AC MOTOR OPERATOR TORQUE

Addressees

All holders of operating licenses or construction permits for nuclear power reactors.

Purpose

The U.S. Nuclear Regulatory Commission (NRC) is issuing this information notice to alert addressees that high ambient temperatures can reduce ac motor torque capability in Limitorque motor operators. It is expected that recipients will review the information for applicability to their facilities and consider actions, as appropriate, to avoid similar problems. However, suggestions contained in this information notice are not NRC requirements; therefore, no specific action or written response is required.

Background

In order to size a motor operator to a given valve, the expected operator torque capable of being developed under design-basis conditions is calculated. The operator torque output is directly related to the torque output of the operator motor. For dc motor operators, Limitorque has published derating factors that are applied to high ambient temperature applications. However, until recently, no derating information was available for Limitorque motor operators equipped with ac motors.

Description of Circumstances

In response to NRC questions, Limitorque Corporation established a test program to evaluate whether elevated ambient temperatures could significantly affect ac motor output torque. In October of 1992, Limitorque completed testing of five ac motors. This testing indicated that ac motor stall torque values decreased significantly with increasing ambient temperatures. The measured torque reductions ranged from 14 to 25 percent for ambient temperature increases from 24°C [75°F] to 169°C [336°F]. Limitorque contracted with its main motor supplier, Reliance Motor Co., to calculate the expected stall torque reduction for all Limitorque/Reliance ac motor designs.

On May 13, 1993, Limitorque issued a report about a potential 10 CFR Part 21 condition. The report contained a tabulation of motor types and expected torque reductions for ambient temperature increases from 25°C [77°F] to 180°C

9309100374

PDR I & E Notice 93-074

ID+R-4-C

DF01

[356°F]. This data is given in Attachment 1. Limitorque has since indicated that the torque reductions would be applicable only for motors in ambient conditions above 40°C [104°F] as the motors are designed to deliver full rated torque up to 40°C [104°F].

Limitorque has stated that the torque reduction is linear with respect to temperature. The Limitorque table also contains information on the expected reduction in locked rotor current at elevated temperatures. The reduced locked rotor current would provide a slightly higher motor terminal voltage. Although this would improve the calculated reduced voltage motor performance, it would not compensate for the torque reduction resulting from an elevated temperature. Limitorque further stated that motor temperature rise as a result of prior motor energization and motor run time (valve stroke time) must be accounted for.

Additional information concerning motor operator performance can be found in NRC Inspection Report 99900100/93-01 issued June 28, 1993.

This information notice requires no specific action or written response. If you have any questions about the information in this notice, please contact one of the technical contacts listed below or the appropriate Office of Nuclear Reactor Regulation (NRR) project manager.



Brian K. Grimes, Director  
Division of Operating Reactor Support  
Office of Nuclear Reactor Regulation

Technical contacts: Jeffrey B. Jacobson, NRR  
(301) 504-2977

Thomas G. Scarbrough, NRR  
(301) 504-2794

Attachments:

1. Current/Torque Changes from 25 to 180 Centigrade
2. List of Recently Issued NRC Information Notices

This information notice requires no specific action or written response. If you have any questions about the information in this notice, please contact one of the technical contacts listed below or the appropriate Office of Nuclear Reactor Regulation (NRR) project manager.

Original signed by  
Al Chaffee for/

Brian K. Grimes, Director  
Division of Operating Reactor Support  
Office of Nuclear Reactor Regulation

Technical contacts: Jeffrey B. Jacobson, NRR  
(301) 504-2977

Thomas G. Scarbrough, NRR  
(301) 504-2794

Attachments:

1. Current/Torque Changes from 25 to 180 Centigrade
2. List of Recently Issued NRC Information Notices

\* See Previous Concurrence

|         |            |               |              |             |
|---------|------------|---------------|--------------|-------------|
| OFFICE: | *RSIB:DRIL | *SC:RSIB:DRIL | *C:RSIB:DRIL | *D:DRIL:NRR |
| NAME:   | JBJacobson | DPNorkin      | EVIbro       | CERossi     |
| DATE:   | 08/12/93   | 08/12/93      | 08/13/93     | 08/16/93    |

|         |              |            |          |              |            |
|---------|--------------|------------|----------|--------------|------------|
| OFFICE: | *EMEB:DE     | *OGCB:DORS | *Tech Ed | *C:OGCB:DORS | D:DORS NRR |
| NAME:   | TGScarbrough | RJKiesel   | DGable   | GHMarcus     | BKGrimes   |
| DATE:   | 08/23/93     | 09/01/93   | 09/01/93 | 09/08/93     | 09/16/93   |

Document Name: 93-74.IN

### Current/Torque Changes from 25 to 180 Centigrade

| <u>Start/RPM</u> | <u>Frame</u> | <u>Curve #</u> | <u>% Current<br/>Loss</u> | <u>% Torq<br/>Loss</u> |
|------------------|--------------|----------------|---------------------------|------------------------|
| 2'#/1800         | 56           | M2735A         | 27.8%                     | 20.7%                  |
| 5'#/1800         | 48           | M2734          | 29.0%                     | 18.6%                  |
| 5'#/1800         | 56           | M1658          | 21.8%                     | 21.9%                  |
| 7.5'#/1800       | 56           | M2925          | 22.4%                     | 5.7%                   |
| 10'#/1800        | 56           | M1468          | 26.9%                     | 27.7%                  |
| 15'#/1800        | 56           | M1476          | 23.7%                     | 23.1%                  |
| 25'#/1800        | 56           | M1480          | 23.1%                     | 23.2%                  |
| 40'#/1800        | 56           | M1488          | 21.1%                     | 23.4%                  |
| 60'#/1800        | 56           | M5204          | 20.8%                     | 20.9%                  |
| 60'#/1800        | 180          | SK-59454       | 19.6%                     | 18.2%                  |
| 80'#/1800        | 210          | SK-59423       | 16.1%                     | 15.8%                  |
| 100'#/1800       | 210          | SK-59419A      | 17.0%                     | 13.1%                  |
| 200'#/1800       | 256          | SK-34177       | 13.5%                     | 9.0%                   |
| 250'#/1800       | 256          | SK-34193       | 11.8%                     | 6.9%                   |
| 300'#/1800       | 326          | SK-34183       | 11.7%                     | 5.8%                   |
| 2'#/3600         | 48           | 413018-03      | 28.3%                     | 16.0%                  |
| 5'#/3600         | 48           | M199           | 27.7%                     | 18.5%                  |
| 5'#/3600         | 56           | M1454          | 24.7%                     | 26.8%                  |
| 7.5'#/3600       | 56           | M1457          | 27.6%                     | 16.7%                  |
| 10'#/3600        | 56           | M1458          | 23.5%                     | 30.8%                  |
| 15'#/3600        | 56           | M1460          | 19.2%                     | 21.4%                  |
| 25'#/3600        | 56           | M1463          | 16.2%                     | 24.1%                  |
| 40'#/3600        | 56           | M4635          | 27.9%                     | 15.9%                  |
| 40'#/3600        | 180          | SK-59450       | 16.2%                     | 11.8%                  |
| 60'#/3600        | 210          | SK-59446       | 18.2%                     | 16.5%                  |
| 80'#/3600        | 210          | SK-59448       | 18.0%                     | 18.3%                  |
| 100'#/3600       | 256          | SK-34176       | 14.1%                     | 9.8%                   |
| 150'#/3600       | 256          | SK-34184       | 13.9%                     | 10.0%                  |
| 200'#/3600       | 326          | SK-34188       | 10.5%                     | 3.4%                   |
| 250'#/3600       | 326          | SK-34173       | 9.3%                      | 3.4%                   |
| 300'#/3600       | 326          | SK-34171       | 10.8%                     | 2.9%                   |
| 400'#/3600       | 365          | SK-34800       | 8.8%                      | -1.8%                  |

LIST OF RECENTLY ISSUED  
 NRC INFORMATION NOTICES

| Information Notice No. | Subject  | Date of Issuance | Issued to   |
|------------------------|--|------------------|---|
| 93-73                  | Criminal Prosecution of Nuclear Suppliers for Wrongdoing   | 09/15/93         | All NRC licensees.  |
| 93-72                  | Observations from Recent Shutdown Risk and Outage Management Pilot Team Inspections                | 09/14/93         | All holders of OLs or CPs for nuclear power reactors.                               |
| 93-71                  | Fire at Chernobyl Unit 2   | 09/13/93         | All holders of OLs or CPs for nuclear power reactors.                               |
| 93-70                  | Degradation of Boraflex Neutron Absorber Coupons   | 09/10/93         | All holders of OLs or CPs for nuclear power reactors.                               |
| 93-69                  | Radiography Events at Operating Power Reactors   | 09/02/93         | All holders of OLs or CPs for nuclear power reactors and all radiography licensees. |
| 93-68                  | Failure of Pump Shaft Coupling Caused by Temper Embrittlement during Manufacture                   | 09/01/93         | All holders of OLs or CPs for nuclear power reactors.                               |
| 92-16, Supp. 2         | Loss of Flow from the Residual Heat Removal Pump during Refueling Cavity Draindown                 | 08/23/93         | All holders of OLs or CPs for nuclear power reactors.                               |
| 93-67                  | Bursting of High Pressure Coolant Injection Steam Line Rupture Discs Injures Plant Personnel       | 08/16/93         | All holders of OLs or CPs for nuclear power reactors.                               |
| 93-66                  | Switchover to Hot-Leg Injection Following A Loss-of-Coolant Accident in Pressurized Water Reactors | 08/16/93         | All holders of OLs or CPs for pressurized water reactors.                           |

OL = Operating License  
 CP = Construction Permit

UNITED STATES  
 NUCLEAR REGULATORY COMMISSION  
 WASHINGTON, D.C. 20555-0001

OFFICIAL BUSINESS  
 PENALTY FOR PRIVATE USE, \$300

FIRST CLASS MAIL  
 POSTAGE AND FEES PAID  
 USNRC  
 PERMIT NO. G-67

This information notice requires no specific action or written response. If you have any questions about the information in this notice, please contact one of the technical contacts listed below or the appropriate Office of Nuclear Reactor Regulation (NRR) project manager.

Brian K. Grimes, Director  
 Division of Operating Reactor Support  
 Office of Nuclear Reactor Regulation

Technical contacts: Jeffrey B. Jacobson, NRR  
 (301) 504-2977

Thomas G. Scarbrough, NRR  
 (301) 504-2794

Enclosures:

1. Current/Torque Changes from 25 to 180 Centigrade
2. List of Recently Issued NRC Information Notices

\* See Previous Concurrence

|         |            |               |              |             |
|---------|------------|---------------|--------------|-------------|
| OFFICE: | *RSIB:DRIL | *SC:RSIB:DRIL | *C:RSIB:DRIL | *D:DRIL:NRR |
| NAME:   | JBJacobson | DPNorkin      | EVIbro       | CERossi     |
| DATE:   | 08/12/93   | 08/12/93      | 08/13/93     | 08/16/93    |

|         |              |            |          |                     |            |
|---------|--------------|------------|----------|---------------------|------------|
| OFFICE: | *EMEB:DE     | *OGCB:DORS | *Tech Ed | C:OGCB:DORS         | D:DORS:NRR |
| NAME:   | TGScarbrough | RJKiesel   | DGable   | GHEarcus <i>for</i> | BKGrimes   |
| DATE:   | 08/23/93     | 9/ 1/93    | 9/ 1/93  | 9/8/93              | 9/ 93      |

Document Name: NRCIN.391

*mkm*

for.

Additional information concerning motor operator performance can be found in NRC inspection report 99900100/93-01 issued June 28, 1993.

This information notice requires no specific action or written response. If you have any questions about the information in this notice, please contact one of the technical contacts listed below or the appropriate Office of Nuclear Reactor Regulation (NRR) project manager.

Brian K. Grimes, Director  
Division of Operating Reactor Support  
Office of Nuclear Reactor Regulation

Technical contacts: Jeffrey B. Jacobson, NRR  
(301) 504-2977

Thomas G. Scarbrough, NRR  
(301) 504-2794

Enclosures:

1. Current/Torque Changes from 25 to 180 Centigrade
2. List of Recently Issued NRC Information Notices

Document Name: nrcin.391

\* Previously Concurred

|         |            |               |              |             |
|---------|------------|---------------|--------------|-------------|
| OFFICE: | *RSIB:DRIL | *SC:RSIB:DRIL | *C:RSIB:DRIL | *D:DRIL:NRR |
| NAME:   | JBJacobson | DPNorkin      | EVImbro      | CERossi     |
| DATE:   | 08/12/93   | 08/12/93      | 08/13/93     | 08/16/93    |

|         |              |           |                    |             |            |
|---------|--------------|-----------|--------------------|-------------|------------|
| OFFICE: | *EMEB:DE     | OGCB:DORS | Tech Ed            | C:OGCB:DORS | D:DORS:NRR |
| NAME:   | TGScarbrough | RJKiesse  | <i>W. J. Noble</i> | GHMarcus    | BKGrimes   |
| DATE:   | 08/23/93     | 09/1/93   | 09/1/93            | 09/ /93     | 09/ 93     |

On May 13, 1993, Limatorque issued a "Potential 10 CFR 21 Condition" report which contained a tabulation of motor types and expected torque reductions for ambient temperature increases from 25°C to 180°C. This tabulated data is attached as Enclosure (1). Limatorque has since indicated that the torque reductions would only be applicable for motors in ambient conditions above 40°C as the motors are designed to deliver full rated torque up to 40°C.

Limatorque has stated that the torque reduction is linear with respect to temperature. The Limatorque table also contains information on the expected reduction in locked rotor current at elevated temperatures. The reduced locked rotor current would provide a slightly higher motor terminal voltage. This would improve the calculated reduced voltage motor performance, however, not nearly enough to compensate for the torque reduction due to elevated temperature. Also, Limatorque stated that motor temperature rise due to prior motor energization and motor run time (valve stroke time) must be accounted for.

Additional information concerning motor operator performance can be found in NRC inspection report 99900100/93-01 issued June 28, 1993.

This information notice requires no specific action or written response. If you have any questions about the information in this notice, please contact one of the technical contacts listed below or the appropriate Office of Nuclear Reactor Regulation (NRR) project manager.

Brian K. Grimes, Director  
 Division of Operating Reactor Support  
 Office of Nuclear Reactor Regulation

Technical contacts: Jeffrey B. Jacobson, NRR  
 (301) 504-2977

Thomas G. Scarbrough, NRR  
 (301) 504-2794

Enclosure 1: Current/Torque Changes from 25 to 180 Centigrade

Distribution:

JBJacobson      DPNorkin      EVImbro      RPZimmerman  
 CERossi      BKGrimes      Central Files      DOEA R/F  
 RSIB R/F

\* Previously Concurred

|         |             |              |             |             |
|---------|-------------|--------------|-------------|-------------|
| OFFICE: | RSIB:DRIL   | SC:RSIB:DRIL | TECH EDITOR | C:RSIB:DRIL |
| NAME:   | JBJacobson* | DPNorkin*    |             | EVImbro*    |
| DATE:   | 08/12/93    | 08/12/93     | 08/ /93     | 08/13/93    |
| OFFICE: | D:DRIL:NRR  | EMED/NRR     | D:DOEA:NRR  |             |
| NAME:   | CERossi*    | TGScarbrough | BKGrimes    |             |
| DATE:   | 08/16/93    | 08/24/93     | 08/ /93     |             |



On May 13, 1993, Limatorque issued a "Potential 10 CFR 21 Condition" report which contained a tabulation of motor types and expected torque reductions for ambient temperature increases from 25°C to 180°C. This tabulated data is attached as Enclosure (1). Limatorque has since indicated that the torque reductions would only be applicable for motors in ambient conditions above 40°C as the motors are designed to deliver full rated torque up to 40°C.

Limatorque has stated that the torque reduction is linear with respect to temperature. The Limatorque table also contains information on the expected reduction in locked rotor current at elevated temperatures. The reduced locked rotor current would provide a slightly higher motor terminal voltage. This would improve the calculated reduced voltage motor performance, however, not nearly enough to compensate for the torque reduction due to elevated temperature. Also, Limatorque stated that motor temperature rise due to prior motor energization and motor run time (valve stroke time) must be accounted for.

Additional information concerning motor operator performance can be found in NRC inspection report 99900100/93-01 issued June 28, 1993.

This information notice requires no specific action or written response. If you have any questions about the information in this notice, please contact one of the technical contacts listed below or the appropriate Office of Nuclear Reactor Regulation (NRR) project manager.

Brian K. Grimes, Director *Reactor Support*  
 Division of Operations *Events Assessment*  
 Office of Nuclear Reactor Regulation

Technical contacts: Jeffrey B. Jacobson, NRR  
 (301) 504-2977

Thomas G. Scarbrough, NRR  
 (301) 504-2794

Enclosure 1: Current/Torque Changes from 25 to 180 Centigrade

Distribution:

JBJacobson      DPNorkin      EVImbro      RPZimmerman  
 CERossi      BKGrimes      Central Files      DOEA R/F  
 RSIB R/F

\* Previously Concurred

*→ Add Scarbrough for concurrence*

|         |                      |              |             |             |
|---------|----------------------|--------------|-------------|-------------|
| OFFICE: | RSIB:DRIL            | SC:RSIB:DRIL | TECH EDITOR | C:RSIB:DRIL |
| NAME:   | JBJacobson*          | DPNorkin*    |             | EVImbro*    |
| DATE:   | 08/12/93             | 08/12/93     | 08/ /93     | 08/13/93    |
| OFFICE: | D:DRIL:NRR <i>cm</i> | D:DOEA:NRR   |             |             |
| NAME:   | <i>CERossi</i>       | BKGrimes     |             |             |
| DATE:   | 08/16/93             | 08/ /93      |             |             |

On May 13, 1993, Limatorque issued a "Potential 10 CFR 21 Condition" report which contained a tabulation of motor types and expected torque reductions for ambient temperature increases from 25°C to 180°C. This tabulated data is attached as Enclosure (1). Limatorque has since indicated that the torque reductions would only be applicable for motors in ambient conditions above 40°C as the motors are designed to deliver full rated torque up to 40°C.

Limatorque has stated that the torque reduction is linear with respect to temperature. The Limatorque table also contains information on the expected reduction in locked rotor current at elevated temperatures. The reduced locked rotor current would provide a slightly higher motor terminal voltage. This would improve the calculated reduced voltage motor performance, however, not nearly enough to compensate for the torque reduction due to elevated temperature. Also, Limatorque stated that motor temperature rise due to prior motor energization and motor run time (valve stroke time) must be accounted for.

Additional information concerning motor operator performance can be found in NRC inspection report 99900100/93-01 issued June 28, 1993.

This information notice requires no specific action or written response. If you have any questions about the information in this notice, please contact one of the technical contacts listed below or the appropriate Office of Nuclear Reactor Regulation (NRR) project manager.

Brian K. Grimes, Director  
 Division of Operation Events Assessment  
 Office of Nuclear Reactor Regulation

Technical contacts: Jeffrey B. Jacobson, NRR  
 (301) 504-2977

Thomas G. Scarbrough, NRR  
 (301) 504-2794

Enclosure 1: Current/Torque Changes from 25 to 180 Centigrade

Distribution:

JBJacobson      DPNorkin      EVImbro      RPZimmerman  
 CERossi      BKGrimes      Central Files      DOEA R/F  
 RSIB R/F

\* Previously Concurred

|         |             |              |             |             |
|---------|-------------|--------------|-------------|-------------|
| OFFICE: | RSIB:DRIL   | SC:RSIB:DRIL | TECH EDITOR | C:RSIB:DRIL |
| NAME:   | JBJacobson* | DPNorkin*    |             | EVImbro     |
| DATE:   | 08/12/93    | 08/12/93     | 08/ /93     | 08/13/93    |
| OFFICE: | D:DRIL:NRR  | D:DOEA:NRR   |             |             |
| NAME:   | CERossi     | BKGrimes     |             |             |
| DATE:   | 08/ /93     | 08/ /93      |             |             |

On May 13, 1992, Limatorque issued a "Potential 10 CFR 21 Condition" report which contained a tabulation of motor types and expected torque reductions from 25°C to 180°C. This tabulated data is attached as Enclosure (1). Limatorque has since indicated that the torque reductions would only be applicable for motors in ambient conditions above 40°C as the motors are designed to deliver full rated torque up to 40°C.

Limatorque has also stated that the torque reduction is linear with respect to temperature. The Limatorque table also contains information on the expected reduction in locked rotor current at elevated temperatures. The reduced locked rotor current would provide a slightly higher motor terminal voltage. This would improve the calculated reduced voltage motor performance, however, not nearly enough to compensate for the torque reduction due to elevated temperature. Also, Limatorque stated that motor temperature rise due to prior motor energization and motor run time (valve stroke time) must be accounted for.

Additional information concerning motor operator performance can be found in NRC inspection report 99900100/93-01 Issued June 28, 1993.

This information notice requires no specific action or written response. If you have any questions about the information in this notice, please contact one of the technical contacts listed below or the appropriate Office of Nuclear Reactor Regulation (NRR) project manager.

Brian K. Grimes, Director  
 Division of Operation Events Assessment  
 Office of Nuclear Reactor Regulation

Technical contacts: Jeffrey B. Jacobson, NRR  
 (301) 504-2977

Thomas G. Scarbrough, NRR  
 (301) 504-2794

Enclosure 1: Current/Torque Changes from 25 to 180 Centigrade

Distribution:

JBJacobson            DPNorkin            EVImbro            RPZimmerman  
 CERossi              BKGrimes            Central Files        DOEA R/F  
 RSIB R/F

|         |            |              |             |             |
|---------|------------|--------------|-------------|-------------|
| OFFICE: | RSIB:DRIL  | SC-RSIB:DRIL | TECH EDITOR | G:RSIB:DRIL |
| NAME:   | JBJacobson | DPNorkin     |             | EVImbro     |
| DATE:   | 08/11/93   | 08/11/93     | 08/ /93     | 08/ /93     |
| OFFICE: | D:DRIL:NRR | D:DOEA:NRR   |             |             |
| NAME:   | CERossi    | BKGrimes     |             |             |
| DATE:   | 08/ /93    | 08/ /93      |             |             |