



**TXU Energy**  
Comanche Peak Steam  
Electric Station  
P.O. Box 1002 (E01)  
Glen Rose, TX 76043  
Tel: 254 897 8920  
Fax: 254 897 6652  
lance.terry@txu.com

**C. Lance Terry**  
Senior Vice President &  
Principal Nuclear Officer

Ref: 10 CFR 50.55(a)(g)

**CPSES-200300632**  
**Log # TXX-03065**  
**File # 10010**

**April 9, 2003**

**U. S. Nuclear Regulatory Commission**  
**ATTN: Document Control Desk**  
**Washington, DC 20555**

**SUBJECT: COMANCHE PEAK STEAM ELECTRIC STATION (CPSES)**  
**DOCKET NO. 50-446; RELIEF REQUESTS B-7 Rev. 1, B-8 Rev. 1,**  
**B-9 Rev. 1 and C-6 Rev. 1 TO THE UNIT 2 INSERVICE INSPECTION**  
**(ISI) FROM 1986 EDITION OF ASME CODE, SECTION XI, NO**  
**ADDENDA (INTERVAL START DATE: AUGUST 3, 1993, FIRST**  
**INTERVAL)**

**REFERENCE: TXU Energy Letter logged TXX -02122 dated July 11, 2002 from**  
**C. Lance Terry to the NRC**

**Dear Sir or Madam:**

**Based on the telephone conversation with your staff, TXU Generation Company LP**  
**(hereafter TXU Energy) is revising its relief requests submitted via the above**  
**referenced letter.**

**TXU Energy requests approval of the proposed Relief Request by June 29, 2003. The**  
**approval date was administratively selected to allow for NRC review but the plant**  
**does not require this relief to allow continued safe full power operations.**

**This communication contains no new licensing basis commitments regarding**  
**Comanche Peak Steam Electric Station (CPSES) Unit 2.**

**A member of the STARS (Strategic Teaming and Resource Sharing) Alliance**

**Callaway • Comanche Peak • Diablo Canyon • Palo Verde • South Texas Project • Wolf Creek**

A047

**TXX-03065**

**Page 2 of 2**


**If you have any questions or need additional information regarding this matter, please feel free to contact Douglas W. Snow at (254) 897-8448.**

**Sincerely,**

**TXU Generation Company LP**

**By: TXU Generation Management Company LLC  
Its General Partner**

**C. L. Terry  
Senior Vice President and Principal Nuclear Officer**

**By:   
Fred W. Madden  
Nuclear Licensing Manager**

**OAB/dws**

**Attachments**

**c - E. W. Merschoff, Region IV  
W. D. Johnson, Region IV  
D. H. Jaffe, NRR  
Resident Inspectors, CPSES  
Terry Parks, Chief Inspector, TDLR  
J.C. Hair ANII, CPSES**

**TXU GENERATION COMPANY LP  
COMANCHE PEAK STEAM ELECTRIC STATION UNIT 2  
FIRST TEN-YEAR INTERVAL ISI RELIEF REQUEST NO. B-7 REV 1**

**PROPOSED ALTERNATIVE IN ACCORDANCE WITH 10 CFR 50.55a(g)(5)(iii)  
-INSERVICE INSPECTION IMPRACTICALITY-**

**I. System/Component for Which Relief is Requested:**

ASME Class I Reactor Pressure Vessel (RPV) closure head to flange weld (Weld No. TCX-1-1300-1) and RPV closure head to disc weld (Weld No. TCX-1-1300-2)

**II. Code Requirement from Which Relief is Requested:**

Comanche Peak Unit 2 is currently required to perform inservice examinations of selected welds in accordance with the requirements of 10 CFR 50.55a, and the 1986 Edition with no Addenda of the American Society of Mechanical Engineers (ASME) Boiler and Pressure Vessel Code, Section XI, Rules for Inservice Inspection of Nuclear Power Plant Components. The Code invokes the examination volume requirements of Figures IWB-2500-3 and IWB-2500-5.

Weld No. TCX-1-1300-1:

Table IWB-2500-1. Examination Category B-A, Code Item B1.40, Figure IWB-2500-5. The subject weld is a full penetration weld, and requires 100% volumetric and surface examination of the RPV head to flange welds as defined by Figure IWB-2500-5.

Weld No. TCX-1-1300-2:

Table IWB-2500-1. Examination Category B-A, Code Item B1.21, Figure IWB-2500-3. The subject weld is a full penetration weld, and requires 100% volumetric examination of the accessible portion of all circumferential welds, as defined by Figure IWB-2500-3.

**III. Impracticality of Compliance:**

The examination coverage is limited by physical interferences from the reactor head flange, shroud, and lifting lugs (refer to the attached sketches on pages 9, 10 and 11). Therefore, pursuant to the requirements of 10 CFR 50.55(g)(5)(iii) relief is requested from performing 100% volumetric examination requirements, Figures IWB-2500-3 and IWB-2500-5.

**TXU GENERATION COMPANY LP  
COMANCHE PEAK STEAM ELECTRIC STATION UNIT 2  
FIRST TEN-YEAR INTERVAL ISI RELIEF REQUEST NO. B-7 REV 1**

**PROPOSED ALTERNATIVE IN ACCORDANCE WITH 10 CFR 50.55a(g)(5)(iii)  
-INSERVICE INSPECTION IMPRACTICALITY-  
(Continued)**

**IV. Burden Caused by Compliance:**

The examination coverage is limited by physical interferences from the reactor head flange, shroud, and lifting lugs as indicated via the attached sketches. These conditions make 100% examination impractical for these welds. To gain access for examination, the RPV head would require design modification. Imposition of this requirement would be a significant burden on TXU Energy.

**V. Proposed Alternative and Basis for Use:**

There are no proposed alternatives. TXU ENERGY has examined a significant portion of these welds, obtaining approximately 84% of weld TCX-1-1300-2, and 85% of weld TCX-1-1300-1 of the required volumetric examination coverage. Additionally, 100% of the required surface examination of weld TCX-1-1300-1 was performed. There were no recordable indications identified by the volumetric examinations or surface examination.

The subject welds were examined to the maximum extent possible (approximately 84% and 85% of examination completed in all cases) and yielded no indications. Based on the high percentage of the examination volume completed, and the lack of any reportable indications, there is a high level of confidence in the continued structural integrity of the welds. There is no anticipated impact upon the overall plant quality and safety, and the granting of relief should not jeopardize the health and safety of the public.

The CPSES ISI plan requires 1/3 of each weld be examined each inspection period. The limitations of the first two inspection periods have been previously reviewed and approved under relief request identified in precedents No. 2 and No. 4.

**VI. Duration of Proposed Alternative:**

This relief is requested for the Comanche Peak Steam Electric Station Unit 2, third period of the first 10-year interval vessel examination.


**TXU GENERATION COMPANY LP  
COMANCHE PEAK STEAM ELECTRIC STATION UNIT 2  
FIRST TEN-YEAR INTERVAL ISI RELIEF REQUEST NO. B-7 REV 1**

**PROPOSED ALTERNATIVE IN ACCORDANCE WITH 10 CFR 50.55a(g)(5)(iii)  
-INSERVICE INSPECTION IMPRACTICALITY-  
(Continued)**

**VII. Precedents:**

- 1) TXU Energy letter logged TXX-98170 dated July 22, 1998, NRC response dated July 8, 1999, reference TAC NO. MA3632.
- 2) TXU Energy letter logged TXX-95042 dated March 6, 1995. NRC response dated December 28, 1995, reference TAC NO. M93333 and M93334.
- 3) NRC SER dated November 29, 1994, reference TAC NO. M83125.
- 4) TXU Energy letter logged TXX-01110 dated June 22, 2001. NRC response dated October 11, 2001, reference TAC NO. MB1190.

**PROPOSED ALTERNATIVE IN ACCORDANCE WITH 10 CFR 50.55a(g)(5)(iii)**  
**-INSERVICE INSPECTION IMPRACTICALITY-**  
**(Continued)**



TXU GENERATION COMPANY LP  
COMANCHE PEAK STEAM ELECTRIC STATION UNIT 2  
FIRST TEN-YEAR INTERVAL ISI RELIEF REQUEST NO. B-7 REV 1

PROPOSED ALTERNATIVE IN ACCORDANCE WITH 10 CFR 50.55a(g)(5)(iii)  
-INSERVICE INSPECTION IMPRACTICALITY-  
(Continued)

WESTINGHOUSE NUCLEAR SERVICES DIVISION		REPORT NO. <u>UT-22</u>
LIMITATION TO EXAMINATION		PAGE <u>3</u> OF <u>3</u>
TXU PLANT <u>COMANCHE PEAK</u>	UNIT <u>2</u>	SKETCH <u>TCX-1-1300</u>
SYST/COMP <u>R.V. CLOSURE HEAD</u>	PROCEDURE <u>TX-ISI-218 REV. 4</u>	
EXAMINER <u>N. Bollingmo</u> <i>N.B.</i>	LEVEL <u>III</u>	DATE <u>4-06-02</u>
EXAMINER <u>S. Erickson</u> <i>Scott R. Erickson</i>	LEVEL <u>II</u>	DATE <u>4-06-02</u>
COMPONENT ID <u>TCX-1-1300-1</u>		
RELATED TO	<input type="checkbox"/> MT	<input type="checkbox"/> PT <input checked="" type="checkbox"/> UT <input type="checkbox"/> VT
PROVIDE SUFFICIENT INFORMATION TO DESCRIBE SIZE, LOCATION AND TYPE OF LIMITATION.		
<u>COMMENTS / SKETCH / DETAILS</u>		
15% of required volume not examined. 89% examined with 45° and 60° in at least one direction. 6% of required volume not examined with 45°, and 15% of required volume not examined with 60°.		
<div style="border: 1px solid black; height: 150px; width: 100%; position: relative;"><div style="position: absolute; top: 10px; right: 10px;">Lug</div><div style="position: absolute; bottom: 10px; left: 10px;">Flange</div><div style="position: absolute; top: 50%; left: 10%; transform: translateY(-50%);">C/L Weld 1</div><div style="position: absolute; bottom: 10%; left: 10%;">C/L of Stud Hole 14</div><div style="position: absolute; bottom: 10%; right: 10%;">C/L of Stud Hole 1</div><div style="position: absolute; bottom: 10%; right: 10%;">C/L of Stud Hole 50</div></div> <p style="text-align: center;">see attached coverage plots</p>		

*John H. H. 2*

**PROPOSED ALTERNATIVE IN ACCORDANCE WITH 10 CFR 50.55a(g)(5)(iii)**  
**-INSERVICE INSPECTION IMPRACTICALITY-**  
**(Continued)**

[illegible]



**TXU GENERATION COMPANY LP  
COMANCHE PEAK STEAM ELECTRIC STATION UNIT 2  
FIRST TEN-YEAR INTERVAL ISI RELIEF REQUEST NO. B-7 REV 1**

**PROPOSED ALTERNATIVE IN ACCORDANCE WITH 10 CFR 50.55a(g)(5)(iii)  
-INSERVICE INSPECTION IMPRACTICALITY-  
(Continued)**

PDI		Calibration Data Sheet	
Plant/Unit	Comanche Peak 1/2	Date Sheet #	UT-22
Company	WesDyne	Page	1 of 6
Comp/System	RV Closure Head	Cal Checks	Time
Procedure No	TX-ISI-210	Initial Calib.	1418
Rev/Chng. No	Rev. 4	Initial Calib. Date	4-06-02
Cal Block No	TFX-RV-29	Intermediate	N/A
Cal Block Temp	78° Comp Temp 120°	Intermediate	N/A
Therm S/N	TU-2261	Final Calib.	1554
Size	N/A	Final Calib. Date	4-06-02
<input checked="" type="checkbox"/> Ferritic	<input type="checkbox"/> Austenitic		
Each Maj. or CRT Div.	= 106°/1.56"		
Cal Direction	Axial Circ Both X	Couplant	
Scan Area	I to Weld X II to Weld X	Type	ULTRAGEL II
		Batch	01225
Examination Area/Weld	Access	Recordable Indications	Exam Sens.
TCX-1-1300-1	2 SIDED	Yes No Geom	30 S/59 E
		X NONE	
Remarks/Reasons for incomplete Scan(s) See attached Limitation To Examination sheet Examined from C/L of stud hole 14 thru stud hole 1 to C/L of stud hole 50			
Examiners	N. Ballingmo	Level	III
Reviewer	S. Enckson	Level	II
Date	4-06-02	Date	4-06-02
Date	4-8-02	Further Evaluation Required?	Yes (No)
Search Unit #1		Search Unit #2	
Manufacture: KBA Serial No: 009Y57/2 25 MHz Size: 1.0" Shape: ROUND Exam Angle: 0° Model: HP Measured Angle: 0° Wedge Style: N/A Search Unit Cable Type: RG-174 Length: 20' Intermediate Connectors: 0 Instrument Settings Make/Model: KBA/USN 52R Serial No: SAP 02352 Delay: 1.813" Range: 10.64" M'U Cal/Vol: 2330µs Pulser: SINGLE Damping: 1000Ω Reject: OFF Rep Rate: HIGH Freq: 2-8 MHz Filter: N/A Mode: FULLWAVE Reference Sensitivity (Sens): Axial: N/A Circ: N/A SHD Sensitivity: 12.5 dB		Manufacture: KBA Serial No: 30B954/2 25 MHz Size: 1.5" x 1.0" Shape: RECT. Exam Angle: -5° Model: GAMMA Measured Angle: 45° Wedge Style: NON-INTEGRAL Search Unit Cable Type: RG-174 Length: 20' Intermediate Connectors: 0 Instrument Settings Make/Model: KBA/USN 52R Serial No: SAP 102352 Delay: 5.438" Range: 15.64" M'U Cal/Vol: 1320µs Pulser: SINGLE Damping: 1000Ω Reject: OFF Rep Rate: HIGH Freq: 2-8 MHz Filter: N/A Mode: FULLWAVE Reference Sensitivity (Sens): Axial: 416 dB Circ: 416 dB SHD Sensitivity: N/A	

II Electric Review / Date

Paul M. Blanding 4/14/02

III Electric Level III Review / Date

J. Ragan 4/18/02

ANII Review / Date

J. C. Hair 4/18/02

**PROPOSED ALTERNATIVE IN ACCORDANCE WITH 10 CFR 50.55a(g)(5)(iii)**  
**-INSERVICE INSPECTION IMPRACTICALITY-**  
**(Continued)**

# Calibration Data Sheet

Plan/Unit  
Company  
Comp/System  
Procedure No  
Rev/Chng No  
Cal Block No  
Cal Block Temp  
Therm S/N  
Size  
N/A

Comanche Peak 1/2  
Weidyne  
RV Closure Head  
TXJSI-210  
Rev. 4  
TBI-RV-39  
TK Com Temp 12°  
TU2261  
Scr. 8" 7" T

Date Sheet #  
Page

UT-22A  
2 of 5

Cal Checks  
Initial Calib  
Initial Calib Date  
Intermediate  
Intermediate  
Final Calib  
Final Calib Date

Time  
1422  
4-05-02  
N/A  
N/A  
1550  
4-05-02

☒ Ferritic  
☐ Austenitic

Each Ma or CRT Div. = 2.39°  
Cal Direction: Axial Circ Both X  
Scan Area: I to Weld X  
II to Weld X

Complant  
Type  
Batch

ULTRAGEL II  
01225

Manufacture  
Serial No.  
Size  
Exam Angle  
Measured Angle  
Wedge Style  
Search Unit Cable  
Type  
Intermediate Connectors

KBA  
009XBL/2.25 MHz  
5" x 1.0" Shape RECT  
60° Model GAMMA  
60°  
NON-INTEGRAL  
Search Unit Cable  
RG-174 Length 20'  
0

Make/Model  
Serial No.  
Delay  
M/I Cal/Vol  
Damping  
Rep Rate  
Filter  
Reference Sensitivity (Sens)  
Axial  
SHD Sensitivity  
Further Evaluation Required?

KBA/USN 52R  
SAP 1C2352  
6.625" Range 23.91"  
1320 μs Pulser SINGLE  
1060 Ω Reject CFF  
HIGH Freq 2.8 MHz  
N/A Mode FULLWAVE  
(Sens)  
47.6 dB Circ 47.6 dB  
N/A  
Yes

Make/Model  
Serial No.  
Delay  
M/I Cal/Vol  
Damping  
Rep Rate  
Filter  
Reference Sensitivity (Sens)  
Axial  
SOH Sensitivity

N/A  
N/A  
N/A Range N/A  
N/A Pulse N/A  
N/A Rejected N/A  
N/A Freq N/A  
N/A Mode N/A  
(Sens)  
N/A Circ N/A  
N/A

Examination Area/Weld  
Indications  
Recordable  
Yes No Geom  
Exam Sens

TCX-1-1300-1  
2 SIDED  
X  
NONE  
65.6

Remarks/Reasons for incomplete Scan(s)  
Limitation To Examination sheet  
Examined from C/L of stud  
hole 14 thru stud hole 1 to C/L of stud hole 50

Examiner(s)  
Reviewer  
NIT Electric Review / Date

S. Erickson  
N. Bollingmo  
4/18/02  
Level III  
Date 4-06-02  
4-8-02

Examiner(s)  
Reviewer  
NIT Electric Review / Date

S. Erickson  
N. Bollingmo  
4/18/02  
Level III  
Date 4-06-02  
4-8-02


Examiner(s)  
Reviewer  
NIT Electric Review / Date

S. Erickson  
N. Bollingmo  
4/18/02  
Level III  
Date 4-06-02  
4-8-02

**TXU GENERATION COMPANY LP  
COMANCHE PEAK STEAM ELECTRIC STATION UNIT 2  
FIRST TEN-YEAR INTERVAL ISI RELIEF REQUEST NO. B-7 REV 1**


**PROPOSED ALTERNATIVE IN ACCORDANCE WITH 10 CFR 50.55a(g)(5)(iii)  
-INSERVICE INSPECTION IMPRACTICALITY-**

**(Continued)**




**TXU GENERATION COMPANY LP  
COMANCHE PEAK STEAM ELECTRIC STATION UNIT 2  
FIRST TEN-YEAR INTERVAL ISI RELIEF REQUEST NO. B-7 REV 1**

**PROPOSED ALTERNATIVE IN ACCORDANCE WITH 10 CFR 50.55a(g)(5)(iii)  
-INSERVICE INSPECTION IMPRACTICALITY-  
(Continued)**



**TXU GENERATION COMPANY LP  
COMANCHE PEAK STEAM ELECTRIC STATION UNIT 2  
FIRST TEN-YEAR INTERVAL ISI RELIEF REQUEST NO. B-7 REV 1**

**PROPOSED ALTERNATIVE IN ACCORDANCE WITH 10 CFR 50.55a(g)(5)(iii)  
-INSERVICE INSPECTION IMPRACTICALITY-  
(Continued)**



COVERAGE: ZONE 2		ZONE 1
PARALLEL SCANS	85%	85%
	85%	85%
TRANSVERSE SCANS	67%	69%
	100%	100%
TOTAL:	84%	85%

SCALE: 2:1      T = 7.3"

*Donny L. Gronebold*  
DONALD GRONEBOLD      LV II  
4-6-02      245

**TXU GENERATION COMPANY LP  
COMANCHE PEAK STEAM ELECTRIC STATION UNIT 2  
FIRST TEN-YEAR INTERVAL ISI RELIEF REQUEST NO. B-8 REV 1**

**PROPOSED ALTERNATIVE IN ACCORDANCE WITH 10 CFR 50.55a(g)(5)(iii)  
-INSERVICE INSPECTION IMPRACTICALITY-**

**I. System/Component for Which Relief is Requested:**

ASME Class I Reactor Pressure Vessel (RPV) Lower Vessel Head Circumferential Weld (Weld No. TCX-1-1100-5).

**II. Code Requirement from Which Relief is Requested:**

Comanche Peak Unit 2 is currently required to perform inservice examinations of selected welds in accordance with the requirements of 10 CFR 50.55a, and the 1986 Edition with no Addenda of the American Society of Mechanical Engineers (ASME) Boiler and Pressure Vessel Code, Section XI, Rules for Inservice Inspection of Nuclear Power Plant Components.

Weld No. TCX-1-1100-5:

Table IWB-2500-1. Examination Category B-A, Code Item B1.21, Figure IWB-2500-3. The subject weld is a full penetration weld, and requires 100% volumetric examination of the accessible portion of all circumferential welds, as defined by Figure IWB-2500-3.

**III. Impracticality of Compliance:**

The examination coverage is limited by physical interferences from the reactor vessel bottom mounted instrument tubes (refer to the attached sketches on pages 3 thru 6). Specifically, refer to page 4 of this attachment (lower left hand corner of the sketch), which depicts the periphery penetration. These areas behind the penetrations were not accessible to the ultrasonic scanning sled. However, cameras on the examination tools were used to visually access the areas that were not accessible to the ultrasonic transducer scanning sled. Additionally, Page 6 of this attachment depicts best effort examination coverage results for each examination angle and scan direction.

Therefore, pursuant to the requirements of 10 CFR 50.55(g)(5)(iii) relief is requested from performing 100% volumetric examination requirements Figures IWB-2500-3.

**TXU GENERATION COMPANY LP  
COMANCHE PEAK STEAM ELECTRIC STATION UNIT 2  
FIRST TEN-YEAR INTERVAL ISI RELIEF REQUEST NO. B-8 REV 1**

**PROPOSED ALTERNATIVE IN ACCORDANCE WITH 10 CFR 50.55a(g)(5)(iii)  
-INSERVICE INSPECTION IMPRACTICALITY-  
(Continued)**

**IV. Burden Caused by Compliance:**

The examination coverage is limited by physical interferences from the reactor bottom mounted instrument tubes as indicated via the attached sketches. These conditions make 100% examination impractical for these welds. To gain access for examination, the RPV head would require design modification. Imposition of this requirement would be a significant burden on TXU Energy.

**V. Proposed Alternative and Basis for Use:**

There are no proposed alternatives. The subject welds were examined to the maximum extent possible (approximately 75%) and yielded no indications. Based on the high percentage of the examination volume completed, and the lack of any reportable indications, there is a high level of confidence in the continued structural integrity of the welds. There is no anticipated impact upon the overall plant quality and safety, and the granting of relief should not jeopardize the health and safety of the public.

**VI. Duration of Proposed Alternative:**

This relief is requested for the Comanche Peak Steam Electric Station Unit 2, third period of the first 10-year interval vessel examination.


**VII. Precedents:**

1. TXU Energy letter logged TXX-99030 dated February 17, 1999. NRC response dated September 24, 1999, reference TAC NO. MA4845 and MA6322.

**TXU GENERATION COMPANY LP  
COMANCHE PEAK STEAM ELECTRIC STATION UNIT 2  
FIRST TEN-YEAR INTERVAL ISI RELIEF REQUEST NO. B-8 REV 1**

**PROPOSED ALTERNATIVE IN ACCORDANCE WITH 10 CFR 50.55a(g)(5)(iii)  
-INSERVICE INSPECTION IMPRACTICALITY-**


Continued






**TXU GENERATION COMPANY LP  
COMANCHE PEAK STEAM ELECTRIC STATION UNIT 2  
FIRST TEN-YEAR INTERVAL ISI RELIEF REQUEST NO. B-8 REV 1**

**PROPOSED ALTERNATIVE IN ACCORDANCE WITH 10 CFR 50.55a(g)(5)(iii)  
-INSERVICE INSPECTION IMPRACTICALITY-  
Continued**



**TXU GENERATION COMPANY LP  
COMANCHE PEAK STEAM ELECTRIC STATION UNIT 2  
FIRST TEN-YEAR INTERVAL ISI RELIEF REQUEST NO. B-8 REV 1**

**PROPOSED ALTERNATIVE IN ACCORDANCE WITH 10 CFR 50.55a(g)(5)(iii)  
-INSERVICE INSPECTION IMPRACTICALITY-  
(Continued)**



**TXU GENERATION COMPANY LP  
COMANCHE PEAK STEAM ELECTRIC STATION UNIT 2  
FIRST TEN-YEAR INTERVAL ISI RELIEF REQUEST NO. B-8 REV 1**

**PROPOSED ALTERNATIVE IN ACCORDANCE WITH 10 CFR 50.55a(g)(5)(iii)  
-INSERVICE INSPECTION IMPRACTICALITY-  
(Continued)**

<b>Comanche Peak Unit #2 (TCX)</b>				<b>DIRECTION / ORIENTATION</b>						
<b>RPV COVERAGE ESTIMATE BREAKDOWNS</b>				PARALLEL SCANS <u>CCW / CW</u> PERP. SCANS <u>UP / DN</u>						
ITEM / AREA <u>Lower Head Circ</u>				WELD NO. <u>TCX-1-1100-5</u>						
<b>BEAM ANGLES</b>										
BEAM DIRECTION	45° L Dual		45° L Single		45° Shear					
	WELD	VOLUME	WELD	VOLUME	WELD	VOLUME	WELD	VOLUME	WELD	VOLUME
CCW	78.8	78.8	78.8	78.8	78.8	78.8				
CW	78.8	78.8	78.8	78.8	78.8	78.8				
UP (LS)	(1) 74	(1) 71	(1) 71	(1) 70	(1) 75	(1) 72				
DOWN (OUT)	(1) 74	(1) 71	(1) 71	(1) 70	(1) 75	(1) 72				
BORE AXIAL										

(1) Combination of dual sided and single sided scans

Combined Coverage = 75.5%

ANALYST JS

**TXU GENERATION COMPANY LP  
COMANCHE PEAK STEAM ELECTRIC STATION UNIT 2  
FIRST TEN-YEAR INTERVAL ISI RELIEF REQUEST NO. B-9 REV 1**

**PROPOSED ALTERNATIVE IN ACCORDANCE WITH 10 CFR 50.55a(g)(5)(iii)  
-INSERVICE INSPECTION IMPRACTICALITY-**

**I. System/Component for Which Relief is Requested:**

**ASME Class I Reactor Pressure Vessel (RPV) Outlet Nozzle to Shell Welds.**

**RPV Nozzle-to-Vessel Weld (Weld No. TCX-1-1100A-19)**

**RPV Nozzle-to-Vessel Weld (Weld No. TCX-1-1100A-22)**

**RPV Nozzle-to-Vessel Weld (Weld No. TCX-1-1100A-23)**

**RPV Nozzle-to-Vessel Weld (Weld No. TCX-1-1100A-26)**

**II. Code Requirement from Which Relief is Requested:**

Comanche Peak Unit 2 is currently required to perform inservice examinations of selected welds in accordance with the requirements of 10 CFR 50.55a, and the 1986 Edition with no Addenda of the American Society of Mechanical Engineers (ASME) Boiler and Pressure Vessel Code, Section XI, Rules for Inservice Inspection of Nuclear Power Plant Components. The subject welds are described in Table IWB-2500-1, Examination Category B-D, and Full Penetration Welds of Nozzles in Vessels, Code Item B3.90, Figures IWB-2500-7(b), and requires volumetric examination of these welds.

**III. Impracticality of Compliance:**

The examination coverage is limited by area geometries of the reactor vessel outlet nozzles. Best effort examination resulted in volumetric coverage of approximately 84.4% due to weld and vessel shell configuration. It is impractical to obtain a volumetric coverage of 100% required by the Code for each of the subject welds unless the RPV is redesigned to improve access to the welds.

Therefore, pursuant to the requirements of 10 CFR 50.55(g)(5)(iii) relief is requested from performing 100% volumetric examination requirements Figures IWB-2500-7(b).

**IV. Burden Caused by Compliance:**

The examination coverage is limited by area geometries of the reactor vessel outlet nozzles, as indicated via the attached sketch on page 4. The examination tool used for this volumetric exam has been used to examine reactor vessels of similar designs at other plants with similar coverage results. These conditions make 100% examination impractical for these welds. To gain access for examination would require design modification. Imposition of this requirement would be a significant burden on TXU Energy.

**TXU GENERATION COMPANY LP  
COMANCHE PEAK STEAM ELECTRIC STATION UNIT 2  
FIRST TEN-YEAR INTERVAL ISI RELIEF REQUEST NO. B-9 REV 1**

**PROPOSED ALTERNATIVE IN ACCORDANCE WITH 10 CFR 50.55a(g)(5)(iii)  
-INSERVICE INSPECTION IMPRACTICALITY-**

Continued

**V. Proposed Alternative and Basis for Use:**

The are no proposed alternatives. TXU Energy has examined a significant portion of the weld, obtaining approximately 84.4% of the required volumetric examination coverage (see typical Table on page 5). Essentially 100% of the examination volume for each weld was examined in the axial scan direction from nozzle inside bore by techniques designed for the detection and sizing of surface and subsurface flaws oriented in a plane normal to the vessel inside surface and parallel to the weld. The examination performed in this manner emphasizes the detection of the types of flaws that can result from welding processes or inservice conditions. There were no recordable indications identified by the volumetric examination.

Additionally, cameras on the examination tool were used to visually access areas that were not accessible to the ultrasonic transducer scanning sled.

The subject welds were examined to the maximum extent possible (approximately 84% and 84.4% of examination completed in all cases) and yielded no indications. Based on the high percentage of the examination volume completed, and the lack of any reportable indications, there is a high level of confidence in the continued structural integrity of the welds. There is no anticipated impact upon the overall plant quality and safety, and the granting of relief should not jeopardize the health and safety of the public.

**VI. Duration of Proposed Alternative:**


This relief is requested for the Comanche Peak Steam Electric Station Unit 2, third period of the first 10-year interval vessel examination.

**VII. Precedents:**

- 1) TXU Energy letter logged TXX-99030 dated February 17, 1999. NRC response dated September 24, 1999, reference TAC NO. MA4845 and MA6322.


**TXU GENERATION COMPANY LP  
COMANCHE PEAK STEAM ELECTRIC STATION UNIT 2  
FIRST TEN-YEAR INTERVAL ISI RELIEF REQUEST NO. B-9 REV 1**

**PROPOSED ALTERNATIVE IN ACCORDANCE WITH 10 CFR 50.55a(g)(5)(iii)  
-INSERVICE INSPECTION IMPRACTICALITY-  
(Continued)**



**TXU GENERATION COMPANY LP  
COMANCHE PEAK STEAM ELECTRIC STATION UNIT 2  
FIRST TEN-YEAR INTERVAL ISI RELIEF REQUEST NO. B-9 REV 1**

**PROPOSED ALTERNATIVE IN ACCORDANCE WITH 10 CFR 50.55a(g)(5)(iii)  
-INSERVICE INSPECTION IMPRACTICALITY-  
(Continued)**



**TXU GENERATION COMPANY LP  
COMANCHE PEAK STEAM ELECTRIC STATION UNIT 2  
FIRST TEN-YEAR INTERVAL ISI RELIEF REQUEST NO. B-9 REV 1**

**PROPOSED ALTERNATIVE IN ACCORDANCE WITH 10 CFR 50.55a(g)(5)(iii)  
-INSERVICE INSPECTION IMPRACTICALITY-**

Continued

<b>Comanche Peak Unit #2 (TCX)</b>					<b>DIRECTION / ORIENTATION</b>					
<b>RPV COVERAGE ESTIMATE BREAKDOWNS</b>					<b>PARALLEL SCANS</b>		<b>CCW / CW</b>			
					<b>PERP. SCANS</b>		<b>Bore Axial</b>			
ITEM / AREA <u>Outlet Nozzle to Shell @ 22°</u>					WELD NO. <u>TCX-1-1100A-28</u>		<i>Typical</i>			
<b>BEAM ANGLES</b>										
BEAM DIRECTION	10° L		60° L		45° L Dual		45° L Single		45° Shear	
	WELD	VOLUME	WELD	VOLUME	WELD	VOLUME	WELD	VOLUME	WELD	VOLUME
CCW					100	100	5	62	55	90
CW					100	100	5	62	55	90
UP (IN)										
DOWN (OUT)										
BORE AXIAL	(1) 100	(1) 100	(1) 100	(1) 100						

(1) Combined Coverage Bore Axial = 100%  
(2) Tan Scan Coverage = 68.7%

ANALYST *SS*

**Combined Coverage = 84.4%**



**TXU GENERATION COMPANY LP  
COMANCHE PEAK STEAM ELECTRIC STATION UNIT 2  
FIRST TEN-YEAR INTERVAL ISI RELIEF REQUEST NO. C-6 REV 1**

**PROPOSED ALTERNATIVE IN ACCORDANCE WITH 10 CFR 50.55a(g)(5)(iii)  
-INSERVICE INSPECTION IMPRACTICALITY-**

**I. System/Component for Which Relief is Requested:**

Chemical and Volume Control (CVCS) Pump TCX-CSAPCH-01. ASME Class 2  
Integrally Welded Pump Attachments.

Weld No. TCX-2-3110-3WS

Weld No. TCX-2-3110-4WS

**II. Code Requirement from Which Relief is Requested:**

Comanche Peak Unit 2 is currently required to perform inservice examinations of selected welds in accordance with the requirements of 10 CFR 50.55a, and the 1986 Edition with no Addenda of the American Society of Mechanical Engineers (ASME) Boiler and Pressure Vessel Code, Section XI, Rules for Inservice Inspection of Nuclear Power Plant Components. The subject welds are described in Table IWC-2500-1, Examination Category C-C, Code Item B3.30, Figures IWC-2500-5, and requires surface examination of these welds.

**III. Impracticality of Compliance:**

The examination coverage is limited due to interference from the housing seal and pump base plate, refer to the attached pictures of the welded attachment (typical for all 4 attachments). Therefore, the Code required 100% surface examination by liquid penetrant method could not be achieved. Best effort examination resulted in coverage of approximately 77% of the area. As depicted via the pictures, it is impractical to obtain coverage of 100% required by the Code for each of the subject welds unless the CVCS Pump is redesigned or completely removed of the pedestal to improve access to the welds.

Therefore, pursuant to the requirements of 10 CFR 50.55(g)(5)(iii) relief is requested from performing 100% volumetric examination requirements of Examination Category C-C, Code Item B3.30, Figures IWC-2500-5.

**TXU GENERATION COMPANY LP  
COMANCHE PEAK STEAM ELECTRIC STATION UNIT 2  
FIRST TEN-YEAR INTERVAL ISI RELIEF REQUEST NO. C-6 REV 1**

**PROPOSED ALTERNATIVE IN ACCORDANCE WITH 10 CFR 50.55a(g)(5)(iii)  
-INSERVICE INSPECTION IMPRACTICALITY-**

Continued

**IV. Burden Caused by Compliance:**

The examination coverage is limited by area geometries of the CVCS pump housing seal and pump base plate, as indicated via the attached sketches on pages 4 thru 7. These conditions make 100% examination impractical for these welds. To gain access for examination would require design modification. Imposition of this requirement would be a significant burden on TXU Energy.

**V. Proposed Alternative and Basis for Use:**

There are no proposed alternatives. TXU ENERGY has examined a significant portion of these welds, obtaining approximately 77% of the required volumetric examination coverage. There were no recordable indications identified by the liquid penetrant surface examination. An attempt to visually inspect the welds was done, however, physical geometry of the location would not permit the visual examination of the entire weld area, which was obstructed by the base plate. The best effort visual examination did not reveal any matters of concern regarding the structural integrity of the accessible weld.

The subject welds were examined to the maximum extent possible (approximately 77% of the weld) and yielded no indications. A review of the previous inspection results did not identify any abnormal results for the subject welds. A visual examination of the welds (using an inspection mirror) did not reveal any reportable indications. A few utilities were polled to determine if any failures had occurred for the same welds. No matters of concern were identified. The stresses on the mounting foot attachments of the pump were reviewed, it was ascertained that the maximum stresses in the components are lower than those allowed and the bearing loads are well within the allowable limits. Therefore, TXU Energy believes the structural integrity and operability of the unit would not be affected by the most severely postulated loading conditions. Based on the high percentage of the examination volume completed, and the lack of any reportable indications, there is a high level of confidence in the continued structural integrity of the welds. There is no anticipated impact upon the overall plant quality and safety, hence, granting of relief should not jeopardize the health and safety of the public.

**VI. Duration of Proposed Alternative:**

This relief is requested for the Comanche Peak Steam Electric Station Unit 2, third period of the first 10-year interval vessel examination.

**TXU GENERATION COMPANY LP  
COMANCHE PEAK STEAM ELECTRIC STATION UNIT 2  
FIRST TEN-YEAR INTERVAL ISI RELIEF REQUEST NO. C-6 REV 1**

**PROPOSED ALTERNATIVE IN ACCORDANCE WITH 10 CFR 50.55a(g)(5)(iii)  
-INSERVICE INSPECTION IMPRACTICALITY-**

**Continued**

**VII. Precedents:**

- 1) TXU Energy letter logged TXX-93107 dated March 15, 1993. NRC response dated November 29, 1994, reference TAC NO. M83125.

**TXU GENERATION COMPANY LP  
COMANCHE PEAK STEAM ELECTRIC STATION UNIT 2  
FIRST TEN-YEAR INTERVAL ISI RELIEF REQUEST NO. C-6 REV 1**

**PROPOSED ALTERNATIVE IN ACCORDANCE WITH 10 CFR 50.55a(g)(5)(iii)  
-INSERVICE INSPECTION IMPRACTICALITY-**

Continued



<small>NOTES: • PUMP DESIGNATION PRECEDES ITEM IDENTIFICATION</small>	<small>DESCRIPTION: ES CHARGING PUMPS 1 &amp; 2</small>	<small>ILLUSTRATIVE USE ONLY</small> <div style="text-align: center; font-weight: bold;">TU ELECTRIC CPSES UNIT 2</div>
<small>APPROVAL:</small> <i>R. May 10/10/09 9-1-11</i>		<small>INSERVICE INSPECTION LOCATION ISOMETRIC</small> <div style="display: flex; justify-content: space-between; font-size: small;"> <span>ICR-2-3110</span> <span>REV. 1</span> <span>09-01-94</span> </div>

**PROPOSED ALTERNATIVE IN ACCORDANCE WITH 10 CFR 50.55a(g)(5)(iii)**  
**-INSERVICE INSPECTION IMPRACTICALITY-**  
**Continued**

[illegible]

**TXU GENERATION COMPANY LP  
COMANCHE PEAK STEAM ELECTRIC STATION UNIT 2  
FIRST TEN-YEAR INTERVAL ISI RELIEF REQUEST NO. C-6 REV 1**

**PROPOSED ALTERNATIVE IN ACCORDANCE WITH 10 CFR 50.55a(g)(5)(iii)  
-INSERVICE INSPECTION IMPRACTICALITY-  
(Continued)**

	<b>WESTINGHOUSE NUCLEAR SERVICES DIVISION</b>	REPORT NO. <u>PT-02</u> PAGE <u>2</u> OF <u>2</u>
<b>LIMITATION TO EXAMINATION</b>		
<b>TXU</b> PLANT <u>COMANCHE PEAK</u> UNIT <u>2</u> SKETCH <u>TCX-2-3100</u>		
SYST / COMP <u>Centrifugal Charging Pump I</u>	PROCEDURE <u>TX-ISI-11 Rev. 6</u>	
EXAMINER <u>J. Peniak</u> <i>[Signature]</i> LEVEL <u>II</u> DATE <u>3-20-02</u>		
EXAMINER <u>L. Musety</u> <i>[Signature]</i> LEVEL <u>II</u> DATE <u>3-20-02</u>		
COMPONENT ID <u>3 WS &amp; 4 WS</u>		
RELATED TO <input type="checkbox"/> MT <input checked="" type="checkbox"/> PT <input type="checkbox"/> UT <input type="checkbox"/> VT		
PROVIDE SUFFICIENT INFORMATION TO DESCRIBE SIZE, LOCATION AND TYPE OF LIMITATION.		
COMMENTS / SKETCH / DETAILS		
		
TYPICAL 3 WS + 4 WS		
23% OF REQUIRED VOLUME NOT EXAMINED OF 3WS + 4WS		
TX ELECTRIC REVIEW DATE <u>4/14/02</u> <i>[Signature]</i>	TX ELECTRIC LEVEL III REVIEW DATE <u>4/6/02</u> <i>[Signature]</i>	APPROVED DATE <u>4/6/02</u> <i>[Signature]</i>

**TXU GENERATION COMPANY LP  
COMANCHE PEAK STEAM ELECTRIC STATION UNIT 2  
FIRST TEN-YEAR INTERVAL ISI RELIEF REQUEST NO. C-6 REV 1**

**PROPOSED ALTERNATIVE IN ACCORDANCE WITH 10 CFR 50.55a(g)(5)(iii)  
-INSERVICE INSPECTION IMPRACTICALITY-  
(Continued)**

