

3.7 PLANT SYSTEMS

3.7.5 Control Building Chiller (CBC) System

LCO 3.7.5 Two CBC subsystems shall be OPERABLE.

APPLICABILITY: MODES 1, 2, and 3,
During movement of irradiated fuel assemblies in the
secondary containment,
During CORE ALTERATIONS,
During Operations with a Potential for Draining the Reactor
Vessel (OPDRVs).

ACTIONS

CONDITION	REQUIRED ACTION	COMPLETION TIME
A. One CBC subsystem inoperable.	A.1 -----NOTE----- LCO 3.0.4 is not applicable.* ----- Restore CBC subsystem to OPERABLE status.	30 days
B. Required Action and associated Completion Time of Condition A not met in MODE 1, 2, or 3.	B.1 Be in MODE 3.	12 hours
	<u>AND</u> B.2 Be in MODE 4.	36 hours

(continued)

* This is a temporary allowance which expires on May 16, 2003.

BASES

- APPLICABILITY
(continued)
- a. During Operations with a Potential for Draining the Reactor Vessel (OPDRVs);
 - b. During CORE ALTERATIONS; and
 - c. During movement of irradiated fuel assemblies in the secondary containment.
-

ACTIONS

A.1

With one CBC subsystem inoperable, the inoperable CBC subsystem must be restored to OPERABLE status within 30 days. With the unit in this condition, the remaining OPERABLE CBC subsystem is adequate to perform the control building air conditioning function. However, the overall reliability is reduced because a single failure in the OPERABLE subsystem could result in loss of the control building air conditioning function. The 30 day Completion Time is based on the low probability of an event occurring requiring control building isolation, the consideration that the remaining subsystem can provide the required protection, and the availability of alternate cooling methods.

Required Action A.1 has been modified by a Note that indicates that the provisions of LCO 3.0.4 are not applicable. As a result, a MODE change is allowed when one CBC subsystem is inoperable. This allowance is provided because of the low probability of an event occurring requiring control building isolation and the redundancy of the remaining portions of the system.

As annotated, this is a temporary allowance which will expire on May 16, 2003, 30 days after the planned entry into MODE 2 from MODE 4. The 30 days corresponds to the Completion Time of Condition A, and represents the maximum time that this allowance may be utilized.

B.1 and B.2

In MODE 1, 2, or 3, if the inoperable CBC subsystem cannot be restored to OPERABLE status within the associated Completion Time, the unit must be placed in a MODE that minimizes risk. To achieve this status, the unit must be

(continued)

BASES (continued)

ACTIONS

B.1 and B.2 (continued)

placed in at least MODE 3 within 12 hours and in MODE 4 within 36 hours. The allowed Completion Times are reasonable, based on operating experience, to reach the required unit conditions from full power conditions in an orderly manner and without challenging unit systems.

C.1, C.2.1, C.2.2, and C.2.3

LCO 3.0.3 is not applicable in MODE 4 or 5. However, since irradiated fuel assembly movement can occur in MODE 1, 2, or 3, the Required Actions of Condition C are modified by a Note indicating that LCO 3.0.3 does not apply. If moving irradiated fuel assemblies while in MODE 1, 2, or 3, the fuel movement is independent of reactor operations. Therefore, inability to suspend movement of irradiated fuel assemblies is not sufficient reason to require a reactor shutdown.

During movement of irradiated fuel assemblies in the secondary containment, during CORE ALTERATIONS, or during OPDRVs, if Required Action A.1 cannot be completed within the required Completion Time, the OPERABLE CBC subsystem may be placed immediately in operation. This action ensures that the remaining subsystem is OPERABLE, that no failures that would prevent actuation will occur, and that any active failure will be readily detected.

An alternative to Required Action C.1 is to immediately suspend activities that present a potential for releasing radioactivity that might require isolation of the control room. This places the unit in a condition that minimizes risk.

If applicable, CORE ALTERATIONS and movement of irradiated fuel assemblies in the secondary containment must be suspended immediately. Suspension of these activities shall not preclude completion of movement of a component to a safe position. Also, if applicable, actions must be initiated immediately to suspend OPDRVs to minimize the probability of a vessel draindown and subsequent potential for fission product release. Actions must continue until the OPDRVs are suspended.

(continued)

BASES

ACTIONS

D.1

If both CBC subsystems are inoperable in MODE 1, 2, or 3, the CBC System may not be capable of performing the intended function. Therefore, LCO 3.0.3 must be entered immediately.

E.1, E.2, and E.3

LCO 3.0.3 is not applicable in MODE 4 or 5. However, since irradiated fuel assembly movement can occur in MODE 1, 2, or 3, the Required Actions of Condition E are modified by a Note indicating that LCO 3.0.3 does not apply. If moving irradiated fuel assemblies while in MODE 1, 2, or 3, the fuel movement is independent of reactor operations. Therefore, inability to suspend movement of irradiated fuel assemblies is not a sufficient reason to require a reactor shutdown.

During movement of irradiated fuel assemblies in the secondary containment, during CORE ALTERATIONS, or during OPDRVs, with two CBC subsystems inoperable, action must be taken immediately to suspend activities that present a potential for releasing radioactivity that might require isolation of the control building. This places the unit in a condition that minimizes risk.

If applicable, CORE ALTERATIONS and handling of irradiated fuel in the secondary containment must be suspended immediately. Suspension of these activities shall not preclude completion of movement of a component to a safe position. Also, if applicable, actions must be initiated immediately to suspend OPDRVs to minimize the probability of a vessel draindown and subsequent potential for fission product release. Actions must continue until the OPDRVs are suspended.

SURVEILLANCE
REQUIREMENTS

SR 3.7.5.1

This SR verifies that the heat removal capability of the system is sufficient to remove available control building heat load. The 92 day Frequency is appropriate since significant degradation of the CBC System is not expected over this time period.

REFERENCES

1. UFSAR, Section 9.4.4.2.