

JUL 21 1983

TO ALL HOLDERS OF OPERATING LICENSES, APPLICANTS FOR OPERATING LICENSES AND HOLDERS OF CONSTRUCTION PERMITS FOR POWER REACTORS

Gentlemen:

Subject: Deletion of Standard Technical Specification Surveillance Requirement 4.8.1.1.2.d.6 for Diesel Generator Testing (Generic Letter No. 83-30)

It has come to our attention that diesel generator Surveillance Requirement 4.8.1.1.2.d.6 in the Standard Technical Specifications (STS) should be deleted. The current revision of the STS for all power reactors is not consistent with the provisions of GDC 17, Regulatory Guide 1.108 and the NRC Standard Review Plans (SRPs 8.2 and 8.3.1). In order to rectify this inconsistency, the Surveillance Requirements for diesel generator testing have been modified to delete a requirement which is in excess of the scope of GDC 17.

We have enclosed the revised Surveillance Requirements for diesel generator testing that are to be used in your submittal of proposed Technical Specifications, or, if your proposed Technical Specifications have already been submitted, the staff will make the necessary revisions. If you already hold a operating license which includes this Surveillance Requirement, you may propose an amendment to your Technical Specifications in accordance with the enclosed revised Surveillance Requirements. These changes will be incorporated in the next revision of the STS for all power reactors. The generic changes are indicated by a line in the margin of the Surveillance Requirements.

This request has been approved by OMB Clearance Number 3150-0011 which expires April 30, 1985.

Original signed by Robert A. Purple

[Signature] Darrell G. Eisenhut, Director Division of Licensing

8306270411

Enclosure: "Revised Surveillance Requirements for Diesel Generator Testing"

Dupe PDR

~~8306270411~~
EXACT ON FICHE

[Handwritten] ✓ IDIR-5
INFO-
LTR.

OFFICE	SSPB:DL <i>[Signature]</i>	SSPB:DL <i>[Signature]</i>	SSPB:DL <i>[Signature]</i>	SSPB:DL <i>[Signature]</i>	D:DL <i>[Signature]</i>		
SURNAME	DHoffman:kab	DBrinkman	CThomas	Pirraglia	DEisenhut		
DATE	6/21/83	6/21/83	6/21/83	6/20/83	6/19/83		

ENCLOSURE

Revised Surveillance Requirements
for Diesel Generator Testing

4.8.1.1.2 Each diesel generator shall be demonstrated OPERABLE:

- a. (No change)
- b. (No change)
- c. (No change)
- d. At least once per 18 months during shutdown by:
 1. (No change)
 2. (No change)
 3. (No change)
 4. (No change)
 5. (No change)
 6. Delete Surveillance Requirement which reads:
"Verifying that on a simulated loss of the diesel generator, with offsite power not available, the loads are shed from the emergency busses and that subsequent loading of the diesel generator is in accordance with design requirements."
6. (Was Item 7 - no change)
 7. (Was Item 8 - no change)
 8. (Was Item 9 - no change)
 9. (Was Item 10 - no change)
 10. (Was Item 11 - no change)
 11. (Was Item 12 - no change)
 12. (Was Item 13 - no change)
 13. (Was Item 14 - no change)
- e. (No change)
- f. (No change)