

- ERRATA -

UNITED STATES
NUCLEAR REGULATORY COMMISSION
OFFICE OF NUCLEAR REACTOR REGULATION
WASHINGTON, D.C. 20555-0001

August 23, 1999

NRC GENERIC LETTER 99-02 (ERRATA): LABORATORY TESTING OF NUCLEAR-GRADE
ACTIVATED CHARCOAL

Addressees

All holders of operating licenses for nuclear power reactors, except those who have permanently ceased operations and have certified that fuel has been permanently removed from the reactor vessel.

Discussion

A typographical error has been identified in Generic Letter 99-02, "Laboratory Testing of Nuclear-Grade Activated Charcoal," issued on June 3, 1999, that makes the sentence in which it appears technically incorrect. This sentence appears in two places, namely, in Requested Actions 2 and 3, on page 7 of the generic letter. The affected sentence reads "If the system has a face velocity greater than 10 percent of 0.203 m/s (40 ft/min), then the revised TS [technical specification] should specify the face velocity." This sentence should read "If the system has a face velocity greater than 110 percent of 0.203 m/s (40 ft/min), then the revised TS should specify the face velocity."

If you have any questions about this matter, please contact one of the staff members listed below or the appropriate Office of Nuclear Reactor Regulation (NRR) project manager.



David B. Matthews, Director
Division of Regulatory Improvement Programs
Office of Nuclear Reactor Regulation

Technical contact: John P. Segala, NRR
301-415-1858
Internet: jps1@nrc.gov

Lead project manager: Brenda L. Mozafari, NRR
301-415-2020
Internet: blm@nrc.gov

*Attachment filed
in JACKET.*

9908060152

updated on 9/28/99

PDR ADOCK 05000003 990823

J. M. Knight
OPI-17

- ERRATA -
UNITED STATES
NUCLEAR REGULATORY COMMISSION
OFFICE OF NUCLEAR REACTOR REGULATION
WASHINGTON, D.C. 20555-0001

August 23, 1999

NRC GENERIC LETTER 99-02 (ERRATA): LABORATORY TESTING OF NUCLEAR-GRADE
ACTIVATED CHARCOAL

Addressees

All holders of operating licenses for nuclear power reactors, except those who have permanently ceased operations and have certified that fuel has been permanently removed from the reactor vessel.

Discussion

A typographical error has been identified in Generic Letter 99-02, "Laboratory Testing of Nuclear-Grade Activated Charcoal," issued on June 3, 1999, that makes the sentence in which it appears technically incorrect. This sentence appears in two places, namely, in Requested Actions 2 and 3, on page 7 of the generic letter. The affected sentence reads "If the system has a face velocity greater than 10 percent of 0.203 m/s (40 ft/min), then the revised TS [technical specification] should specify the face velocity." This sentence should read "If the system has a face velocity greater than 110 percent of 0.203 m/s (40 ft/min), then the revised TS should specify the face velocity."

If you have any questions about this matter, please contact one of the staff members listed below or the appropriate Office of Nuclear Reactor Regulation (NRR) project manager.

Original signed by
Scott F. Newberry FOR

David B. Matthews, Director
Division of Regulatory Improvement Programs
Office of Nuclear Reactor Regulation

Technical contact: John P. Segala, NRR
301-415-1858
Internet: jps1@nrc.gov

Lead project manager: Brenda L. Mozafari, NRR
301-415-2020
Internet: blm@nrc.gov

DOCUMENT NAME: G:\REXB\jws\errata.wpd

To receive a copy of this document, indicate in the box C=Copy w/o attachment/enclosure E=Copy with attachment/enclosure N = No copy

OFFICE	REXB		Tech Ed		SPLB		C:REXB		D:DRIP	
NAME	JShapaker				JHannon		LMarsh		DMatthews	
DATE	8/16/99		7/15/99		8/11/99		8/11/99		8/17/99	

OFFICIAL RECORD COPY

9908060152

updated on 9/28/99

- ERRATA -
 UNITED STATES
 NUCLEAR REGULATORY COMMISSION
 OFFICE OF NUCLEAR REACTOR REGULATION
 WASHINGTON, D.C. 20555-0001

August 23, 1999

**NRC GENERIC LETTER 99-02 (ERRATA): LABORATORY TESTING OF NUCLEAR-GRADE
 ACTIVATED CHARCOAL**

Addressees

All holders of operating licenses for nuclear power reactors, except those who have permanently ceased operations and have certified that fuel has been permanently removed from the reactor vessel.

Discussion

A typographical error has been identified in Generic Letter 99-02, "Laboratory Testing of Nuclear-Grade Activated Charcoal," issued on June 3, 1999, that makes the sentence in which it appears technically incorrect. This sentence appears in two places, namely, in Requested Actions 2 and 3, on page 7 of the generic letter. The affected sentence reads "If the system has a face velocity greater than 10 percent of 0.203 m/s (40 ft/min), then the revised TS [technical specification] should specify the face velocity." This sentence should read "If the system has a face velocity greater than 110 percent of 0.203 m/s (40 ft/min), then the revised TS should specify the face velocity."

If you have any questions about this matter, please contact one of the staff members listed below or the appropriate Office of Nuclear Reactor Regulation (NRR) project manager.

Original signed by
 Scott F. Newberry FOR

David B. Matthews, Director
 Division of Regulatory Improvement Programs
 Office of Nuclear Reactor Regulation

Technical contact: John P. Segala, NRR
 301-415-1858
 Internet: jps1@nrc.gov

Lead project manager: Brenda L. Mozafari, NRR
 301-415-2020
 Internet: blm@nrc.gov

DOCUMENT NAME: G:\REXB\jws\errata.wpd

To receive a copy of this document, indicate in the box C=Copy w/o attachment/enclosure E=Copy with attachment/enclosure N = No copy

OFFICE	REXB	Tech Ed	SPLB	C:REXB	D:DRIP
NAME	JShapaker		JHannon	LMarsh	DMatthews
DATE	8/16/99	7/13/99	8/17/99	8/16/99	8/17/99

OFFICIAL RECORD COPY

- ERRATA -
 UNITED STATES
 NUCLEAR REGULATORY COMMISSION
 OFFICE OF NUCLEAR REACTOR REGULATION
 WASHINGTON, D.C. 20555-0001

August 12, 1999

**NRC GENERIC LETTER 99-02 (ERRATA): LABORATORY TESTING OF NUCLEAR-GRADE
 ACTIVATED CHARCOAL**

Addressees

All holders of operating licenses for nuclear power reactors, except those who have permanently ceased operations and have certified that fuel has been permanently removed from the reactor vessel.

Discussion

A typographical error has been identified in Generic Letter 99-02, "Laboratory Testing of Nuclear-Grade Activated Charcoal," issued on June 3, 1999, that makes the sentence in which it appears technically incorrect. This sentence appears in two places, namely, in Requested Actions 2 and 3, on page 7 of the generic letter. The affected sentence reads "If the system has a face velocity greater than 10 percent of 0.203 m/s (40 ft/min), then the revised TS [technical specification] should specify the face velocity." This sentence should read "If the system has a face velocity greater than 110 percent of 0.203 m/s (40 ft/min), then the revised TS should specify the face velocity."

If you have any questions about this matter, please contact one of the staff members listed below or the appropriate Office of Nuclear Reactor Regulation (NRR) project manager.

David B. Matthews, Director
 Division of Regulatory Improvement Programs
 Office of Nuclear Reactor Regulation

Technical contact: John P. Segala, NRR
 301-415-1858
 Internet: jps1@nrc.gov

Lead project manager: Brenda L. Mozafari, NRR
 301-415-2020
 Internet: blm@nrc.gov

DOCUMENT NAME: G:\REXB\jws\errata.wpd

To receive a copy of this document, indicate in the box C=Copy w/o attachment/enclosure E=Copy with attachment/enclosure N = No copy

OFFICE	REXB		Tech Ed		SPLB		C:REXB		D:DRIP
NAME	JShapaker		E. CALVO		JHannon		LMarsh		DMatthews
DATE	8/16/99		7/13/99		8/12/99		8/16/99		1 / 99

OFFICIAL RECORD COPY

- ERRATA -
 UNITED STATES
 NUCLEAR REGULATORY COMMISSION
 OFFICE OF NUCLEAR REACTOR REGULATION
 WASHINGTON, D.C. 20555-0001

August 23, 1999

NRC GENERIC LETTER 99-02 (ERRATA): LABORATORY TESTING OF NUCLEAR-GRADE
 ACTIVATED CHARCOAL

Addressees

All holders of operating licenses for nuclear power reactors, except those who have permanently ceased operations and have certified that fuel has been permanently removed from the reactor vessel.

Discussion

A typographical error has been identified in Generic Letter 99-02, "Laboratory Testing of Nuclear-Grade Activated Charcoal," issued on June 3, 1999, that makes the sentence in which it appears technically incorrect. This sentence appears in two places, namely, in Requested Actions 2 and 3, on page 7 of the generic letter. The affected sentence reads "If the system has a face velocity greater than 10 percent of 0.203 m/s (40 ft/min), then the revised TS [technical specification] should specify the face velocity." This sentence should read "If the system has a face velocity greater than 110 percent of 0.203 m/s (40 ft/min), then the revised TS should specify the face velocity."

If you have any questions about this matter, please contact one of the staff members listed below or the appropriate Office of Nuclear Reactor Regulation (NRR) project manager.

Original signed by
 Scott F. Newberry FOR

David B. Matthews, Director
 Division of Regulatory Improvement Programs
 Office of Nuclear Reactor Regulation

Technical contact: John P. Segala, NRR
 301-415-1858
 Internet: jps1@nrc.gov

Lead project manager: Brenda L. Mozafari, NRR
 301-415-2020
 Internet: blm@nrc.gov

DOCUMENT NAME: G:\REXB\jws\errata.wpd

To receive a copy of this document, indicate in the box C=Copy w/o attachment/enclosure E=Copy with attachment/enclosure N = No copy

OFFICE	REXB	Tech Ed	SPLB	C:REXB	D:DRIP
NAME	JShapaker		JHannon	LMarsh	DMatthews
DATE	8/16/99	7/13/99	8/17/99	8/17/99	8/17/99

OFFICIAL RECORD COPY