

APR 14 2003

LR-N03-0162



U. S. Nuclear Regulatory Commission  
Document Control Desk  
Washington, DC 20555

Gentlemen:

**MONTHLY OPERATING REPORT  
SALEM GENERATING STATION UNIT 1  
DOCKET NO. 50-272**

In compliance with Section 6.9, Reporting Requirements for the Salem Unit 1 Technical Specifications, the operating statistics for **March 2003** are being forwarded.

Sincerely,

A handwritten signature in black ink, appearing to read "Lon Waldinger", written over a circular stamp or mark.

Lon Waldinger  
Operations Director

RAR  
Attachments

C Distribution

JE24

DOCKET NO.: 50-272  
 UNIT: Salem 1  
 DATE: 4/8/03  
 COMPLETED BY: F. Todd  
 TELEPHONE: (856) 339-1316

Reporting Period March 2003

**OPERATING DATA REPORT**

Design Electrical Rating (MWe-Net)  
 Maximum Dependable Capacity (MWe-Net)

No. of hours reactor was critical  
 No. of hours generator was on line (service hours)  
 Unit reserve shutdown hours  
 Net Electrical Energy (MWH)

1130		
1096		
Month	Year-to-date	Cumulative
744	2160	144348
744	2160	139711
0	0	0
738724	2313895	142217861

**UNIT SHUTDOWNS**

NO.	DATE	TYPE F=FORCED S=SCHEDULED	DURATION (HOURS)	REASON (1)	METHOD OF SHUTTING DOWN THE REACTOR (2)	CORRECTIVE ACTION/ COMMENT

(1) Reason

- A - Equipment Failure (Explain)
- B - Maintenance or Test
- C - Refueling
- D - Regulatory Restriction
- E - Operator Training/License Examination
- F - Administrative
- G - Operational Error (Explain)
- H - Other

(2) Method

- 1 - Manual
- 2 - Manual Trip/Scram
- 3 - Automatic Trip/Scram
- 4 - Continuation
- 5 - Other (Explain)

DOCKET NO.: 50-272  
UNIT: Salem 1  
DATE: 3/10/03  
COMPLETED BY: R. Ritzman  
TELEPHONE: (856) 339-1445

### Summary Of Monthly Operating Experience

- On March 3, the unit was reduced to 71% power due to two circulators being out of service. Power was restored to 100% on March 7.
- On March 25, power was reduced to 72% power due to two circulators being out of service.
- On March 29, power was further reduced to 56% power due to three circulators being out of service and ended the month at reduced power.
- At the end of the month, Salem 1 completed 138 days of continuous on-line operation.