

Peter E. Katz
Vice President
Calvert Cliffs Nuclear Power Plant
Constellation Generation Group, LLC

1650 Calvert Cliffs Parkway
Lusby, Maryland 20657
410 495-4455
410 495-3500 Fax



April 17, 2003

U. S. Nuclear Regulatory Commission
Washington, DC 20555

ATTENTION: Document Control Desk

SUBJECT: Calvert Cliffs Nuclear Power Plant
Unit Nos. 1 & 2; Docket Nos. 50-317 & 50-318
Information Regarding Interim Inspection Requirements for Reactor Pressure
Vessel Head (TAC Nos. MB7752 and MB7753)

In References (a), (b), and (c) Calvert Cliffs Nuclear Power Plant, Inc. requested relaxation from aspects of the Nuclear Regulatory Commission Order on reactor vessel head inspections (Reference d). We understand that you desire to place the following condition in our Renewed Operating License Nos. DPR-53 and DPR-69 for Unit Nos. 1 and 2, respectively, as part of granting the requested relaxation:

If the NRC staff finds that the crack growth formula in industry report MRP-55 is unacceptable, the licensee shall revise its analysis that justifies relaxation of the Order within 30 days after the NRC informs the licensee of an NRC-approved crack growth formula. If the licensee's revised analysis shows that the crack growth acceptance criteria are exceeded prior to the end of the current operating cycle, this relaxation is rescinded and the licensee shall, within 72 hours, submit to the NRC written justification for continued operation. If the revised analysis shows that the crack growth acceptance criteria are exceeded during the subsequent operating cycle, the licensee shall, within 30 days, submit the revised analysis for NRC review. If the revised analysis shows that the crack growth acceptance criteria are not exceeded during either the current operating cycle or the subsequent operating cycle, the licensee shall, within 30 days, submit a letter to the NRC confirming that its analysis has been revised.

We agree to the condition, as worded above, that you wish to place in our license.

Should you have questions regarding this matter, we will be pleased to discuss them with you.

Very truly yours,

A handwritten signature in black ink that reads "Peter E. Katz".

PEK/PSF/bjd

A101

REFERENCES:

- (a) Letter from Mr. P. E. Katz (CCNPP) to Document Control Desk (NRC), dated February 18, 2003, Response to Issuance of Order Establishing Interim Inspection Requirements for Reactor Pressure Vessel Heads at Pressurized Water Reactors
- (b) Letter from Mr. P. E. Katz (CCNPP) to Document Control Desk (NRC), dated March 13, 2003, Response to Request for Additional Information Regarding Interim Inspection Requirements for Reactor Pressure Vessel Head (TAC Nos. MB7752 and MB7753)
- (c) Letter from Mr. P. E. Katz (CCNPP) to Document Control Desk (NRC), dated April 4, 2003, Response to Request for Additional Information Regarding Interim Inspection Requirements for Reactor Pressure Vessel Head (TAC Nos. MB7752 and MB7753)
- (d) Letter from Mr. S. J. Collins (NRC) to Holders of Licenses for Operating Pressurized Water Reactors, dated February 11, 2003, Issuance of Order Establishing Interim Inspection Requirements for Reactor Pressure Vessel Heads at Pressurized Water Reactors (EA-03-009)

cc: J. Petro, Esquire
J. E. Silberg, Esquire
Director, Project Directorate I-1, NRC
G. S. Vissing, NRC

H. J. Miller, NRC
Resident Inspector, NRC
R. I. McLean, DNR