

UNITED STATES  
NUCLEAR REGULATORY COMMISSION  
OFFICE OF NUCLEAR REACTOR REGULATION  
WASHINGTON, D.C. 20555

October 30, 1990

NRC INFORMATION NOTICE NO. 90-68: STRESS CORROSION CRACKING OF REACTOR  
COOLANT PUMP BOLTS

Addressees:

All holders of operating licenses or construction permits for pressurized water reactors (PWRs).

Purpose:

This information notice is intended to alert addressees of a significant event which occurred at a foreign reactor. The event involves the use of a material sensitive to intergranular stress corrosion cracking (IGSCC) in the fabrication of the bolts fastening the turning vanes of the reactor coolant pumps. It is expected that recipients will review the information for applicability to their facilities and consider actions, as appropriate, to avoid similar problems. However, suggestions contained in this information notice do not constitute NRC requirements; therefore, no specific action or written response is required.

Description of Circumstances:

The U.S. Nuclear Regulatory Commission (NRC) has received information concerning cracking of the bolts fastening the turning vanes of the reactor coolant pumps at a foreign reactor plant. There are 23 bolts fastening the turning vanes in each of three reactor coolant pumps. Five of these bolts had experienced stress corrosion cracking. The bolts were made of a stainless steel alloy which is designated by the American Society for Testing and Materials as A453 grade 660. The material is commonly described commercially as alloy A-286. The reactor coolant pumps are similar in design to those manufactured by the Westinghouse Electric Company.

Considerable information has previously been available regarding the susceptibility of alloy A-286 to IGSCC. For example, licensees of U.S. reactors designed by Babcock and Wilcox (B&W) have noted stress corrosion cracking of bolts fabricated of alloy A-286. Specifically, bolts fastening the B&W reactor internals, including the core barrel and lower thermal shield, were fabricated of alloy A-286. Between 1981 and 1984, bolt cracking and indication of cracking were documented at Oconee, Rancho Seco, Crystal River and Arkansas Unit 1. In response, the B&W owners group formed a special task force to study the internal bolts of the reactor vessel. This task force documented its conclusions in BAW-1842, "The B&W Owners Group Evaluation of Internals Bolting Concerns in 177 FA Plants," August 1984. The task force concluded that bolts fabricated


9010240315 ZA

IDAR-11C

of alloy A-286 are subject to IGSCC at peak stresses above 100 ksi. The occurrence of IGSCC also appeared to be a function of chromium content, fabrication practice and environment. As a result of the task force findings, the design of the reactor internal bolts was modified at B&W plants to use fastener materials that are less sensitive to IGSCC than alloy A-286 or to reduce the maximum stress loadings of bolts fabricated of alloy A-286 to less than 100 ksi.

In addition, the Brookhaven National Laboratory (BNL) performed an extensive study of bolting which is documented in NUREG/CR-3604, "Bolting Applications," May 1984. The report discusses the direct relationship between loading and IGSCC of bolts fabricated of alloy A-286. In this report, BNL recommended that alloy A-286 not be used as a reactor structural material because of its susceptibility to IGSCC.

This information notice requires no specific action or written response. If you have any questions about this matter, please contact one of the technical contacts listed below or the appropriate NRR project manager.

  
Charles E. Rossi, Director  
Division of Operational Events Assessment  
Office of Nuclear Reactor Regulation

Technical Contacts: Clifford Sellers, NRR  
(301) 492-0703

Walton Jensen, NRR  
(301) 492-1157

Attachment: List of Recently Issued NRC Information Notices

LIST OF RECENTLY ISSUED  
NRC INFORMATION NOTICES

Information Notice No.	Subject	Date of Issuance	Issued to
90-67	Potential Security Equipment Weaknesses	10/29/90	All holders of OLs or CPs for nuclear power reactors and Category I fuel facilities.
90-66	Incomplete Draining and Drying of Shipping Casks	10/25/90	All holders of OLs for nuclear power reactors and all registered users of NRC approved waste shipping packages.
88-63, Supp. 1	High Radiation Hazards From Irradiated Incore Detectors and Cables	10/5/90	All holders of OLs or CPs for nuclear power reactors.
90-65	Recent Orifice Plate Problems	10/5/90	All holders of OLs or CPs for nuclear power reactors.
90-64	Potential for Common-Mode Failure Of High Pressure Safety Injection Pumps or Release of Reactor Coolant Outside Containment During A Loss-Of-Coolant Accident	10/4/90	All holders of OLs or CPs for pressurized-water reactors.
90-63	Management Attention to the Establishment and Maintenance of A Nuclear Criticality Safety Program	10/3/90	All fuel cycle licensees possessing more than critical mass quantities of special nuclear material.

---

OL = Operating License  
CP = Construction Permit

of alloy A-286 are subject to IGSCC at peak stresses above 100 ksi. The occurrence of IGSCC also appeared to be a function of chromium content, fabrication practice and environment. As a result of the task force findings, the design of the reactor internal bolts was modified at B&W plants to use fastener materials that are less sensitive to IGSCC than alloy A-286 or to reduce the maximum stress loadings of bolts fabricated of alloy A-286 to less than 100 ksi.

In addition, the Brookhaven National Laboratory (BNL) performed an extensive study of bolting which is documented in NUREG/CR-3604, "Bolting Applications," May 1984. The report discusses the direct relationship between loading and IGSCC of bolts fabricated of alloy A-286. In this report, BNL recommended that alloy A-286 not be used as a reactor structural material because of its susceptibility to IGSCC.

This information notice requires no specific action or written response. If you have any questions about this matter, please contact one of the technical contacts listed below or the appropriate NRR project manager.

Original Signed by  
Charles E. Rossi, Director  
Division of Operational Events Assessment  
Office of Nuclear Reactor Regulation

Technical Contacts: Clifford Sellers, NRR  
(301) 492-0703

Walton Jensen, NRR  
(301) 492-1157

Attachment: List of Recently Issued NRC Information Notices

**\*SEE PREVIOUS CONCURRENCE**

NRR:EAB	NRR:EAB	TECH ED	GPA:IP	NRR:EMCB
*WJensen	*NPKadambi		*KBurke	*CSellers
08/01/90	08/13/90	07/27/90	08/21/90	08/10/90
NRR:EMCB	NRR:DET	NRR:EAB	NRR:GCB	NRR:DEA
*CYCheng	*JRichardson	*PBaranowsky	*CBerlinger	CROSS
08/27/90	08/27/90	09/06/90	10/19/90	10/25/90

DOCUMENT NAME: IN 90-68

of alloy A-286 are subject to IGSCC at peak stresses above 100 ksi. The occurrence of IGSCC also appeared to be a function of chromium content, fabrication practice and environment. As a result of the task force findings, the design of the reactor internal bolts was modified at B&W plants to use fastener materials that are less sensitive to IGSCC than alloy A-286 or to reduce the maximum stress loadings of bolts fabricated of alloy A-286 to less than 100 ksi.

In addition, the Brookhaven National Laboratory (BNL) performed an extensive study of bolting which is documented in NUREG/CR-3604, "Bolting Applications," May 1984. The report discusses the direct relationship between loading and IGSCC of bolts fabricated of alloy A-286. In this report, BNL recommended that alloy A-286 not be used as a reactor structural material because of its susceptibility to IGSCC.

This information notice requires no specific action or written response. If you have any questions about this matter, please contact one of the ~~the~~ technical contacts listed below or the appropriate NRR project manager.

Charles E. Rossi, Director  
Division of Operational Events Assessment  
Office of Nuclear Reactor Regulation

Technical Contacts: Clifford Sellers, NRR  
(301) 492-0703

Walton Jensen, NRR  
(301) 492-1157

Attachment: List of Recently Issued NRC Information Notices

\*SEE PREVIOUS CONCURRENCE

NRR:EAB  
\*WJensen  
08/01/90

NRR:EAB  
\*NPKadambi  
08/13/90

TECH ED  
07/27/90

GPA:IP  
\*KBurke  
08/21/90

NRR:EMCB  
\*CSellers  
08/10/90

NRR:EMCB  
\*CYCheng  
08/27/90

NRR:DET  
\*JRichardson  
08/27/90

NRR:EAB  
\*PBaranowsky  
09/06/90

NRR:GCE  
CBerlinger  
09/19/90

NRR:DOEA  
CRossi  
09/ /90

DOCUMENT NAME: INBOLT

internal bolts was modified at B&W plants to use fastener materials that are less sensitive to IGSCC than alloy A-286 or to reduce the maximum stress loadings of bolts fabricated of alloy A-286 to less than 100 ksi.

The Brookhaven National Laboratory (BNL) performed an extensive study of bolting for the NRC staff. This study is documented in NUREG/CR-3604, "Bolting Applications," May 1984. The report discusses the direct relationship between loading and IGSCC of bolts fabricated of alloy A-286. In this report, BNL recommended that alloy A-286 not be used as a reactor structural material because of its susceptibility to IGSCC.

This information notice requires no specific action or written response. If you have any questions about this matter, please contact one of the the technical contacts listed below or the appropriate NRR project manager.

Charles E. Rossi, Director  
Division of Operational Events Assessment  
Office of Nuclear Reactor Regulation

Technical Contacts: Clifford Sellers, NRR  
(301) 492-0703

Walton Jensen, NRR  
(301) 492-1157

Attachment: List of Recently Issued NRC Information Notices

DISTRIBUTION:

Crossi	DOEA r/f
WJensen	EAB r/f
NPKadambi	Central Files
CSellers	JRichardson
PBaranowsky	CBerlinger

\*SEE PREVIOUS CONCURRENCE  
NRR:EAB  
\*WJensen  
08/01/90

NRR:EAB  
\*NPKadambi  
08/13/90

\*TECH ED  
07/27/90

NRR:EMCB  
CYCheng  
08/27/90

NRR:DET  
JRichardson  
08/27/90

NRR:EAB  
PBaranowsky  
09/16/90

\*GPA:IP  
KBurke  
08/21/90

\*NRR:EMCB  
CSellers  
08/10/90

*Discussed removal of name of Crossi with R. Burke on 10/24/90*  
NPK (Recd. 10/19/90)  
NRR:GCB  
CBerlinger  
(connection of minor types discussed with Whit)  
10/19/90.

NRR:DOEA  
Crossi

DOCUMENT NAME: INBOLT

internal bolts was modified at B&W plants to use fastener materials that are less sensitive to IGSCC than alloy A-286 or to reduce the maximum stress loadings of bolts fabricated of alloy A-286 to less than 100 ksi.

The Brookhaven National Laboratory (BNL) performed an extensive study of bolting for the NRC staff. This study is documented in NUREG/CR-3604, "Bolting Applications," May 1984. The report discusses the direct relationship between loading and IGSCC of bolts fabricated of alloy A-286. In this report, BNL recommended that alloy A-286 not be used as a reactor structural material because of its susceptibility to IGSCC.

This information notice requires no specific action or written response. If you have any questions about this matter, please contact one of the the technical contacts listed below or the appropriate NRR project manager.

Charles E. Rossi, Director  
Division of Operational Events Assessment  
Office of Nuclear Reactor Regulation

Technical Contacts: Clifford Sellers, NRR  
(301) 492-0703

Walton Jensen, NRR  
(301) 492-1157

Attachment: List of Recently Issued NRC Information Notices

DISTRIBUTION:


CRossi  
WJensen  
NPKadambi  
CSellers  
PBaranowsky

DOEA r/f  
EAB r/f  
Central Files  
JRichardson  
CBerlinger

NRR: EABO  
WJensen  
08/1/90

*NPK*  
NRR: EAB  
NPKadambi  
08/13/90

*reviewed by*  
TECH ED  
*myll*  
07/27/90

  
GPA: IP  
KBurke  
08/24/90

NRR: EMCB  
CSellers *edg*  
08/10/90

*2C 8/27/90*  
NRR: EMCB  
CY Cheng  
08/1/90

NRR: DET  
JRichardson  
07/ /90

NRR: EAB  
PBaranowsky  
07/ /90

NRR: GCB  
CBerlinger  
07/ /90

NRR: DOEA  
CRossi

DOCUMENT NAME: INBOLT