



APR 15 2003

L-2003-089  
10 CFR 50.36

U. S. Nuclear Regulatory Commission  
Attn: Document Control Desk  
Washington, D. C. 20555

Re: Turkey Point Units 3 and 4  
Docket Nos. 50-250 and 50-251  
Monthly Operating Report – March 2003

In accordance with the requirements of Turkey Point Units 3 and 4 Technical Specification 6.9.1.5, and the guidance of Generic Letter 97-02, attached are the March 2003 Operating Data Reports and Summaries of Operating Experience for Turkey Point Units 3 and 4.

Very truly yours,

A handwritten signature in black ink that reads "Terry Jones". The signature is written in a cursive, flowing style.

Terry O. Jones  
Vice President  
Turkey Point Plant

DRL

Attachments

NRC Regulatory Issue Summary 2001-05 waived the requirements that multiple copies of documents be submitted to the NRC.

IE24

DOCKET NO.: 50-250  
 UNIT: Turkey Point Unit 3  
 DATE: 4/4/2003  
 COMPLETED BY: David Lafleur  
 TELEPHONE: (305) 246-7150

Reporting Period March, 2003

**OPERATING DATA REPORT**

<b>Design Electrical Rating (MWe-Net)</b>	720		
<b>Maximum Dependable Capacity (MWe-Net)</b>	693		
	<b>Month</b>	<b>Year-to-date</b>	<b>Cumulative</b>
<b>No. of hours reactor was critical</b>	105.5	1481.2	196021
<b>No. of hours generator was on line (service hours)</b>	77.5	1447.6	193656.1
<b>Unit reserve shutdown hours</b>	0	0	121.8
<b>Net Electrical Energy (MWH)</b>	28123	914648	126273725

**UNIT SHUTDOWNS**

No.	Date	Type F=Forced S=Scheduled	Duration (hours)	Reason (1)	Method of Shutting Down (2)	Corrective Action/ Comments
20030008	03/1/03	S	666.6	C	1	Manual trip as part of unit shutdown for refueling outage.

**(1) Reason**

- A - Equipment Failure (Explain)
- B - Maintenance or Test
- C - Refueling
- D - Regulatory Restriction
- E - Operator Training/License Examination
- F - Administrative
- G - Operational Error (Explain)
- H - Other

**(2) Method**

- 1 - Manual
- 2 - Manual Trip/Scram
- 3 - Automatic Trip/Scram
- 4 - Continuation
- 5 - Other (Explain)

**Summary Of Monthly Operating Experience**

Unit 3 performed a scheduled shutdown from 60% power on 3/1/03 for refueling and returned to power operation on 3/28/03.

DOCKET NO.: 50-251  
 UNIT: Turkey Point Unit 4  
 DATE: 4/4/2003  
 COMPLETED BY: David Lafleur  
 TELEPHONE: (305) 246-7150

Reporting Period March, 2003

<b>Design Electrical Rating (MWe-Net)</b>	<b>720</b>		
<b>Maximum Dependable Capacity (MWe-Net)</b>	<b>693</b>		
	<b>Month</b>	<b>Year-to-date</b>	<b>Cumulative</b>
<b>No. of hours reactor was critical</b>	744	2160	193522.7
<b>No. of hours generator was on line (service hours)</b>	744	2160	189105.2
<b>Unit reserve shutdown hours</b>	0	0	577.2
<b>Net Electrical Energy (MWH)</b>	527840	1520559	124479649

**UNIT SHUTDOWNS**

No.	Date	Type F=Forced S=Scheduled	Duration (hours)	Reason (1)	Method of Shutting Down (2)	Corrective Action/ Comments
N/A	N/A	N/A	N/A	N/A	N/A	N/A

**(1) Reason**

- A - Equipment Failure (Explain)
- B - Maintenance or Test
- C - Refueling
- D - Regulatory Restriction
- E - Operator Training/License Examination
- F - Administrative
- G - Operational Error (Explain)
- H - Other

**(2) Method**

- 1 - Manual
- 2 - Manual Trip/Scram
- 3 - Automatic Trip/Scram
- 4 - Continuation
- 5 - Other (Explain)

**Summary Of Monthly Operating Experience**

Unit 4 operated at essentially 100% power for the month of March, 2003.