



April 14, 2003

L-MT-03-027  
Technical Specification  
6.7.A.3

U.S. Nuclear Regulatory Commission  
ATTN: Document Control Desk  
Washington, DC 20555

MONTICELLO NUCLEAR GENERATING PLANT  
DOCKET 50-263  
LICENSE No. DPR-22

MONTICELLO MONTHLY OPERATING REPORT FOR MARCH 2003

In accordance with Monticello Technical Specification 6.7.A.3, the report of operating statistics for Monticello Nuclear Generating Plant for the month of March is enclosed.

Please contact John Fields at 763-295-1663 if you require further information.

David L. Wilson  
Site Vice President  
Monticello Nuclear Generating Plant

CC Regional Administrator, USNRC, Region III  
Project Manager, USNRC, NRR  
NRC Resident Inspector  
Minnesota Dept. of Commerce

Attachments: Operating Data Report  
Unit Shutdowns

LE24



DOCKET NO. 50-263  
UNIT NAME Monticello  
DATE April 1, 2003  
COMPLETED BY J. I. Helland  
TELEPHONE 763-295-1333

OPERATING DATA REPORT

REPORTING PERIOD: March 2003

	<u>MONTH</u>	<u>YEAR TO DATE</u>	<u>CUMULATIVE</u>
1. Design Electrical Rating (MWe-Net)	600.0	600.0	600.0
2. Maximum Dependable Capacity (MWe-Net)	578.1	578.1	578.1
3. Number of Hours the Reactor Was Critical	744.0	2,160.0	231,001.6
4. Number of Hours the Generator Was On Line	744.0	2,160.0	227,578.8
5. Unit Reserve Hours	0.0	0.0	0.0
6. Net Electrical Energy (MWHe)	437,856.0	1,267,562.2	117,433,104.7

UNIT SHUTDOWNS

DOCKET NO. 50-263

UNIT NAME Monticello

DATE 04 - 01 - 03

COMPLETED BY J. I. Helland

TELEPHONE 763-295-1333

REPORTING PERIOD March 2003

No.	Date	Type	Duration (hours)	Reason (1)	Method of Shutting Down (2)	Cause/Corrective Actions
		F:Forced S.Scheduled				Comments
	None					

1

Reason:

- A Equipment Failure (Explain)
- B Maintenance or Test
- C Refueling
- D Regulator Restriction
- E Operator Training & Licensing Examination
- F Administrative
- G Operational Error (Explain)
- H Other (Explain)

2

Method:

- 1 Manual
- 2 Manual Scram
- 3 Automatic Trip/Scram
- 4 Continuation
- 5 Other (Explain)

SUMMARY: The plant operated at essentially 100% power the entire month, except for the following four power reductions: A power reduction to 93% for about 1.5 hours on March 8 for a rod pattern adjustment. A power reduction to about 90% for about 3 hours on March 18 for an Amertap and a rod pattern adjustment. A power reduction to 98% for about 40 minutes on March 28/29 for a rod pattern adjustment and a power reduction to about 92% for about 1 hour 30 minutes on March 30 for a rod pattern adjustment.