

UNITED STATES  
NUCLEAR REGULATORY COMMISSION  
OFFICE OF INSPECTION AND ENFORCEMENT  
WASHINGTON, D.C. 20555

SSINS: 6870  
Accession No.:  
7912190681

March 7, 1980

IE Information Notice No. 80-09

POSSIBLE OCCUPATIONAL HEALTH HAZARD ASSOCIATED WITH CLOSED COOLING SYSTEMS FOR  
OPERATING POWER PLANTS

As a result of information that the causative agent for meningoencephalitis, the amoeba Naegleria fowleri, had been found in warm water ponds in Florida and Texas where two fatalities were reported, NRC initiated a study by Oak Ridge National Laboratory on the occurrence of Naegleria in power plants with closed cycle cooling systems. For seven power stations examined (6 fossil, 1 nuclear), this study confirmed the presence of pathogenic Naegleria at three plants including the nuclear plant (Dresden).

Recently, Northern States Power Company (NSP), while monitoring the Prairie Island Nuclear Generating Plant closed cooling system for the amoeba, did identify the presence of Naegleria. Although the Minnesota Department of Health does not consider the existence of the organism to be a public health threat, it was recognized as a possible occupational health hazard. Plant personnel were instructed to wear rubber gloves when coming into contact with the circulating water and to wear respirators when working in the area of the cooling towers. In November 1979, NSP conducted a special chlorination program at Prairie Island that was designed by Dr. Richard Tyndall of Oak Ridge to eradicate this organism. Chlorine concentrations in the circulating water system was raised to 2.0 mg/l (measured as free chlorine) for a period of six hours to destroy both the amoebae and its encysted form. This program also included dechlorination prior to discharge and intensive monitoring to document chlorine concentrations, the impacts of chlorinated cooling tower draft and sampling to determine the efficacy of the special chlorination program in destroying Naegleria. Preliminary results indicate that the program was successful in reducing the number of organisms present by two to three orders of magnitude.

It is recognized that there have been no reported cases of meningoencephalitis reported among power plant personnel to date; however, the seriousness of the disease (if contracted) and the confirmed presence of Naegleria at four plants, leads us to inform all licensees with closed cycle cooling water systems of the potential occupational hazard and advise that they take appropriate action.

No written response to this IE Information Notice is required. If you desire additional information regarding this matter, contact the Director of the appropriate NRC Regional Office.

IE Information Notice No. 80-09  
March 7, 1980

Enclosure

RECENTLY ISSUED  
IE INFORMATION NOTICES

| Information Notice No. | Subject   | Date Issued | Issued To   |
|------------------------|---|-------------|---|
| 80-08                  | The States Company Sliding Link Electrical Terminal Block | 3/7/80      | All power reactor facilities with an OL or a CP   |
| 80-07                  | Pump Shaft Fatigue Cracking                               | 2/29/80     | All Light Water Reactor Facilities holder power reactor OLs and CPs                                       |
| 80-06                  | Notification of Significant Events                        | 2/27/80     | All holders of Reactor OLs and to near term OL applicants   |
| 80-05                  | Chloride Contamination of Safety Related Piping           | 2/8/80      | All licensees of nuclear power reactor facilities and applicants and holders of nuclear power reactor CPs |
| 80-04                  | BWR Fuel Exposure in Excess of Limits                     | 2/4/80      | All BWR's holding a power reactor OL or CP  |
| 80-03                  | Main Turbine Electro-Hydraulic Control System             | 1/31/80     | All holders of power reactor OLs and CPs  |
| 80-02                  | 8X8R Water Rod Lower End Plug Wear                        | 1/25/80     | All BWR Facilities holder power reactor OLs or CPs  |
| 80-01                  | Fuel Handling Events                                      | 1/4/80      | All holders of power reactor OLs and CPs  |
| 79-37                  | Cracking in Low Pressure Turbine Discs                    | 12/28/79    | All power reactor OLs and CPs   |
| 79-36                  | Computer Code Defect in Stress Analysis of Piping Elbow   | 12/31/79    | All power reactor OLs and CPs   |
| 79-35                  | Control of Maintenance and Essential Equipment            | 12/31/79    | All power reactor facilities with an OL or CP   |
| 79-34                  | Inadequate Design of Safety-Related Heat Exchangers       | 12/27/79    | All holders of power reactor OLs and CPs  |