

April 22, 2003

U S Nuclear Regulatory Commission
ATTN: Document Control Desk
Washington, DC 20555-0001


PALISADES NUCLEAR PLANT
DOCKET 50-255
LICENSE No. DPR-20
2003 STEAM GENERATOR TUBE SURVEILLANCE REPORT – TUBES PLUGGED

Nuclear Management Company, LLC completed an inservice inspection of the Palisades steam generator tubes on April 10, 2003. Palisades Technical Specification 5.6.8.a requires that the number of tubes plugged in each steam generator be reported within fifteen days following the completion of the inservice inspection.

Twenty-five tubes were plugged in steam generator E-50A and twenty-one tubes were plugged in steam generator E-50B. The total number of tubes plugged in steam generator E-50A is 365. The total number of tubes plugged in steam generator E-50B is 360.

SUMMARY OF COMMITMENTS

This letter contains no new commitments and no revisions to existing commitments.



Douglas E. Cooper
Site Vice-President, Palisades

CC Regional Administrator, USNRC, Region III
 Project Manager, USNRC, NRR
 NRC Resident Inspector – Palisades

A047