

May 19, 2003

Mr. Roy A. Anderson
Chief Nuclear Officer & President
PSEG Nuclear LLC-X04
Post Office Box 236
Hancocks Bridge, NJ 08038

SUBJECT: HOPE CREEK GENERATING STATION - ISSUANCE OF CHANGE TO BASES
PAGE (TAC NO. MB8762)

Dear Mr. Anderson:

By letter dated March 21, 2003, you requested that we incorporate a change to Technical Specifications (TSs) Bases page B 3/4 6-1 for the Hope Creek Generating Station (HCGS). The change corrects an error that was incorporated in the Bases with the issuance of Amendment No. 134, on October 3, 2001. The correction changes a sentence that reads, in part, "...when tested at 5 psig and corrected to Pa..." to read "...when tested at 5 psig and corrected to 25 psig..." We understand that you have reviewed this change in accordance with the requirements of 10 CFR 50.59. The U.S. Nuclear Regulatory Commission staff has no objection to this change. The enclosed TS page is being distributed for inclusion in the HCGS TSs.

Sincerely,

/RA by RFretz for/

George F. Wunder, Project Manager, Section 2
Project Directorate I
Division of Licensing Project Management
Office of Nuclear Reactor Regulation

Docket No. 50-354

Enclosure: As stated

cc w/encl: See next page

May 19, 2003

Mr. Roy A. Anderson
Chief Nuclear Officer
PSEG Nuclear LLC-X04
Post Office Box 236
Hancocks Bridge, NJ 08038

Dear Mr. Anderson:

By letter dated March 21, 2003, you requested that we incorporate a change to Technical Specifications (TSs) Bases page B 3/4 6-1 for the Hope Creek Generating Station (HCGS). The change corrects an error that was incorporated in the Bases with the issuance of Amendment No. 134, on October 3, 2001. The correction changes a sentence that reads, in part, "...when tested at 5 psig and corrected to Pa..." to read "...when tested at 5 psig and corrected to 25 psig..." We understand that you have reviewed this change in accordance with the requirements of 10 CFR 50.59. The U.S. Nuclear Regulatory Commission staff has no objection to this change. The enclosed TS page is being distributed for inclusion in the HCGS TSs.

Sincerely,

/RA by RFretz for/
George F. Wunder, Project Manager, Section 2
Project Directorate I
Division of Licensing Project Management
Office of Nuclear Reactor Regulation

Docket No. 50-354

Enclosure: As stated

cc w/encl: See next page

DISTRIBUTION

PUBLIC JClifford WBeckner OGC GMeyer, RGN-I
PDI-2 Reading GWunder CRaynor ACRS GHill (2)

ADAMS Accession Numbers:

Package: ML03
Cover Letter: ML031260586
TS Page: ML03

OFFICE	PDI-2/PM	PDI-2/LA	PDI-2/SC
NAME	RFretz for GWunder	CRaynor	REnnis for JClifford
DATE	5/16/03	5/16/03	5/16/03

OFFICIAL RECORD COPY

Hope Creek Generating Station

cc:

Jeffrie J. Keenan, Esquire
PSEG Nuclear - N21
P.O. Box 236
Hancocks Bridge, NJ 08038

Hope Creek Resident Inspector
U.S. Nuclear Regulatory Commission
Drawer 0509
Hancocks Bridge, NJ 08038

Mr. David F. Garchow
Vice President - Operations
PSEG Nuclear - X10
P.O. Box 236
Hancocks Bridge, NJ 08038

Mr. Gabor Salamon
Manager - Nuclear Safety and Licensing
PSEG Nuclear - N21
P.O. Box 236
Hancocks Bridge, NJ 08038

Regional Administrator, Region I
U.S. Nuclear Regulatory Commission
475 Allendale Road
King of Prussia, PA 19406

Dr. Jill Lipoti, Asst. Director
Radiation Protection Programs
NJ Department of Environmental
Protection and Energy
CN 415
Trenton, NJ 08625-0415

Richard Hartung
Electric Service Evaluation
Board of Regulatory Commissioners
2 Gateway Center, Tenth Floor
Newark, NJ 07102

Lower Alloways Creek Township
c/o Mary O. Henderson, Clerk
Municipal Building, P.O. Box 157
Hancocks Bridge, NJ 08038