



Duke Power

McGuire Nuclear Station
12700 Hagers Ferry Road
Huntersville, NC 28078-9340
(704) 875-4000

D. M. Jamil
Vice President, McGuire
Nuclear Generation Department

(704) 875-5333 OFFICE
(704) 875-4809 FAX

April 23, 2003

U. S. Nuclear Regulatory Commission
Attention: Document Control Desk
Washington, DC 20555-0001

Subject: Duke Energy Corporation
McGuire Nuclear Station Units 1 and 2
Docket Nos. 50-369 and 50-370
Clarification of License Amendment Request Information

Re: December 12, 2002 Proposed Revision to Technical
Specifications (TS)
TS 3.3.2 - Engineered Safety Feature Actuation System
Instrumentation
TS 3.4.3 - Reactor Coolant System (RCS) Pressure and
Temperature (P-T) Limits
TS 3.4.12 - Low Temperature Overpressure Protection
System
TAC Numbers MB6972 and MB6973

The purpose of this letter is to docket Duke's response to your request by telephone for clarification of information related to the referenced submittal. Duke stated in the technical analysis section of this submittal that Revision 2 of WCAP-14040, which has been approved by the NRC, was used to develop the proposed P-T curves. Duke also referenced Revision 3 of this WCAP, which has not been approved by the NRC, in the reference list of the same submittal. The NRC requested clarification of which WCAP revision was used to develop the proposed P-T curves. Duke hereby clarifies that Revision 2 of this WCAP was used to develop the proposed P-T curves.

If there are any questions regarding this correspondence, please contact P. T. Vu at (704) 875-4302.

D. M. Jamil

DMJ/PTV/s

A001

U. S. Nuclear Regulatory Commission
April 23, 2003
Page 2

xc:

L. A. Reyes
NRC Regional Administrator, Region II

S. M. Schaeffer
NRC Resident Inspector

R. E. Martin
NRC Project Manager

B. O. Hall
Section Chief, N.C. Radiation Protection Section