

Wolf Creek Nuclear Operating Corporation

Wolf Creek Generating Station

**Docket No: 50-482
Facility Operating License No: NPF-42**

Annual Radioactive Effluent Release Report

Report No. 26

Reporting Period: January 1, 2002 - December 31, 2002

Table of Contents

	<u>Page</u>
<u>Executive Summary</u>	4
<u>Section I</u>	6
Report of 2002 Radioactive Effluents: Liquid	6
2002 Liquid Effluents	8
2002 Liquid Cumulative Dose Summary – Table 1	10
2002 Liquid Cumulative Dose Summary – Table 2	11
Report of 2002 Radioactive Effluents: Airborne	12
2002 Gaseous Effluents	14
2002 Gaseous Cumulative Dose Summary – Table 1	16
2002 Gaseous Cumulative Dose Summary – Table 2	17
<u>Section II</u>	18
Offsite Dose Calculation Manual Limits	18
Effluent Concentration Limits (ECLs)	18
Average Energy	19
Measurements and Approximations of Total Radioactivity (Liquid and Gaseous Effluents)	19
Batch Releases	21
Continuous Releases	21
Doses to a Member of the Public from Activities Inside the Site Boundary	21
Additional Information	21
2002 Effluent Concentration Limits	23
2002 Solid Waste Shipments	24
Irradiated Fuel Shipments	25
<u>Section III</u>	26
Meteorological Data – Hours At Each Wind Speed and Direction	26
<u>Section IV</u>	35
Unplanned or Abnormal Releases	35
Offsite Dose Calculation Manual	35
Major Changes to Liquid, Solid or Gaseous Radioactive Waste Treatment Systems	35
Land Use Census	35
Radwaste Shipments	36
Inoperability of Effluent Monitoring Instrumentation	36
Storage Tanks	36

Table of Contents

Attachment I - 2002 Radioactive Effluent Correction Resulting From PIR 2002-1791

Attachment II - WCGS Procedure AP 07B-003, Revision 4, "Offsite Dose Calculation Manual"

Attachment III - WCGS Procedure AP 07B-004, Revision 4, "Offsite Dose Calculation Manual (Radiological Environmental Monitoring Program)"

Attachment IV – WCGS Procedure AP 31A-100, Revision 4, "Solid Radwaste Process Control Program"

EXECUTIVE SUMMARY

This Annual Radioactive Effluent Release Report (Report 26) documents the quantities of liquid and gaseous effluents and solid waste released by the Wolf Creek Generating Station (WCGS) from January 1, 2002, through December 31, 2002. The format and content of this report are in accordance with Regulatory Guide 1.21, Revision 1, "Measuring, Evaluating, and Reporting Radioactivity in Solid Wastes and Releases of Radioactive Materials in Liquid and Gaseous Effluents from Light-Water-Cooled Nuclear Power Plants." Sections I, II, III, and IV of this report provide information required by NRC Regulatory Guide 1.21 and Section 7.2 of AP 07B-003, "Offsite Dose Calculation Manual" (ODCM).

Section I — Section I contains in detail the quantities of radioactive liquid and gaseous effluents and cumulative dose summaries for 2002, tabulated for each quarter and for yearly totals. Specific ODCM effluent limits and dose limits are also listed in Section I, along with the percentage of the effluent limits actually released, and the percentages of the dose limit actually received. No effluent or dose limits were exceeded during 2002.

An elevated release pathway does not exist at WCGS. All airborne releases are considered to be ground level releases. The gaseous pathway dose determination is met by the WCGS ODCM methodology of assigning all gaseous pathways to a hypothetical individual residing at the highest annual X/Q and D/Q location, as specified in the ODCM. This results in a conservative estimate of dose to a member of the public, rather than determining each pathway dose for each release condition. A conservative error of thirty percent has been estimated in the effluent data. As stated above, no ODCM dose limits were exceeded in 2002.

Section II — Section II includes supplemental information on continuous and batch releases, calculated doses, and solid waste disposal. There were 77 gaseous batch releases in 2002 versus 75 in 2001. There were more liquid batch releases in 2002 than there were in 2001 (71 versus 51). WCGS released 0.018 Curies in liquid releases during 2002, excluding gas and tritium. The higher number of liquid releases was due to Refuel XII in the spring of 2002. Continuous release pathways remained the same as previous years and all continuous releases were monitored. The report contains information on the following Performance Improvement Requests (PIRs).

PIR 2002-1242 was written to document the release of Secondary Liquid Waste Monitor Tank A on an incorrect release permit form. The form issued for the release was for Waste Monitor Tank A.

PIR 2002-1791 was written to document the incorrect flow rate for the Radwaste Vent was given to Operations during the performance of STN PE-054, "Flow Rate Verification of Fans with Monitored Exhausts." The flow rate supplied to the Control Room was 12,503 cfm and 12,510 cfm and should have been 13,215 cfm and 13,125 cfm, respectively. The 2002 Radioactive Effluent Release Report is included as Attachment I with corrections as a result of this PIR.

PIR 2002-2647 was written due to a missed ODCM surveillance. Per Table 3-2 of the ODCM, samples were required every 12 hours due to GHRE10B inoperability. Wolf Creek has an administrative sample time of 10 hours for a 12 hour requirement. The 12 hour sampling requirement was not met.

PIR 2003-0817 was written during the review process of this Annual Radioactive Effluent Report to document the evaluation of several isotopes that normally are not present. The PIR relates to Ar-

41 and Na-24 in liquid batch releases, Co-58 in a liquid continuous release and Gross Alpha in continuous and batch liquid releases.

Maximum estimated doses to members of the public were slightly higher than in 2001. This is due to the cooling lake being open to the public for fishing a greater number of days.

Section III — Section III documents the WCGS meteorological data for wind speed, wind direction, and atmospheric stability. Wolf Creek Generating Station meets the Regulatory Guide 1.23, "Meteorological Programs in Support of Nuclear Power Plants" Requirement for having at least 90% meteorological data recovery for 2002.

PIR 2002-0576 was written to evaluate the fact that we did not meet the meteorological instrumentation 90% availability goal in 2001 as stated in Regulatory Guide 1.23. A summary of the evaluation is included in Section III as well.

Section IV — Section IV documents unplanned and abnormal releases; changes to radwaste treatment systems, land use census, monitoring instruments, radwaste shipments; and storage tank quantities. Gas Decay Tank (GDT) #6 experienced a loss of pressure on May 20, 2002, when the tank was in re-circulation in support of a Volume Control Tank (VCT) purge. The pressure in the GDT decreased approximately 6 psig. The source for the loss of pressure in GDT #6 was due to failure of a valve seat on the Recombiner Moisture Separator Drain Valve. This valve is used manually to decrease the level in the moisture separator as needed. There were 4.65E-02 curies released. PIR 2002-1274 was initiated to capture and evaluate the events. This PIR was upgraded to a Level II, Category 16. No ODCM limits were exceeded.

No changes or events occurred on the land use census, monitoring instruments, radwaste shipments, and storage tanks.

ATTACHMENTS

Attachment I - Corrections to the Annual Radioactive Effluent Report Report 25, summarizing 2001 data

Attachment II - AP 07B-003, Revision 4, "Offsite Dose Calculation Manual"

Attachment III - AP 07B-004, Revision 4, "Offsite Dose Calculation Manual (Radiological Environmental Monitoring Program)"

Attachment IV - AP 31A-100, Revision 4, "Solid Radwaste Process Control Program"

SECTION I

REPORT OF 2002 RADIOACTIVE EFFLUENTS: LIQUID

	Unit	Quarter 1	Quarter 2
A. Fission and Activation Products			
1. Total Release (not including tritium, gases, alpha)	Ci	4.45E-03	9.77E-03
2. Average Diluted Concentration During Period	µCi/ml	2.63E-10	3.43E-10
3. Percent of Applicable Limit (1)	%	8.90E-02	1.95E-01
B. Tritium			
1. Total Release	Ci	5.81E+02	1.33E+02
2. Average Diluted Concentration During Period	µCi/ml	3.43E-05	4.66E-06
3. Percent of Applicable Limit (ECL) (2)	%	3.43E+00	4.66E-01
C. Dissolved and Entrained Gases			
1. Total Release	Ci	9.44E-02	1.13E-02
2. Average Diluted Concentration During Period	µCi/ml	5.58E-09	3.97E-10
3. Percent of Applicable Limit (3)	%	2.79E-03	1.98E-04
D. Gross Alpha Radioactivity			
1. Total Release	Ci	1.11E-05	0.00E+00
E. Volume of waste released (prior to dilution)	liters	7.54E+07	5.51E+07
F. Volume of dilution water used	liters	1.69E+10	2.85E+10

NOTES:

1) The applicable limit for the Wolf Creek Generating Station is 5 Curies per year. (Reference 10 CFR 50, Appendix I, "Guides On Design Objectives For Light-Water Cooled Nuclear Power Reactors," Paragraph A.2.) The value printed here is derived by dividing the total release Curies by 5 Curies and then multiplying the result by 100.

2) This value is derived by the following formula:

$$\% \text{ of Applicable Limit} = \frac{(\text{Average Diluted Concentration}) (100)}{(\text{MPC or ECL, Appendix B, Table 2 10CFR20})}$$

3) This value is derived by the following formula:

$$\% \text{ of Applicable Limit} = \frac{(\text{Average Diluted Concentration}) (100)}{(2E - 4 \text{ from ODCM Section 2.1})}$$

REPORT OF 2002 RADIOACTIVE EFFLUENTS: LIQUID

	Unit	Quarter 3	Quarter 4
A. Fission and Activation Products			
1. Total Release (not including tritium, gases, alpha)	Ci	2.92E-03	1.05E-03
2. Average Diluted Concentration During Period	μCi/ml	1.48E-10	5.31E-11
3. Percent of Applicable Limit (1)	%	5.83E-02	2.11E-02
B. Tritium			
1. Total Release	Ci	5.20E+01	5.07E+01
2. Average Diluted Concentration During Period	μCi/ml	2.64E-06	2.56E-06
3. Percent of Applicable Limit (ECL) (2)	%	2.64E-01	2.56E-01
C. Dissolved and Entrained Gases			
1. Total Release	Ci	1.68E-05	4.08E-06
2. Average Diluted Concentration During Period	μCi/ml	8.52E-13	2.06E-13
3. Percent of Applicable Limit (3)	%	4.26E-07	1.03E-07
D. Gross Alpha Radioactivity			
1. Total Release	Ci	0.00E+00	5.66E-06
E. Volume of waste released (prior to dilution)	liters	4.93E+07	4.64E+07
F. Volume of dilution water used	liters	1.97E+10	1.98E+10

NOTES:

1) The applicable limit for the Wolf Creek Generating Station is 5 Curies per year. (Reference 10 CFR 50, Appendix I, "Guides On Design Objectives For Light-Water Cooled Nuclear Power Reactors," Paragraph A.2.) The value printed here is derived by dividing the total release Curies by 5 Curies and then multiplying the result by 100.

2) This value is derived by the following formula:

$$\% \text{ of Applicable Limit} = \frac{(\text{Average Diluted Concentration}) (100)}{(\text{MPC or ECL, Appendix B, Table 2 10CFR20})}$$

3) This value is derived by the following formula:

$$\% \text{ of Applicable Limit} = \frac{(\text{Average Diluted Concentration}) (100)}{(2E - 4 \text{ from ODCM Section 2.1})}$$

2002 LIQUID EFFLUENTS

Nuclides Released	Unit	Continuous Mode		Batch Mode	
		Quarter 1	Quarter 2	Quarter 1	Quarter 2
H-3	Ci	1.64E+00	9.71E-01	5.80E+02	1.31E+02
Cr-51	Ci	n/a	n/a	n/a	3.02E-04
Mn-54	Ci	<3.64E-02	<2.69E-02	4.03E-05	3.69E-05
Fe-55	Ci	<7.29E-02	<5.37E-02	<9.90E-04	<1.34E-03
Fe-59	Ci	<3.64E-02	<2.69E-02	<4.95E-04	1.52E-05
Co-57	Ci	n/a	n/a	3.06E-06	1.69E-06
Co-58	Ci	<3.64E-02	2.05E-04	1.22E-04	4.72E-03
Co-60	Ci	<3.64E-02	<2.69E-02	7.22E-04	2.19E-04
Zn-65	Ci	<3.64E-02	<2.69E-02	<4.95E-04	<6.68E-04
Sr-89	Ci	<3.64E-03	<2.69E-03	<4.95E-05	<6.68E-05
Sr-90	Ci	<3.64E-03	<2.69E-03	<4.95E-05	<6.68E-05
Nb-95	Ci	n/a	n/a	n/a	1.74E-05
Zr-95	Ci	n/a	n/a	n/a	6.84E-06
Tc-99m	Ci	n/a	n/a	n/a	7.89E-06
Mo-99	Ci	<3.64E-02	<2.69E-02	<4.95E-04	<6.68E-04
Na-24	Ci	n/a	n/a	n/a	1.67E-06
Rb-88	Ci	n/a	n/a	3.28E-04	n/a
Sn-117M	Ci	n/a	n/a	3.07E-06	n/a
Sb-122	Ci	n/a	n/a	n/a	3.21E-05
Sb-124	Ci	n/a	n/a	n/a	4.41E-05
Sb-125	Ci	n/a	n/a	n/a	4.05E-03
I-131	Ci	<7.29E-02	<5.37E-02	<9.90E-04	<6.68E-04
I-133	Ci	n/a	n/a	3.38E-06	n/a
Cs-134	Ci	<3.64E-02	<2.69E-02	4.61E-04	1.73E-05
Cs-136	Ci	n/a	n/a	n/a	1.95E-07
Cs-137	Ci	<3.64E-02	<2.69E-02	1.75E-03	9.00E-05
Ce-141	Ci	<3.64E-02	<2.69E-02	<4.95E-04	<6.68E-04
Ce-144	Ci	<3.64E-02	<2.69E-02	<4.95E-04	<6.68E-04
Gross Alpha	Ci	2.53E-06	<5.37E-03	8.54E-06	<1.34E-04
Ar-41	Ci	<7.29E-01	<5.37E-01	2.44E-05	<1.34E-02
Kr-85M	Ci	<7.29E-01	<5.37E-01	1.35E-04	6.53E-06
Kr-85	Ci	<7.29E-01	<5.37E-01	<9.90E-03	<1.34E-02
Kr-87	Ci	<7.29E-01	<5.37E-01	<9.90E-03	1.11E-05
Kr-88	Ci	<7.29E-01	<5.37E-01	7.33E-05	<1.34E-02
Xe-131M	Ci	<7.29E-01	<5.37E-01	2.72E-05	<1.34E-02
Xe-133M	Ci	<7.29E-01	<5.37E-01	1.62E-03	1.62E-04
Xe-133	Ci	<7.29E-01	<5.37E-01	8.29E-02	1.00E-02
Xe-135M	Ci	<7.29E-01	<5.37E-01	1.34E-05	<1.34E-02
Xe-135	Ci	<7.29E-01	<5.37E-01	9.69E-03	1.11E-03

NOTE

"Less than" values are calculated using the Lower Limit of Detection (LLD) values listed in Table 2-1 of the ODCM multiplied by the volume of waste discharged during the respective quarter. The "less than" values are not included in the summation for the total release values.

2002 LIQUID EFFLUENTS

Nuclides Released	Unit	Continuous Mode		Batch Mode	
		Quarter 3	Quarter 4	Quarter 3	Quarter 4
H-3	Ci	1.01E+00	1.02E+00	5.10E+01	4.97E+01
Mn-54	Ci	<2.44E-02	<2.30E-02	<2.44E-04	<1.67E-04
Fe-55	Ci	<4.88E-02	<4.60E-02	<4.88E-04	<3.33E-04
Fe-59	Ci	<2.44E-02	<2.30E-02	<2.44E-04	<1.67E-04
Co-57	Ci	n/a	n/a	7.57E-06	<1.67E-04
Co-58	Ci	<2.44E-02	<2.30E-02	1.38E-03	2.64E-04
Co-60	Ci	<2.44E-02	<2.30E-02	1.31E-04	6.83E-05
Zn-65	Ci	<2.44E-02	<2.30E-02	<2.44E-04	<1.67E-04
Sr-89	Ci	<2.44E-03	<2.30E-03	<2.44E-05	<1.67E-05
Sr-90	Ci	<2.44E-03	<2.30E-03	<2.44E-05	<1.67E-05
Mo-99	Ci	<2.44E-02	<2.30E-02	<2.44E-04	<1.67E-04
Sb-125	Ci	n/a	n/a	1.34E-03	6.04E-04
I-131	Ci	<4.88E-02	<4.60E-02	<4.88E-04	<3.33E-04
Cs-134	Ci	<2.44E-02	<2.30E-02	7.90E-06	1.84E-05
Cs-137	Ci	<2.44E-02	<2.30E-02	4.85E-05	9.87E-05
Ce-141	Ci	<2.44E-02	<2.30E-02	<2.44E-04	<1.67E-04
Ce-144	Ci	<2.44E-02	<2.30E-02	<2.44E-04	<1.67E-04
Gross Alpha	Ci	<4.88E-03	<4.60E-03	<4.88E-05	5.66E-06
Ar-41	Ci	<4.88E-01	<4.60E-01	<4.88E-03	<3.33E-03
Kr-85M	Ci	<4.88E-01	<4.60E-01	<4.88E-03	<3.33E-03
Kr-85	Ci	<4.88E-01	<4.60E-01	<4.88E-03	<3.33E-03
Kr-87	Ci	<4.88E-01	<4.60E-01	<4.88E-03	<3.33E-03
Kr-88	Ci	<4.88E-01	<4.60E-01	<4.88E-03	<3.33E-03
Xe-131M	Ci	<4.88E-01	<4.60E-01	<4.88E-03	<3.33E-03
Xe-133M	Ci	<4.88E-01	<4.60E-01	<4.88E-03	<3.33E-03
Xe-133	Ci	<4.88E-01	<4.60E-01	1.68E-05	4.08E-06
Xe-135M	Ci	<4.88E-01	<4.60E-01	<4.88E-03	<3.33E-03
Xe-135	Ci	<4.88E-01	<4.60E-01	<4.88E-03	<3.33E-03

NOTE

"Less than" values are calculated using the Lower Limit of Detection (LLD) values listed in Table 2-1 of the ODCM multiplied by the volume of waste discharged during the respective quarter. The "less than" values are not included in the summation for the total release values.

**2002 LIQUID CUMULATIVE DOSE SUMMARY
TABLE 1**

QUARTER 1 OF 2002	ODCM CALCULATED DOSE	ODCM ¹ LIMIT	% OF LIMIT
TOTAL DOSE (mRem) FOR BONE	1.08E-02	5.00E+00	2.16E-01
TOTAL DOSE (mRem) FOR LIVER	1.57E-01	5.00E+00	3.14E+00
TOTAL DOSE (mRem) FOR TOTAL BODY	1.52E-01	1.50E+00	1.01E+01
TOTAL DOSE (mRem) FOR THYROID	1.40E-01	5.00E+00	2.80E+00
TOTAL DOSE (mRem) FOR KIDNEY	1.46E-01	5.00E+00	2.92E+00
TOTAL DOSE (mRem) FOR LUNG	1.42E-01	5.00E+00	2.84E+00
TOTAL DOSE (mRem) FOR GI-LLI	1.41E-01	5.00E+00	2.82E+00
QUARTER 2 OF 2002			
TOTAL DOSE (mRem) FOR BONE	4.82E-03	5.00E+00	9.64E-02
TOTAL DOSE (mRem) FOR LIVER	1.17E-01	5.00E+00	2.34E+00
TOTAL DOSE (mRem) FOR TOTAL BODY	1.15E-01	1.50E+00	7.67E+00
TOTAL DOSE (mRem) FOR THYROID	1.10E-01	5.00E+00	2.20E+00
TOTAL DOSE (mRem) FOR KIDNEY	1.12E-01	5.00E+00	2.24E+00
TOTAL DOSE (mRem) FOR LUNG	1.10E-01	5.00E+00	2.20E+00
TOTAL DOSE (mRem) FOR GI-LLI	1.11E-01	5.00E+00	2.22E+00
QUARTER 3 OF 2002			
TOTAL DOSE (mRem) FOR BONE	1.77E-04	5.00E+00	3.54E-03
TOTAL DOSE (mRem) FOR LIVER	3.61E-02	5.00E+00	7.22E-01
TOTAL DOSE (mRem) FOR TOTAL BODY	3.60E-02	1.50E+00	2.40E+00
TOTAL DOSE (mRem) FOR THYROID	3.58E-02	5.00E+00	7.16E-01
TOTAL DOSE (mRem) FOR KIDNEY	3.59E-02	5.00E+00	7.18E-01
TOTAL DOSE (mRem) FOR LUNG	3.58E-02	5.00E+00	7.16E-01
TOTAL DOSE (mRem) FOR GI-LLI	3.59E-02	5.00E+00	7.18E-01
QUARTER 4 OF 2002			
TOTAL DOSE (mRem) FOR BONE	3.82E-04	5.00E+00	7.64E-03
TOTAL DOSE (mRem) FOR LIVER	1.37E-02	5.00E+00	2.74E-01
TOTAL DOSE (mRem) FOR TOTAL BODY	1.35E-02	1.50E+00	9.00E-01
TOTAL DOSE (mRem) FOR THYROID	1.31E-02	5.00E+00	2.62E-01
TOTAL DOSE (mRem) FOR KIDNEY	1.33E-02	5.00E+00	2.66E-01
TOTAL DOSE (mRem) FOR LUNG	1.32E-02	5.00E+00	2.64E-01
TOTAL DOSE (mRem) FOR GI-LLI	1.32E-02	5.00E+00	2.64E-01
TOTALS FOR 2002			
TOTAL DOSE (mRem) FOR BONE	1.62E-02	1.00E+01	1.62E-01
TOTAL DOSE (mRem) FOR LIVER	3.24E-01	1.00E+01	3.24E+00
TOTAL DOSE (mRem) FOR TOTAL BODY	3.16E-01	3.00E+00	1.05E+01
TOTAL DOSE (mRem) FOR THYROID	2.99E-01	1.00E+01	2.99E+00
TOTAL DOSE (mRem) FOR KIDNEY	3.07E-01	1.00E+01	3.07E+00
TOTAL DOSE (mRem) FOR LUNG	3.02E-01	1.00E+01	3.02E+00
TOTAL DOSE (mRem) FOR GI-LLI	3.00E-01	1.00E+01	3.00E+00

1. Based on ODCM Section 2.2, which restricts dose to the whole body to less than or equal to 1.5 mRem per quarter and 3.0 mRem per year. Dose restriction of any organ is less than or equal to 5 mRem per quarter and 10 mRem per year.

**2002 LIQUID CUMULATIVE DOSE SUMMARY
TABLE 2**

A.	Fission and Activation Products (not including H-3, gases, alpha)	Quarter 1	Quarter 2	Quarter 3	Quarter 4	Total
1.	Total Release - (Ci)	4.45E-03	9.77E-03	2.92E-03	1.05E-03	1.82E-02
2.	Maximum Organ Dose (mRem)	1.67E-02	7.27E-03	2.62E-04	5.69E-04	2.48E-02
3.	Organ Dose Limit (mRem)	5.00E+00	5.00E+00	5.00E+00	5.00E+00	1.00E+01
4.	Percent of Limit	3.34E-01	1.45E-01	5.24E-03	1.14E-02	2.48E-01
B.	Tritium					
1.	Total Release - (Ci)	5.81E+02	1.33E+02	5.21E+01	5.07E+01	8.17E+02
2.	Maximum Organ Dose (mRem)	1.40E-01	1.10E-01	3.58E-02	1.31E-02	2.99E-01
3.	Organ Dose Limit (mRem)	5.00E+00	5.00E+00	5.00E+00	5.00E+00	1.00E+01
4.	Percent of Limit	2.80E+00	2.20E+00	7.16E-01	2.62E-01	2.99+00

This table is included to show the correlation between Curies released and the associated calculated maximum organ dose. Wolf Creek ODCM methodology is used to calculate the maximum organ dose which assumes that an individual drinks the water and eats the fish from the discharge point. ODCM Section 2.2 organ dose limits are used.

REPORT OF 2002 RADIOACTIVE EFFLUENTS: AIRBORNE

	Unit	Quarter 1	Quarter 2
A. Fission and Activation Gases			
1. Total Release	Ci	1.34E+00	2.28E+00
2. Average Release Rate for Period	μCi/sec	1.74E-01	2.90E-01
3. Percent of ODCM Limit (1)	%	1.51E-03	3.31E-03
B. Iodines			
1. Total Iodine-131	Ci	0.00E+00	0.00E+00
2. Average Release Rate for Period	μCi/sec	0.00E+00	0.00E+00
3. Percent of Applicable Limit (2)	%	0.00E+00	0.00E+00
C. Particulates			
1. Particulates with Half-lives > 8 days	Ci	1.13E-05	3.00E-06
2. Average Release Rate for Period	μCi/sec	1.47E-06	3.82E-07
3. Percent of ODCM Limit (3)	%	8.04E-05	2.13E-05
4. Gross Alpha Radioactivity	Ci	0.00E+00	0.00E+00
D. Tritium			
1. Total Release	Ci	1.56E+01	1.71E+01
2. Average Release Rate for Period	μCi/sec	2.03E+00	2.18E+00
3. Percent of ODCM Limit (4)	%	1.95E-01	1.18E-01

NOTES:

- 1) The percent of ODCM limit for fission and activation gases is calculated using the following methodology: % of ODCM Limit = $\frac{(\text{Qtrly Total Beta Airdose})(100)}{10 \text{ mrad}}$ or $\frac{(\text{Qtrly Total Gamma Airdose})(100)}{5 \text{ mrad}}$
The largest value calculated between Gamma and Beta air dose is listed as the % of ODCM Limit.
- 2) The percent of ODCM limit for iodine is calculated using the following methodology:
% of ODCM Limit = $\frac{(\text{Total Curies of Iodine - 131})(100)}{1 \text{ Curie}}$
- 3) The percent of ODCM limit for particulates is calculated using the following methodology:
% of ODCM Limit = $\frac{(\text{Highest Organ Dose Due to Particulates})(100)}{7.5 \text{ mrem}}$

NOTE

This type of methodology is used since the Wolf Creek ODCM ties release limits to doses rather than Curie release Rates.

- 4) The percent of ODCM limit for tritium is calculated using the following methodology:

$$\% \text{ of ODCM Limit} = \frac{(\text{Highest Organ Dose Due to H - 3})(100)}{7.5 \text{ mrem}}$$

REPORT OF 2002 RADIOACTIVE EFFLUENTS: AIRBORNE

	Unit	Quarter 3	Quarter 4
A. Fission and Activation Gases			
1. Total Release	Ci	5.82E-01	3.67E-01
2. Average Release Rate for Period	μCi/sec	7.32E-02	4.62E-02
3. Percent of ODCM Limit (1)	%	1.32E-03	7.64E-04
B. Iodines			
1. Total Iodine-131	Ci	0.00E+00	0.00E+00
2. Average Release Rate for Period	μCi/sec	0.00E+00	0.00E+00
3. Percent of Applicable Limit (2)	%	0.00E+00	0.00E+00
C. Particulates			
1. Particulates with Half-lives > 8 days	Ci	0.00E+00	0.00E+00
2. Average Release Rate for Period	μCi/sec	0.00E+00	0.00E+00
3. Percent of ODCM Limit (3)	%	0.00E+00	0.00E+00
4. Gross Alpha Radioactivity	Ci	0.00E+00	0.00E+00
D. Tritium			
1. Total Release	Ci	1.42E+01	1.15E+01
2. Average Release Rate for Period	μCi/sec	1.79E+00	1.45E+00
3. Percent of ODCM Limit (4)	%	1.32E-01	1.07E-01

NOTES:

- 1) The percent of ODCM limit for fission and activation gases is calculated using the following methodology: % of ODCM Limit = $\frac{(\text{Qtrly Total Beta Airdose})(100)}{10 \text{ mrad}}$ or $\frac{(\text{Qtrly Total Gamma Airdose})(100)}{5 \text{ mrad}}$
The largest value calculated between Gamma and Beta air dose is listed as the % of ODCM Limit.
- 2) The percent of ODCM limit for iodine is calculated using the following methodology:
% of ODCM Limit = $\frac{(\text{Total Curies of Iodine - 131})(100)}{1 \text{ Curie}}$
- 3) The percent of ODCM limit for particulates is calculated using the following methodology:
% of ODCM Limit = $\frac{(\text{Highest Organ Dose Due to Particulates})(100)}{7.5 \text{ mrem}}$

NOTE

This type of methodology is used since the Wolf Creek ODCM ties release limits to doses rather than Curie release rates.

- 4) The percent of ODCM limit for tritium is calculated using the following methodology:

$$\% \text{ of ODCM Limit} = \frac{(\text{Highest Organ Dose Due to H - 3})(100)}{7.5 \text{ mrem}}$$

2002 GASEOUS EFFLUENTS

Nuclides Released	Unit	Continuous Mode		Batch Mode	
		Quarter 1	Quarter 2	Quarter 1	Quarter 2
1. Fission and Activation Gases					
Ar-41	Ci	n/a	n/a	3.43E-01	1.40E-01
Kr-85	Ci	n/a	n/a	n/a	6.35E-01
Kr-85M	Ci	n/a	n/a	n/a	n/a
Kr-87	Ci	<4.94E+01	<5.04E+01	<8.79E-01	<6.51E+00
Kr-88	Ci	<5.14E+01	<5.25E+01	<9.16E-01	<6.78E+00
Xe-131M	Ci	n/a	n/a	n/a	7.82E-04
Xe-133	Ci	4.18E-01	1.21E-01	5.74E-01	3.47E-01
Xe-133M	Ci	<9.97E+01	<1.02E+02	<1.78E+00	5.59E-05
Xe-135	Ci	<1.11E+01	1.04E+00	1.09E-03	3.36E-04
Xe-138	Ci	<1.06E+03	<1.08E+03	<1.88E+01	<1.39E+02
Total	Ci	4.18E-01	1.16E+00	9.18E-01	1.12E+00
2. Halogens (Gaseous)					
I-131	Ci	<2.66E-04	<2.71E-04	<4.73E-06	<3.50E-05
I-133	Ci	<2.66E-02	<2.71E-02	<4.73E-04	<3.50E-03
Total	Ci	0.00E+00	0.00E+00	0.00E+00	0.00E+00
3. Particulates and Tritium					
H-3	Ci	5.95E+00	1.07E+01	9.65E+00	6.44E+00
Mn-54	Ci	<2.65E-03	<2.71E-03	<4.73E-05	<3.50E-04
Fe-59	Ci	<2.65E-03	<2.71E-03	<4.73E-05	<3.50E-04
Co-58	Ci	1.13E-05	3.00E-06	<4.73E-05	<3.50E-04
Co-60	Ci	<2.65E-03	<2.71E-03	<4.73E-05	<3.50E-04
Zn-65	Ci	<2.65E-03	<2.71E-03	<4.73E-05	<3.50E-04
Mo-99	Ci	<2.65E-03	<2.71E-03	<4.73E-05	<3.50E-04
Cs-134	Ci	<2.65E-03	<2.71E-03	<4.73E-05	<3.50E-04
Cs-137	Ci	<2.65E-03	<2.71E-03	<4.73E-05	<3.50E-04
Ce-141	Ci	<2.65E-03	<2.71E-03	<4.73E-05	<3.50E-04
Ce-144	Ci	<2.65E-03	<2.71E-03	<4.73E-05	<3.50E-04
Sr-89	Ci	<2.65E-03	<2.71E-03	<4.73E-05	<3.50E-04
Sr-90	Ci	<2.65E-03	<2.71E-03	<4.73E-05	<3.50E-04
Gross Alpha	Ci	<2.65E-03	<2.71E-03	<4.73E-05	<3.50E-04
Total	Ci	5.95E+00	1.07E+01	9.65E+00	6.44E+00

NOTE

"Less than" values for Noble Gases are calculated using the Lower Limit of Detection (LLD) values obtained at Wolf Creek Generating Station multiplied by the volume of air discharged during the respective quarter. For the Halogens and Particulates the ODCM LLD values are used.

2002 GASEOUS EFFLUENTS (Continued)

Nuclides Released	Unit	Continuous Mode		Batch Mode	
		Quarter 3	Quarter 4	Quarter 3	Quarter 4
1. Fission and Activation Gases					
Ar-41	Ci	n/a	n/a	5.78E-01	2.61E-01
Kr-85	Ci	n/a	n/a	n/a	n/a
Kr-85M	Ci	n/a	n/a	n/a	n/a
Kr-87	Ci	<5.03E+01	<5.04E+01	<1.04E-01	<4.61E-02
Kr-88	Ci	<5.24E+01	<5.25E+01	<1.08E-01	<4.80E-02
Xe-131M	Ci	n/a	n/a	n/a	9.44E-03
Xe-133	Ci	<2.72E+01	<2.73E+01	4.27E-03	6.35E-03
Xe-133M	Ci	<1.02E+02	<1.02E+02	<2.10E-01	<9.30E-02
Xe-135	Ci	<1.13E+01	9.11E-02	<2.34E-02	<1.03E-02
Xe-138	Ci	<1.08E+03	<1.08E+03	<2.23E+00	<9.86E-01
Total	Ci	0.00E+00	9.11E-02	5.82E-01	2.77E-01
2. Halogens (Gaseous)					
I-131	Ci	<2.70E-04	<2.71E-04	<5.60E-07	<2.48E-07
I-133	Ci	<2.70E-02	<2.71E-02	<5.60E-05	<2.48E-05
Total	Ci	0.00E+00	0.00E+00	0.00E+00	0.00E+00
3. Particulates and Tritium					
H-3	Ci	1.36E+01	1.09E+01	6.13E-01	5.60E-01
Mn-54	Ci	<2.70E-03	<2.71E-03	<5.60E-06	<2.48E-06
Fe-59	Ci	<2.70E-03	<2.71E-03	<5.60E-06	<2.48E-06
Co-58	Ci	<2.70E-03	<2.71E-03	<5.60E-06	<2.48E-06
Co-60	Ci	<2.70E-03	<2.71E-03	<5.60E-06	<2.48E-06
Zn-65	Ci	<2.70E-03	<2.71E-03	<5.60E-06	<2.48E-06
Mo-99	Ci	<2.70E-03	<2.71E-03	<5.60E-06	<2.48E-06
Cs-134	Ci	<2.70E-03	<2.71E-03	<5.60E-06	<2.48E-06
Cs-137	Ci	<2.70E-03	<2.71E-03	<5.60E-06	<2.48E-06
Ce-141	Ci	<2.70E-03	<2.71E-03	<5.60E-06	<2.48E-06
Ce-144	Ci	<2.70E-03	<2.71E-03	<5.60E-06	<2.48E-06
Sr-89	Ci	<2.70E-03	<2.71E-03	<5.60E-06	<2.48E-06
Sr-90	Ci	<2.70E-03	<2.71E-03	<5.60E-06	<2.48E-06
Gross Alpha	Ci	<2.70E-03	<2.71E-03	<5.60E-06	<2.48E-06
Total	Ci	1.36E+01	1.09E+01	6.13E-01	5.60E-01

NOTE

"Less than" values for Noble Gases are calculated using the Lower Limit of Detection (LLD) values obtained at Wolf Creek Generating Station multiplied by the volume of air discharged during the respective quarter. For the Halogens and Particulates, the ODCM LLD values are used.

**2002 GASEOUS CUMULATIVE DOSE SUMMARY
TABLE 1**

QUARTER 1 OF 2002	ODCM CALCULATED DOSE	ODCM ¹ LIMIT	% OF LIMIT
TOTAL DOSE (mRem) FOR BONE	2.43E-06	7.50E+00	3.25E-05
TOTAL DOSE (mRem) FOR LIVER	1.11E-02	7.50E+00	1.48E-01
TOTAL DOSE (mRem) FOR TOTAL BODY	1.11E-02	7.50E+00	1.48E-01
TOTAL DOSE (mRem) FOR THYROID	1.11E-02	7.50E+00	1.48E-01
TOTAL DOSE (mRem) FOR KIDNEY	1.11E-02	7.50E+00	1.48E-01
TOTAL DOSE (mRem) FOR LUNG	1.11E-02	7.50E+00	1.48E-01
TOTAL DOSE (mRem) FOR GI-LLI	1.11E-02	7.50E+00	1.48E-01
QUARTER 2 OF 2002			
TOTAL DOSE (mRem) FOR BONE	6.51E-07	7.50E+00	8.68E-06
TOTAL DOSE (mRem) FOR LIVER	1.22E-02	7.50E+00	1.62E-01
TOTAL DOSE (mRem) FOR TOTAL BODY	1.22E-02	7.50E+00	1.62E-01
TOTAL DOSE (mRem) FOR THYROID	1.22E-02	7.50E+00	1.62E-01
TOTAL DOSE (mRem) FOR KIDNEY	1.22E-02	7.50E+00	1.62E-01
TOTAL DOSE (mRem) FOR LUNG	1.22E-02	7.50E+00	1.62E-01
TOTAL DOSE (mRem) FOR GI-LLI	1.22E-02	7.50E+00	1.62E-01
QUARTER 3 OF 2002			
TOTAL DOSE (mRem) FOR BONE	0.00E+00	7.50E+00	0.00E+00
TOTAL DOSE (mRem) FOR LIVER	1.01E-02	7.50E+00	1.34E-01
TOTAL DOSE (mRem) FOR TOTAL BODY	1.01E-02	7.50E+00	1.34E-01
TOTAL DOSE (mRem) FOR THYROID	1.01E-02	7.50E+00	1.34E-01
TOTAL DOSE (mRem) FOR KIDNEY	1.01E-02	7.50E+00	1.34E-01
TOTAL DOSE (mRem) FOR LUNG	1.01E-02	7.50E+00	1.34E-01
TOTAL DOSE (mRem) FOR GI-LLI	1.01E-02	7.50E+00	1.34E-01
QUARTER 4 OF 2002			
TOTAL DOSE (mRem) FOR BONE	0.00E+00	7.50E+00	0.00E+00
TOTAL DOSE (mRem) FOR LIVER	8.10E-03	7.50E+00	1.08E-01
TOTAL DOSE (mRem) FOR TOTAL BODY	8.10E-03	7.50E+00	1.08E-01
TOTAL DOSE (mRem) FOR THYROID	8.10E-03	7.50E+00	1.08E-01
TOTAL DOSE (mRem) FOR KIDNEY	8.10E-03	7.50E+00	1.08E-01
TOTAL DOSE (mRem) FOR LUNG	8.10E-03	7.50E+00	1.08E-01
TOTAL DOSE (mRem) FOR GI-LLI	8.10E-03	7.50E+00	1.08E-01
TOTALS FOR 2002			
TOTAL DOSE (mRem) FOR BONE	3.08E-06	1.50E+01	2.05E-05
TOTAL DOSE (mRem) FOR LIVER	4.14E-02	1.50E+01	2.76E-01
TOTAL DOSE (mRem) FOR TOTAL BODY	4.14E-02	1.50E+01	2.76E-01
TOTAL DOSE (mRem) FOR THYROID	4.14E-02	1.50E+01	2.76E-01
TOTAL DOSE (mRem) FOR KIDNEY	4.14E-02	1.50E+01	2.76E-01
TOTAL DOSE (mRem) FOR LUNG	4.14E-02	1.50E+01	2.76E-01
TOTAL DOSE (mRem) FOR GI-LLI	4.14E-02	1.50E+01	2.76E-01

1. Based on Wolf Creek ODCM Section 3.2.2 which restricts dose during any calendar quarter to less than or equal to 7.5 mRem to any organ and during any calendar year to less than or equal to 15 mRem to any organ.

**2002 GASEOUS CUMULATIVE DOSE SUMMARY
TABLE 2**

	Nuclides Released	Quarter 1	Quarter 2	Quarter 3	Quarter 4	Total
A.	Fission and Activation Gases					
1.	Total Release - (Ci)	1.34E+00	2.28E+00	5.82E-01	3.67E-01	4.57E+00
2.	Total Gamma Airdose (mRad)	2.47E-04	2.42E-04	3.75E-04	1.81E-04	1.05E-03
3.	Gamma Airdose Limit (mRad)	5.00E+00	5.00E+00	5.00E+00	5.00E+00	1.00E+01
4.	Percent of Gamma Airdose Limit	4.94E-03	4.85E-03	7.49E-03	3.63E-03	1.05E-02
5.	Total Beta Airdose (mRad)	1.51E-04	3.31E-04	1.32E-04	7.64E-05	6.91E-04
6.	Beta Airdose Limit (mRad)	1.00E+01	1.00E+01	1.00E+01	1.00E+01	2.00E+01
7.	Percent of Beta Airdose Limit (mRad)	1.51E-03	3.31E-03	1.32E-03	7.64E-04	3.46E-03
B.	Particulates					
1.	Total Particulates (Ci)	1.13E-05	3.00E-06	0.00E+00	0.00E+00	1.43E-05
2.	Maximum Organ Dose (mRem)	6.03E-06	1.60E-06	0.00E+00	0.00E+00	7.63E-06
3.	Organ Dose Limit (mRem)	7.50E+00	7.50E+00	7.50E+00	7.50E+00	1.50E+01
4.	Percent of Limit	8.04E-05	2.13E-05	0.00E+00	0.00E+00	5.09E-05
C.	Tritium					
1.	Total Release (Ci)	1.56E+01	1.71E+01	1.42E+01	1.15E+01	5.84E+01
2.	Maximum Organ Dose (mRem)	1.46E-02	8.83E-03	9.93E-03	8.05E-03	4.14E-02
3.	Organ Dose Limit (mRem)	7.50E+00	7.50E+00	7.50E+00	7.50E+00	1.50E+01
4.	Percent of Limit	1.94E-01	1.18E-01	1.32E-01	1.07E-01	2.76E-01
D.	Iodine					
1.	Total I-131, I-133 (Ci)	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
2.	Maximum Organ Dose (mRem)	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
3.	Organ Dose Limit (mRem)	7.50E+00	7.50E+00	7.50E+00	7.50E+00	1.50E+01
4.	Percent of Limit	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00

This table is included to show the correlation between Curies released and the associated calculated maximum organ dose. The maximum organ dose is calculated using Wolf Creek ODCM methodology which assumes that an individual actually resides at the release point. ODCM Section 3.2.2 organ dose limits are used.

SECTION II**SUPPLEMENTAL INFORMATION****1. Offsite Dose Calculation Manual Limits****A. For liquid waste effluents**

- A.1** The concentration of radioactive material released in liquid effluents to **UNRESTRICTED AREAS** shall be limited to the concentrations specified in 10 CFR 20, Appendix B, Table II, Column 2, for radionuclides other than dissolved or entrained noble gases. For dissolved or entrained noble gases, the concentration shall be limited to 2×10^{-4} microCuries/ml total activity.
- A.2** The dose or dose commitment to a **MEMBER OF THE PUBLIC** from radioactive materials in liquid effluents released, from each unit, to **UNRESTRICTED AREAS** shall be limited:
- a. During any calendar quarter to less than or equal to 1.5 mrems to the whole body and to less than or equal to 5 mrems to any organ, and
 - b. During any calendar year to less than or equal to 3 mrems, to the whole body and to less than or equal to 10 mrems to any organ.

B. For gaseous waste effluents

- B.1** The dose rate due to radioactive material released in gaseous effluents from the site to area at and beyond the **SITE BOUNDARY** shall be limited to the following:
- a. For noble gases: Less than or equal to 500 mrems/yr to the whole body and less than or equal to 3000 mrems/yr to the skin, and
 - b. For Iodine-131, Iodine-133, tritium, and all radionuclides in particulate form with half-lives greater than 8 days: Less than or equal to 1500 mrems/yr to any organ.
- B.2** The air dose due to noble gases released in gaseous effluents, from each unit, to areas at and beyond the **SITE BOUNDARY** shall be limited to the following:
- a. During any calendar quarter: Less than or equal to 5 mrad for gamma radiation and less than or equal to 10 mrad for beta radiation, and
 - b. During any calendar year: Less than or equal to 10 mrad for gamma radiation and less than or equal to 20 mrad for beta radiation.
- B.3** The dose from Iodine-131, Iodine-133, tritium, and a radionuclide in particulate form with half-lives greater than 8 days in gaseous effluents released to area at and beyond the **SITE BOUNDARY** shall be limited to the following:
- a. During any calendar quarter: Less than or equal to 7.5 mrems to any organ, and
 - b. During any calendar year: Less than or equal to 15 mrems to any organ.

2. Effluent Concentration Limits (ECLs)

Water - covered in Section 1.A.

Air - covered in Section 1.B.

3. Average Energy

Average energy of fission and activation gaseous effluents is not applicable. See ODCM Section 3.1 for the methodology used in determining the release rate limits from noble gas releases.

4. Measurements and Approximations of Total Radioactivity

A. Liquid Effluents

Liquid Release Type	Sampling Frequency	Method of Analysis	Type of Activity Analysis	
1. Batch Waste Release Tank	P Each Batch	P.H.A.	Principal Gamma Emitters	
	P Each Batch	P.H.A.	I-131	
	a. Waste Monitor Tank	P One Batch/M	P.H.A.	Dissolved and Entrained Gases (Gamma Emitters)
	b. Secondary Liquid Waste Monitor Tanks	P Each Batch	L.S. S.A.C.	H-3 Gross Alpha
P		O.S.L.	Sr-89, Sr-90	
2. Continuous Releases	Daily Grab Sample	P.H.A.	Principal Gamma Emitters	
		P.H.A.	I-131	
	a. Steam Generator Blowdown	M Grab Sample	P.H.A.	Dissolved and entrained Gases (Gamma Emitters)
	b. Turbine Building Sump/Waste Water Treatment	Daily Grab Sample	L.S.	H-3
S.A.C.			Gross Alpha	
c. Lime Sludge Pond	Daily Grab Sample	O.S.L.	Sr-89, Sr-90	
		O.S.L.	Fe-55	

P = prior to each batch

M = monthly

L. S. = Liquid scintillation detector

S.A.C. = scintillation alpha counter

O.S.L. = performed by an offsite laboratory

P.H.A. = gamma spectrum pulse height analysis using a High Purity Germanium detector

B. Gaseous Waste Effluents

Gaseous, Release Type	Sampling Frequency	Method of Analysis	Type of Activity Analysis
Waste Gas Decay Tank	P Each Tank Grab Sample	P.H.A.	Principal Gamma Emitters
Containment Purge or Vent	P Each Purge Grab Sample	P.H.A. <hr/> Gas Bubbler and L.S.	Principal Gamma Emitters <hr/> H-3 (oxide)
Unit Vent	M Grab Sample	P.H.A. <hr/> Gas Bubbler and L.S.	Principal Gamma Emitters <hr/> H-3 (oxide)
Radwaste Building Vent	M Grab Sample	P.H.A.	Principal Gamma Emitters
For Unit Vent and Radwaste Building Vent release types listed above	Continuous	P.H.A.	I-131 <hr/> I-133
	Continuous	P.H.A. Particulate Sample	Principal Gamma Emitters
	Continuous Composite	S.A.C. Particulate Sample	Gross Alpha
	Continuous	O.S.L. Composite Particulate Sample	Sr-89, Sr-90

P = prior to each batch
M = monthly
L.S. = Liquid scintillation detector

S.A.C. = scintillation alpha counter
O.S.L. = performed by an offsite laboratory
P.H.A. = gamma spectrum pulse height analysis using a High Purity Germanium detector

5. Batch Releases

A batch release is the discontinuous release of gaseous or liquid effluents which takes place over a finite period of time, usually hours or days.

There were 77 gaseous batch releases during the reporting period. The longest gaseous batch release lasted 8,842 minutes, while the shortest lasted 14 minutes. The average release lasted 700 minutes with a total gaseous batch release time of 53,888 minutes.

There were 71 liquid batch releases during the reporting period. The longest liquid batch release lasted 280 minutes, while the shortest lasted 50 minutes. The average release lasted 176 minutes with a total liquid batch release time of 12,264 minutes.

6. Continuous Releases

A continuous release is a release of gaseous or liquid effluent, which is essentially uninterrupted for extended periods during normal operation of the facility. Four liquid release pathways were designated as continuous releases during this reporting period: Steam Generator Blowdown, Turbine Building Sump, Waste Water Treatment, and Lime Sludge Pond. Two gas release pathways were designated as continuous releases: Unit Vent and Radwaste Building Vent.

7. Doses to a Member of the Public from Activities Inside the Site Boundary

Four activities by members of the public were considered in this evaluation: personnel making deliveries to the plant, workers at the William Allen White Building located outside of the restricted area, the use of the access road south of the Radwaste Building, and public use of the cooling lake during times when fishing was allowed. The dose calculated for the maximum exposed individual for these four activities was as follows:

Plant Deliveries	4.46E-01 mRem
William Allen White Building Workers	9.91E-03 mRem
Access Road Users	4.57E-02 mRem
Lake Use	6.41E-02 mRem

The plant delivery calculations were based on deliveries 3 hours per week for 50 weeks per year. The William Allen White Building occupancy was based on normal working hours of 2000 per year. The usage factor for the access road south of the Radwaste Building was 25 hours per year. The dose to fishermen on the lake was based upon 3048 hours (12 hours a day for 254 days, based on the number of days that the lake was open to fisherman). Pathways used in the calculation were gaseous inhalation, submersion, and ground plane. All calculations were performed in accordance with the methodology and parameters in the ODCM.

8. Additional Information

PIR 2002-1791 was written on the performance of STN PE-054, "Flow Rate Verification for Fans with Monitored Exhausts" on July 23, 2002. The PIR addressed two problems. The first being that the flow rate on each train was above the design flow rate given in the procedure. The unblocked flow rate for the Radwaste Exhaust Fans was 14,272 cfm for A Train and 14,790 cfm for B Train. The maximum design flow rate is 13,200 cfm (plus instrument inaccuracy). Work requests were written which adjusted the modulating dampers and brought the flow rate for each fan to within design on July 23, 2002. The higher flow rates are attributed to the change out of HEPA filters and prefilters on July 11, 2002. The second issue was the wrong flow rates being recorded and sent to the Control Room for inclusion into the Liquid/Gaseous Discharge Permit Book. The flow rates were 13,215 cfm and 13,125 cfm, respectively. However, the flow rate that was recorded for determining releases was 12,503 and 12,510 cfm, respectively. STN PE-054 takes two flow readings, an unblocked flow and a blocked flow that would simulate dirty filter conditions on the filter adsorber. The flow rates recorded were the lower blocked flow rates. This condition existed from 1-23-01 through 7-23-02. As a result, the affected release permits were edited and the 2002 Annual Report was reviewed and corrected. The corrections are included as Attachment I.

PIR 2002-1242 was written due to liquid release parameters being recorded on the incorrect release permit. The release information for Secondary Liquid Waste Monitor Tank A (THF04A) was recorded on a release permit for Waste Monitor Tank A (THB07A). THF04A was re-circulated, sampled and analyzed for release. The pre-release calculations had been performed using the correct information and release point in the Effluent Management System (EMS). The expected monitor response for the release was calculated using the background value for radiation monitor HBRE18, "Waste Monitor Tank Pump A Discharge." This is the monitor associated with the release of THB07A. The setpoints were entered into the RM-11 for HBRE18. THF04A was discharged through HFRE45, "Plant Disch Line Rad Ele Ent." The setpoints used to release this tank were from the previous tank released through monitor HFRE45. The setpoints for the previous release through HFRE45 were more conservative than the setpoints which should have been entered into HFRE45. Because of the more conservative setpoints used the levels released did not exceed any ODCM limits.

PIR 2002-2647 was written due to a missed ODCM surveillance requirement. GHRE10B was declared inoperable on October 29, 2002 at 1050. Table 3-2 of the ODCM requires grab samples at least once per 12 hours. Chemistry has an administrative limit of once per 10 hours for the 12 hour requirement. On November 3, 2002, the 10 hour administrative sample time was due at 1120. The ODCM 12 hour sample was due at 1320. Due to high work load the chemistry technician failed to sample GHRE10B within the 10 or 12 hour period. The sample was obtained at 1505 which violated the ODCM sampling requirement. As a result of this PIR, Chemistry now uses electrical timers to help track Technical Specification, TRM and ODCM requirements with durations of 24 hours or less.

PIR 2003-0817 was written during the review process for this Annual Report. The presence of several isotopes detected should be evaluated. They include Ar-41 and Na-24 in liquid batch releases, Co-58 in a continuous liquid release and Gross Alpha in both batch and continuous liquid releases. The evaluation of this PIR will be included in the Annual Effluent Report 27 to be submitted in 2004.

2002 EFFLUENT CONCENTRATION LIMITS
Liquid Effluents

<u>Nuclides</u>	<u>Curies</u>	<u>Average Diluted Concentration (uCi/ml)</u>	<u>10 CFR 20 ECL (uCi/ml)</u>	<u>% of ECL</u>
H-3	8.17E+02	9.60E-06	1.00E-03	9.60E-01
Cr-51	3.02E-04	3.55E-12	5.00E-04	7.10E-07
Mn-54	7.72E-05	9.07E-13	3.00E-05	3.02E-06
Co-57	1.23E-05	1.44E-13	6.00E-05	2.40E-07
Co-58	6.69E-03	7.86E-11	2.00E-05	3.93E-04
Co-60	1.14E-03	1.34E-11	3.00E-06	4.47E-04
Sb-125	7.01E-03	8.23E-11	3.00E-05	2.74E-04
I-133	3.38E-06	3.97E-14	7.00E-06	5.67E-07
Cs-134	5.05E-04	5.93E-12	9.00E-07	6.59E-04
Cs-136	1.95E-07	2.29E-15	6.00E-06	3.82E-08
Cs-137	1.99E-03	2.34E-11	1.00E-06	2.34E-03
Na-24	1.67E-06	1.96E-14	5.00E-05	3.92E-08
Fe-59	1.52E-05	1.79E-13	1.00E-05	1.79E-06
Nb-95	1.74E-05	2.04E-13	3.00E-05	6.80E-07
Zr-95	6.84E-06	8.03E-14	2.00E-05	4.02E-07
Tc-99M	7.89E-06	9.27E-14	1.00E-03	9.27E-09
Rb-88	3.28E-04	3.85E-12	4.00E-04	9.63E-07
Sn-117M	3.07E-06	3.61E-14	1.00E-08	3.61E-04
Sb-122	3.21E-05	3.77E-13	1.00E-05	3.77E-06
Sb-124	4.41E-05	5.18E-13	7.00E-06	7.40E-06
Ar-41	2.44E-05	2.87E-13	2.00E-04	1.44E-07
Kr-85M	1.42E-04	1.67E-12	2.00E-04	8.35E-07
Kr-87	1.11E-05	1.30E-13	2.00E-04	6.50E-08
Kr-88	7.33E-05	8.61E-13	2.00E-04	4.31E-07
Xe-131M	2.72E-05	3.19E-13	2.00E-04	1.60E-07
Xe-133M	1.78E-03	2.09E-11	2.00E-04	1.05E-05
Xe-133	9.29E-02	1.09E-09	2.00E-04	6.35E-05
Xe-135M	1.34E-05	1.57E-13	2.00E-04	7.85E-08
Xe-135	1.08E-02	1.27E-10	2.00E-04	6.35E-05

**EFFLUENT AND WASTE DISPOSAL ANNUAL REPORT
2002 SOLID WASTE SHIPMENTS**

A. SOLID RADWASTE SHIPPED OFFSITE FOR BURIAL OR DISPOSAL (Not Irradiated fuel)

1. Type of Waste	Unit	1- Year Period	Est. Total Error %
a. Spent resins, filter sludges evaporator bottoms, etc.	m3*	6.56E+01**	2.50E+01
	Ci	5.62E+02	
b. Dry compressible waste, contaminated equip. etc.	m3*	1.54E+02**	2.50E+01
	Ci	7.73E-01	
c. Irradiated components, control rods, etc.	m3*	0.00E+00	2.50E+01
	Ci	0.00E+00	
d. Other	m3*	0.00E+00	2.50E+01
	Ci	0.00E+00	

*m3 = cubic meters **Volume sent offsite for volume reduction, prior to disposal.

2. Estimate of Major Nuclide Composition (by type of waste).
[Nuclides listed with % abundance greater than 10 %]

a. Spent resin, filter sludges, evaporator bottoms, etc.

<u>Nuclide Name</u>	<u>Percent Abundance</u>	<u>Curies</u>
Fe-55	22.950	1.29E+02
Co-58	12.443	7.00E+01
Ni-63	42.658	2.40E+02

b. Dry compressible waste, contaminated equipment, etc.

<u>Nuclide Name</u>	<u>Percent Abundance</u>	<u>Curies</u>
Fe-55	26.313	2.03E-01
Co-58	13.540	1.05E-01
Ni-63	30.910	2.39E-01

c. Irradiated components, control rods, etc. - None

d. Other - None

3. Solid Waste Disposition

<u>Number of Shipments</u>	<u>Mode of Transportation</u>	<u>Destination</u>
5	Truck (Hittman Transport Services)	Barnwell Waste Management Facility, Barnwell, SC
2	Truck (Hittman Transport Services)	Duratek, Inc., Bear Creek, Oak Ridge, TN
2	Truck (Hittman Transport Services)	Duratek Inc., Gallaher, Oak Ridge, TN
1	Truck (Tag Transport Services)	Duratek Inc., Gallaher, Oak Ridge, TN
4	Truck (Hittman Transport Services)	Studsvik Processing Facility, LLC; Columbia, SC
2	Truck (Kendrick Trucking)	Studsvik Processing Facility, LLC; Columbia, SC

4. Class of Solid Waste

- a. Class A, Class B, Class C- Corresponding to 2a
- b. Class A, Class B - Corresponding to 2b
- c. Not applicable
- d. Not applicable

5. Type of Container

- a. LSA (Strong, tight), Type A, Type B - corresponding to 2a
- b. LSA (Strong, tight) - corresponding to 2b
- c. Not applicable
- d. Not applicable

6. Solidification Agent

- a. Not applicable
- b. Not applicable
- c. Not applicable
- d. Not applicable

B. IRRADIATED FUEL SHIPMENTS (Disposition)

No irradiated fuel shipments occurred during the 2002 period.

SECTION III

HOURS AT EACH WIND SPEED AND DIRECTION

This section documents WCGS meteorological data for wind speed, wind direction, and atmospheric stability.

The meteorological data supplied in the following tables covers the period from January 1, 2002, through December 31, 2002, and indicates the number of hours at each wind speed and direction for each stability class. All gaseous releases at the WCGS are ground level releases. Wolf Creek Generating Station meets Regulatory Guide 1.23 requirement for having at least 90% meteorological data recovery for 2002.

PIR 2002-0576 was written March 11, 2002, to evaluate the fact that we did not meet the 90% availability in 2001 as required by Regulatory Guide 1.23. The following is a summary of the evaluation.

Two methods are used to calculate the availability of the Meteorological data:

1. A Meteorological Professor at the University of Kansas established the first set of criteria. This verification takes a look at all instruments on the tower and compares the instruments against one another to verify a parameter that is outside the normal meteorological parameters for this part of Kansas. The software then flags all parameters in that 15-minute period as bad data. Bad data is then accumulated assuming all parameters were unavailable. This method also flags data as bad anytime the communication link to the plant computer is down. This method is conservative and may flag data as bad even though the required Reg. Guide 1.23 instruments are still available.
2. The second method available for calculating meteorological data availability is using the Maintenance Rule data base unavailability program. This method uses a software program that searches the electronic control room logs as the main source for tracking unavailability for Maintenance Rule components.

Prior to 2002, Method #1 was the only method used to determine the meteorological data availability. As a result of this evaluation both methods will now be used to determine the meteorological data availability.

HOURS AT EACH WIND SPEED AND DIRECTION

PERIOD OF RECORD: JANUARY 1 THROUGH DECEMBER 31 2002
 STABILITY CLASS: A
 ELEVATION: 10 METERS

WIND DIRECTION	WIND SPEED (mph)						TOTAL
	1-3	4-7	8-12	13-18	19-24	>24	
N	0	3	6	2	5	1	17
NNE	0	7	2	2	0	0	11
NE	0	10	2	0	0	0	12
ENE	0	5	1	1	0	0	7
E	0	5	3	0	0	0	8
ESE	1	4	2	1	0	0	8
SE	1	8	6	4	0	0	19
SSE	0	14	8	4	1	0	27
S	0	10	14	6	2	4	36
SSW	0	2	9	12	6	1	30
SW	1	3	3	2	2	0	11
WSW	0	3	1	0	1	0	5
W	0	1	2	0	0	0	3
WNW	0	0	3	1	0	0	4
NW	0	2	1	3	4	4	14
NNW	1	2	4	6	1	0	14
TOTAL	4	79	67	44	22	10	226

PERIOD OF
 CALM
 (HOURS): 1

HOURS AT EACH WIND SPEED AND DIRECTION

PERIOD OF RECORD: JANUARY 1 THROUGH DECEMBER 31 2002

STABILITY CLASS: B

ELEVATION: 10 METERS

WIND DIRECTION	WIND SPEED (mph)						TOTAL
	1-3	4-7	8-12	13-18	19-24	>24	
N	2	5	15	10	3	0	35
NNE	1	5	8	6	4	0	24
NE	1	7	9	0	0	0	17
ENE	0	9	8	0	0	0	17
E	1	13	5	0	0	0	19
ESE	0	13	5	2	0	0	20
SE	1	11	19	5	0	0	36
SSE	0	19	11	8	2	0	40
S	0	18	26	13	6	4	67
SSW	1	4	11	14	9	2	41
SW	2	0	7	1	2	0	12
WSW	1	7	8	4	1	0	21
W	1	4	3	1	2	0	11
WNW	1	7	3	7	3	1	22
NW	0	5	14	16	13	9	57
NNW	1	6	13	17	9	2	48
TOTAL	13	133	165	104	54	18	487

PERIOD OF
CALM
(HOURS): 7

HOURS AT EACH WIND SPEED AND DIRECTION

PERIOD OF RECORD: JANUARY 1 THROUGH DECEMBER 31 2002
 STABILITY CLASS: C
 ELEVATION: 10 METERS

WIND DIRECTION	WIND SPEED (mph)						TOTAL
	1-3	4-7	8-12	13-18	19-24	>24	
N	1	6	18	11	6	2	44
NNE	2	13	22	9	4	1	51
NE	1	15	4	0	1	0	21
ENE	2	7	6	1	0	0	16
E	0	13	7	3	0	0	23
ESE	0	8	7	3	1	0	19
SE	1	12	10	8	0	0	31
SSE	0	25	12	10	2	1	50
S	1	14	8	15	10	3	51
SSW	0	0	14	9	6	1	30
SW	2	5	3	1	1	0	12
WSW	1	3	4	1	0	0	9
W	0	3	3	2	0	0	8
WNW	1	3	5	5	4	1	39
NW	1	7	19	18	5	0	50
NNW	1	7	12	10	2	2	34
TOTAL	14	141	154	106	42	11	468

PERIOD OF
 CALM
 (HOURS):
 14

HOURS AT EACH WIND SPEED AND DIRECTION

PERIOD OF RECORD: JANUARY 1 THROUGH DECEMBER 31 2002
 STABILITY CLASS: D
 ELEVATION: 10 METERS

WIND DIRECTION	WIND SPEED (mph)						TOTAL
	1-3	4-7	8-12	13-18	19-24	>24	
N	3	34	104	01	23	7	272
NNE	5	33	70	50	21	2	181
NE	16	70	47	11	0	0	144
ENE	7	44	43	4	1	0	99
E	3	40	32	7	0	0	82
ESE	7	54	37	14	4	0	116
SE	4	55	101	97	7	0	264
SSE	4	36	114	80	22	5	261
S	10	41	172	146	74	23	466
SSW	8	27	106	62	25	1	245
SW	5	39	12	5	1	0	62
WSW	3	16	22	4	2	1	48
W	2	21	18	0	1	0	42
WNW	3	13	31	18	1	0	66
NW	4	21	59	40	9	5	138
NNW	0	41	64	48	26	6	185
TOTAL	84	601	1032	687	217	50	2671

PERIOD OF
 CALM
 (HOURS):
 29

HOURS AT EACH WIND SPEED AND DIRECTION

PERIOD OF RECORD: JANUARY 1 THROUGH DECEMBER 31 2002

STABILITY CLASS: E

ELEVATION: 10 METERS

WIND DIRECTION	WIND SPEED (mph)						TOTAL
	1-3	4-7	8-12	13-18	19-24	>24	
N	5	40	77	37	23	11	193
NNE	3	36	36	13	1	2	91
NE	15	35	10	1	0	0	61
ENE	8	58	38	4	0	0	108
E	6	53	40	6	1	1	107
ESE	5	90	52	14	3	0	164
SE	7	98	135	88	10	1	339
SSE	3	94	159	101	28	5	390
S	3	50	158	183	86	23	503
SSW	5	48	74	68	36	2	233
SW	5	53	31	9	2	0	100
WSW	4	37	15	8	2	0	66
W	5	27	34	4	3	1	74
WNW	3	22	20	10	3	1	59
NW	2	35	31	4	7	3	82
NNW	3	35	57	30	12	9	146
TOTAL	82	811	967	580	217	59	2716

PERIOD OF
CALM
(HOURS): 1

HOURS AT EACH WIND SPEED AND DIRECTION

PERIOD OF RECORD: JANUARY 1 THROUGH DECEMBER 31 2002
 STABILITY CLASS: F
 ELEVATION: 10 METERS

WIND DIRECTION	WIND SPEED (mph)						TOTAL
	1-3	4-7	8-12	13-18	19-24	>24	
N	6	42	21	0	0	0	69
NNE	3	24	6	0	0	0	33
NE	12	25	0	0	0	0	37
ENE	7	63	3	1	0	0	74
E	14	70	16	0	0	0	100
ESE	6	93	13	0	1	0	113
SE	6	55	15	0	0	0	76
SSE	3	35	30	2	5	0	75
S	2	5	28	19	0	0	54
SSW	0	8	10	3	0	0	21
SW	2	16	3	1	0	0	22
WSW	3	12	4	0	0	0	19
W	1	0	1	0	0	0	2
WNW	3	5	3	0	0	0	11
NW	4	23	3	0	0	0	30
NNW	6	27	16	1	0	0	50
TOTAL	78	503	172	27	6	0	786

PERIOD OF
 CALM
 (HOURS): 2

HOURS AT EACH WIND SPEED AND DIRECTION

PERIOD OF RECORD: JANUARY 1 THROUGH DECEMBER 31 2002
 STABILITY CLASS: G
 ELEVATION: 10 METERS

WIND DIRECTION	WIND SPEED (mph)						TOTAL
	1-3	4-7	8-12	13-18	19-24	>24	
N	0	17	3	0	0	0	20
NNE	2	44	9	0	0	0	55
NE	10	16	0	0	0	0	26
ENE	3	28	2	0	0	0	33
E	1	51	6	0	0	0	58
ESE	0	44	8	0	0	0	52
SE	1	27	3	0	0	0	31
SSE	2	15	8	0	0	0	25
S	0	8	0	0	0	0	8
SSW	3	0	1	0	0	0	4
SW	1	5	0	0	0	0	6
WSW	0	2	0	0	0	0	2
W	0	1	0	0	0	0	1
WNW	2	1	0	0	0	0	3
NW	1	13	7	0	0	0	21
NNW	5	17	10	0	0	0	32
TOTAL	31	289	57	0	0	0	377

PERIOD OF
 CALM
 (HOURS): 2

HOURS AT EACH WIND SPEED AND DIRECTION

PERIOD OF RECORD: JANUARY 1 THROUGH DECEMBER 31 2002
 STABILITY CLASS: ALL
 ELEVATION: 10 METERS

WIND DIRECTION	WIND SPEED (mph)						TOTAL
	1-3	4-7	8-12	13-18	19-24	>24	
N	17	147	244	161	60	21	650
NNE	16	162	153	80	30	5	446
NE	55	178	72	12	1	0	318
ENE	27	214	101	11	1	0	354
E	25	245	109	16	1	1	397
ESE	19	306	124	34	9	0	492
SE	21	266	289	202	17	1	796
SSE	12	238	342	205	60	11	868
S	16	146	406	382	178	57	1185
SSW	17	105	225	168	82	7	604
SW	18	121	59	19	8	0	225
WSW	12	80	54	17	6	1	170
W	9	57	61	7	6	1	141
WNW	13	51	65	41	11	3	184
NW	12	106	134	181	38	21	392
NNW	17	135	176	112	50	19	509
TOTAL	306	2557	2614	1548	558	148	7731

PERIOD OF
 CALM
 (HOURS):
 56

SECTION IV

ADDITIONAL INFORMATION

1. Unplanned or Abnormal Releases

On May 20, 2002, at 2119 it was determined by Radwaste Operations that Gas Decay Tank (GDT) #6 was losing pressure. The tank had decreased approximately 6 psig from 0500 hrs on May 20, 2002. A trend of Radiation Monitor GHRE-023 indicated a slight increase from $1.0E-06$ to $1.3E-06$ uCi/cc over the time period. A trend of the Radwaste Effluent Gas Monitor showed no significant increase over the period. Health Physics pulled a gas sample in the area and noted that fission gases were present. A Volume Control Tank (VCT) purge was in progress. The purge was secured and the Waste Gas System was shut down. The cause for the loss of pressure in GDT #6 was equipment failure due to gas leakage past the valve seat at HAV0079, Recombiner Moisture Separator Drain Valve. The operational leakage was captured by the Radwaste Building exhaust ventilation system and filtered prior to release into the environment. A release total of $4.65E-2$ curies were released as a result of this event. The release is captured on Vent Release Permit #2002-0106. Work Requests were written on the leaking valve. (WO 02-237639-000)

2. Offsite Dose Calculation Manual (ODCM)

The ODCM is in the form of two separate Wolf Creek Nuclear Operating Corporation (WCNOC) administrative procedures. One of these procedures, the WCNOC "Offsite Dose Calculation Manual", AP 07B-003, Revision 4, was revised in 2001; it is included with this report as Attachment II. The other procedure, "Offsite Dose Calculation Manual (Radiological Environmental Monitoring Program)", AP 07B-004, Revision 4, was revised in 2002; it is included with this report as Attachment III.

3. Major Changes to Liquid, Solid, or Gaseous Radioactive Waste Treatment Systems

As previously reported in the "1999 Annual Radioactive Effluent Release Report- Report 22", a state-of-the-art filtration system was installed in 1998. Below is a summary of the improvements that were made to the system in 2002.

The Recycle and Secondary Liquid Waste Evaporators were permanently removed from service during 2002 with the implementation of Change Package 06244. The vendor supplied water processing skids installed under Temporary Modification 98-018-HB are providing the water processing function previously performed by the retired components. This Temporary Modification is being made permanent with the implementation of Design Change Package 9337. Hard piping and alternative processing options for some of the concentrate streams will allow more efficient area dose control and minimize issues with processing via long runs of temporary hose.

4. Land Use Census

No new locations for dose calculation were identified during this report period.

5. Radwaste Shipments

Sixteen shipments of radioactive waste occurred during this report period. Section II, Subsection 3, of this report contains specific details regarding each shipment's mode of transportation and destination.

6. Inoperability of Effluent Monitoring Instrumentation

No events occurred that violated ODCM Requirements Tables 2-2 and 3-2, liquid or gaseous effluent monitoring instrumentation.

7. Storage Tanks

At no time during the year 2002 was there an event that lead to liquid holdup tanks or gas storage tanks exceeding the limits of Technical Requirements Manual Sections 3.10.1 or 3.10.3 . Technical Specification requirements for the program are now covered by Technical Requirements Manual Section 3.10, "Explosive Gas and Storage Tank Radioactivity Monitoring."

**ATTACHMENTS TO WCGS
ANNUAL RADIOACTIVE EFFLUENT RELEASE REPORT – REPORT 26**

Attachment I contains the corrections to the Annual Radioactive Effluent Release Report – Report 25 as a result of PIR 2002-1791 written to document the incorrect flow rate for the Radwaste Vent being given to the Control Room during the performance of STN PE-054. The corrected numbers are bolded and the numbers previously reported are in parenthesis.

Changes to the Wolf Creek Generating Station (WCGS) Offsite Dose Calculation Manual (ODCM) are submitted annually with the "Annual Radioactive Effluent Release Report." The WCGS ODCM is divided into two administrative procedures: WCNOG procedure AP 07B-003, "Offsite Dose Calculation Manual" and WCNOG procedure AP 07B-004, "Offsite Dose Calculation Manual (Radiological Environmental Monitoring Program)".

Attachment II is AP 07B-003, Revision 4, "Offsite Dose Calculation Manual"

Attachment III is AP 07B-004, Revision 4, "Offsite Dose Calculation Manual (Radiological Environmental Monitoring Program)"

Attachment IV is AP 31A-100, Revision 4, "Solid Radwaste Process Control Program"

**Attachment I to the Wolf Creek Generating Station
Annual Radiological Effluent Release Report 26**

Attachment 1

**Annual Radiological Effluent Report – Report 25
Corrections Resulting from PIR 2002-1791**

**Attachment I
2002 Annual Report Corrections Resulting from PIR 2002-1791**

REPORT OF 2001 RADIOACTIVE EFFLUENTS: AIRBORNE

	Unit	Quarter 1	Quarter 2
A. Fission and Activation Gases			
1. Total Release	Ci	8.54E-01	1.06E+00 (1.04)
2. Average Release Rate for Period	μCi/sec	1.10E-01	1.35E-01 (1.32E-01)
3. Percent of ODCM Limit (1)	%	4.31E-03	5.12E-03
B. Iodines			
1. Total Iodine-131	Ci	0.00E+00	0.00E+00
2. Average Release Rate for Period	μCi/sec	0.00E+00	0.00E+00
3. Percent of Applicable Limit (2)	%	0.00E+00	0.00E+00
C. Particulates			
1. Particulates with Half-lives > 8 days	Ci	0.00E+00	0.00E+00
2. Average Release Rate for Period	μCi/sec	0.00E+00	0.00E+00
3. Percent of ODCM Limit (3)	%	0.00E+00	0.00E+00
4. Gross Alpha Radioactivity	Ci	0.00E+00	0.00E+00
D. Tritium			
1. Total Release	Ci	5.70E+00	1.19E+01
2. Average Release Rate for Period	μCi/sec	7.33E-01	1.52E+00
3. Percent of ODCM Limit (4)	%	5.59E-02	1.14E-01

NOTES:

- 4) The percent of ODCM limit for fission and activation gases is calculated using the following methodology: % of ODCM Limit = $\frac{(\text{Qtrly Total Beta Airdose})(100)}{10 \text{ mrad}}$ or $\frac{(\text{Qtrly Total Gamma Airdose})(100)}{5 \text{ mrad}}$
The largest value calculated between Gamma and Beta air dose is listed as the % of ODCM Limit.
- 5) The percent of ODCM limit for iodine is calculated using the following methodology:
% of ODCM Limit = $\frac{(\text{Total Curies of Iodine - 131})(100)}{1 \text{ Curie}}$
- 6) The percent of ODCM limit for particulates is calculated using the following methodology:
% of ODCM Limit = $\frac{(\text{Highest Organ Dose Due to Particulates})(100)}{7.5 \text{ mrem}}$

NOTE

This type of methodology is used since the Wolf Creek ODCM ties release limits to doses rather than Curie release rates.

- 4) The percent of ODCM limit for tritium is calculated using the following methodology:

$$\% \text{ of ODCM Limit} = \frac{(\text{Highest Organ Dose Due to H - 3})(100)}{7.5 \text{ mrem}}$$

2001 GASEOUS EFFLUENTS

Nuclides Released	Unit	Continuous Mode		Batch Mode	
		Quarter 1	Quarter 2	Quarter 1	Quarter 2
1. Fission and Activation Gases					
Ar-41	Ci	n/a	n/a	2.93E-01	3.59E-01
Kr-85	Ci	n/a	n/a	3.44E-01	2.09E-01
Kr-85M	Ci	n/a	n/a	n/a	n/a
Kr-87	Ci	<3.53E+01	<3.74E+01	<4.10E-02	<5.27E-02
Kr-88	Ci	<4.52E+01	<4.79E+01	<5.26E-02	<6.75E-02
Xe-131M	Ci	n/a	n/a	n/a	n/a
Xe-133	Ci	<2.56E+01	3.47E-01(3.29E-01)	3.01E-02	3.99E-02
Xe-133M	Ci	<7.94E+01	<8.41E+01	<9.26E-02	<1.19E-01
Xe-135	Ci	1.87E-01	1.04E-01	<1.36E-02	1.36E-04
Xe-138	Ci	<1.11E+03	<1.17E+03	<1.29E+00	<1.65E+00
Total	Ci	1.87E-01	4.51E-01(4.32E-01)	6.67E-01	6.08E-01
2. Halogens (Gaseous)					
I-131	Ci	<2.44E-04	<2.58E-04	<2.84E-07	<3.65E-07
I-133	Ci	<2.44E-02	<2.58E-02	<2.84E-05	<3.65E-05
Total	Ci	0.00E+00	0.00E+00	0.00E+00	0.00E+00
3. Particulates and Tritium					
H-3	Ci	5.41E+00	1.06E+01	2.89E-01	1.32E+00
Mn-54	Ci	<2.44E-03	<2.57E-03	<2.84E-06	<3.65E-06
Fe-59	Ci	<2.44E-03	<2.57E-03	<2.84E-06	<3.65E-06
Co-58	Ci	<2.44E-03	<2.57E-03	<2.84E-06	<3.65E-06
Co-60	Ci	<2.44E-03	<2.57E-03	<2.84E-06	<3.65E-06
Zn-65	Ci	<2.44E-03	<2.57E-03	<2.84E-06	<3.65E-06
Mo-99	Ci	<2.44E-03	<2.57E-03	<2.84E-06	<3.65E-06
Cs-134	Ci	<2.44E-03	<2.57E-03	<2.84E-06	<3.65E-06
Cs-137	Ci	<2.44E-03	<2.57E-03	<2.84E-06	<3.65E-06
Ce-141	Ci	<2.44E-03	<2.57E-03	<2.84E-06	<3.65E-06
Ce-144	Ci	<2.44E-03	<2.57E-03	<2.84E-06	<3.65E-06
Sr-89	Ci	<2.44E-03	<2.57E-03	<2.84E-06	<3.65E-06
Sr-90	Ci	<2.44E-03	<2.57E-03	<2.84E-06	<3.65E-06
Gross Alpha	Ci	<2.44E-03	<2.57E-03	<2.84E-06	<3.65E-06
Total	Ci	5.41E+00	1.06E+01	2.89E-01	1.32E+00

NOTE

"Less than" values for Noble Gases are calculated using the Lower Limit of Detection (LLD) values obtained at Wolf Creek Generating Station multiplied by the volume of air discharged during the respective quarter. For the Halogens and Particulates the ODCM LLD values are used.

**2001 GASEOUS CUMULATIVE DOSE SUMMARY
TABLE 1**

QUARTER 1 OF 2001	ODCM CALCULATED DOSE	ODCM ¹ LIMIT	% OF LIMIT
TOTAL DOSE (mRem) FOR BONE	0.00E+00	7.50E+00	0.00E+00
TOTAL DOSE (mRem) FOR LIVER	4.03E-03	7.50E+00	5.37E-02
TOTAL DOSE (mRem) FOR TOTAL BODY	4.03E-03	7.50E+00	5.37E-02
TOTAL DOSE (mRem) FOR THYROID	4.03E-03	7.50E+00	5.37E-02
TOTAL DOSE (mRem) FOR KIDNEY	4.03E-03	7.50E+00	5.37E-02
TOTAL DOSE (mRem) FOR LUNG	4.03E-03	7.50E+00	5.37E-02
TOTAL DOSE (mRem) FOR GI-LLI	4.03E-03	7.50E+00	5.37E-02
QUARTER 2 OF 2001			
TOTAL DOSE (mRem) FOR BONE	0.00E+00	7.50E+00	0.00E+00
TOTAL DOSE (mRem) FOR LIVER	8.47E-03(8.44E-03)	7.50E+00	1.13E-01
TOTAL DOSE (mRem) FOR TOTAL BODY	8.47E-03(8.44E-03)	7.50E+00	1.13E-01
TOTAL DOSE (mRem) FOR THYROID	8.47E-03(8.44E-03)	7.50E+00	1.13E-01
TOTAL DOSE (mRem) FOR KIDNEY	8.47E-03(8.44E-03)	7.50E+00	1.13E-01
TOTAL DOSE (mRem) FOR LUNG	8.47E-03(8.44E-03)	7.50E+00	1.13E-01
TOTAL DOSE (mRem) FOR GI-LLI	8.47E-03(8.44E-03)	7.50E+00	1.13E-01
QUARTER 3 OF 2001			
TOTAL DOSE (mRem) FOR BONE	0.00E+00	7.50E+00	0.00E+00
TOTAL DOSE (mRem) FOR LIVER	1.39E-02	7.50E+00	1.85E-01
TOTAL DOSE (mRem) FOR TOTAL BODY	1.39E-02	7.50E+00	1.85E-01
TOTAL DOSE (mRem) FOR THYROID	1.39E-02	7.50E+00	1.85E-01
TOTAL DOSE (mRem) FOR KIDNEY	1.39E-02	7.50E+00	1.85E-01
TOTAL DOSE (mRem) FOR LUNG	1.39E-02	7.50E+00	1.85E-01
TOTAL DOSE (mRem) FOR GI-LLI	1.39E-02	7.50E+00	1.85E-01
QUARTER 4 OF 2001			
TOTAL DOSE (mRem) FOR BONE	0.00E+00	7.50E+00	0.00E+00
TOTAL DOSE (mRem) FOR LIVER	1.09E-02	7.50E+00	1.46E-01
TOTAL DOSE (mRem) FOR TOTAL BODY	1.09E-02	7.50E+00	1.46E-01
TOTAL DOSE (mRem) FOR THYROID	1.09E-02	7.50E+00	1.46E-01
TOTAL DOSE (mRem) FOR KIDNEY	1.09E-02	7.50E+00	1.46E-01
TOTAL DOSE (mRem) FOR LUNG	1.09E-02	7.50E+00	1.46E-01
TOTAL DOSE (mRem) FOR GI-LLI	1.09E-02	7.50E+00	1.46E-01
TOTALS FOR 2001			
TOTAL DOSE (mRem) FOR BONE	0.00E+00	1.50E+01	0.00E+00
TOTAL DOSE (mRem) FOR LIVER	3.73E-02	1.50E+01	2.49E-01
TOTAL DOSE (mRem) FOR TOTAL BODY	3.73E-02	1.50E+01	2.49E-01
TOTAL DOSE (mRem) FOR THYROID	3.73E-02	1.50E+01	2.49E-01
TOTAL DOSE (mRem) FOR KIDNEY	3.73E-02	1.50E+01	2.49E-01
TOTAL DOSE (mRem) FOR LUNG	3.73E-02	1.50E+01	2.49E-01
TOTAL DOSE (mRem) FOR GI-LLI	3.73E-02	1.50E+01	2.49E-01

1. Based on Wolf Creek ODCM Section 3.2.2 which restricts dose during any calendar quarter to less than or equal to 7.5 mRem to any organ and during any calendar year to less than or equal to 15 mRem to any organ.

**2001 GASEOUS CUMULATIVE DOSE SUMMARY
TABLE 2**

Nuclides Released	Quarter 1	Quarter 2	Quarter 3	Quarter 4	Total
A. Fission and Activation Gases					
1. Total Release - (Ci)	8.54E-01	1.06E+00	8.68E-01	1.88E+00	4.66E+00
2. Total Gamma Airdose (mRad)	2.16E-04	2.56E-04	4.99E-04	4.64E-04	1.44E-03
3. Gamma Airdose Limit (mRad)	5.00E+00	5.00E+00	5.00E+00	5.00E+00	1.00E+01
4. Percent of Gamma Airdose Limit	4.33E-03	5.12E-03	9.98E-03	9.29E-03	1.44E-02
5. Total Beta Airdose (mRad)	1.48E-04	1.57E-04	1.83E-04	3.14E-04	8.02E-04
		(1.55E-04)			(8.01E-04)
6. Beta Airdose Limit (mRad)	1.00E+01	1.00E+01	1.00E+01	1.00E+01	2.00E+01
7. Percent of Beta Airdose Limit (mRad)	1.48E-03	1.57E-03	1.83E-03	3.14E-03	4.01E-03
		(1.55E-03)			
B. Particulates					
1. Total Particulates (Ci)	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
2. Maximum Organ Dose (mRem)	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
3. Organ Dose Limit (mRem)	7.50E+00	7.50E+00	7.50E+00	7.50E+00	1.50E+01
4. Percent of Limit	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
C. Tritium					
1. Total Release (Ci)	5.70E+00	1.19E+01	1.96E+01	1.55E+01	5.27E+01
2. Maximum Organ Dose (mRem)	4.19E-03	8.54E-03	1.37E-02	1.08E-02	3.73E-02
3. Organ Dose Limit (mRem)	7.50E+00	7.50E+00	7.50E+00	7.50E+00	1.50E+01
4. Percent of Limit	5.59E-02	1.14E-01	1.83E-01	1.44E-01	2.49E-01
D. Iodine					
1. Total I-131, I-133 (Ci)	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
2. Maximum Organ Dose (mRem)	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
3. Organ Dose Limit (mRem)	7.50E+00	7.50E+00	7.50E+00	7.50E+00	1.50E+01
4. Percent of Limit	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00

This table is included to show the correlation between Curies released and the associated calculated maximum organ dose. The maximum organ dose is calculated using Wolf Creek ODCM methodology which assumes that an individual actually resides at the release point. ODCM Section 3.2.2 organ dose limits are used.

**Attachment II to the Wolf Creek Generating Station
Annual Radiological Effluent Release Report 26**

Attachment II

AP 07B-003, Revision 4

Offsite Dose Calculation Manual

CORRECTED COPY 06/26/2002



AP 07B-003

OFFSITE DOSE CALCULATION MANUAL

Responsible Manager

Manager Chemistry/Radiation Protection

Revision Number	4
Use Category	Reference
Administrative Controls Procedure	Yes
Infrequently Performed Procedure	No
Program Number	07B

DC12 10/18/2001

TABLE OF CONTENTS

<u>SECTION</u>	<u>TITLE</u>	<u>PAGE</u>
1.0	PURPOSE	2
2.0	SCOPE	2
3.0	REFERENCES AND COMMITMENTS	2
4.0	DEFINITIONS	3
5.0	RESPONSIBILITIES	3
6.0	PROCEDURE	4
6.1	Revision Of The ODCM	4
6.2	ODCM Submittal To NRC	4
7.0	RECORDS	5
8.0	FORMS	5
	ATTACHMENT A OFFSITE DOSE CALCULATION MANUAL	6

Revision: 4	OFFSITE DOSE CALCULATION MANUAL	AP 07B-003
Reference Use		Page 2 of 165

1.0 PURPOSE

1.1 This procedure contains the Offsite Dose Calculation Manual (ODCM) and the requirements for revision and submittal to the NRC.

2.0 SCOPE

2.1 This procedure partially fulfills the requirements of Technical Specifications 3.3.6, 3.3.7, and 3.3.8 Radiation Monitoring Instrumentation; 5.5.2 Primary Coolant Sources Outside Containment; 5.6.3 Radioactive Effluent Release Report and 5.5.1 Offsite Dose Calculation Manual.

2.2 Requirements for the Radiological Environmental Monitoring Program have been moved to AP 07B-004.

3.0 REFERENCES AND COMMITMENTS

3.1 References

3.1.1 WCGS Technical Specifications

3.1.2 AP 15C-001, PROCEDURE WRITERS GUIDE

3.1.3 AP 15C-004, PREPARATION, REVIEW, AND APPROVAL OF DOCUMENTS

3.1.4 Regulatory Guide 1.109, Calculation of Annual Doses to Man from Routine Releases of Reactor Effluents for the Purpose of Evaluating Compliance with 10CFRPart50, Appendix I

3.1.5 NUREG 0133, Preparation of Radiological Effluent Technical Specifications for Nuclear Power Plants

3.1.6 AP 07B-004 OFFSITE DOSE CALCULATION MANUAL (RADIOLOGICAL ENVIRONMENTAL MONITORING PROGRAM)

3.1.7 PIR 98-0112, Revising the ODCM with an OTSC

3.1.8 Technical Requirements Manual

3.2 Commitments

3.2.1 None

4.0 DEFINITIONS

- 4.1 UNRESTRICTED AREA shall be any area at or beyond the SITE BOUNDARY access to which is not controlled by the licensee for purposes of protection of individuals from exposure to radiation and radioactive materials, or any area within the SITE BOUNDARY used for residential quarters or for industrial, commercial, institutional and/or recreational purposes.
- 4.2 Source Check - A source check shall be the qualitative assessment of channel response when the channel sensor is exposed to a source of increased radioactivity.

5.0 RESPONSIBILITIES

- 5.1 The Manager Chemistry/Radiation Protection is responsible for the ODCM.

6.0 PROCEDURE

6.1 Revision Of The ODCM

NOTE

To comply with Technical Specification 5.5.1, revisions to the ODCM are not permitted via APF 15C-004-04, ON THE SPOT CHANGE form (3.1.7).

- 6.1.1 All revisions to the ODCM are to be submitted through the Manager Chemistry/Radiation Protection via a document revision request (APF 15C-004-01).
- 6.1.2 The Manager Chemistry/Radiation Protection shall ensure the Document Revision Request (APF 15C-004-01) package includes the following:
1. Each change shall be identified by markings in the margins of the affected pages, clearly indicating the area of the page that was changed, and shall indicate the date (e.g., month/year) the change was implemented.
 2. Sufficient information to support the change together with the appropriate analyses or evaluations justifying the change(s) and
 3. A determination that the change will maintain the level of Radioactive Effluent Control required by 10 CFR 20.106 (gaseous effluent), 10CFR 20.1302 (liquid effluent), 40 CFR Part 190, 10 CFR 50.36A, and Appendix I to 10 CFR Part 50 and not adversely impact the accuracy or reliability of effluent dose, or setpoint calculations.
- 6.1.3 The ODCM revision shall become effective after review and acceptance by the PSRC and the approval of the Plant Manager.

6.2 ODCM Submittal To NRC

- 6.2.1 Changes to the ODCM shall be submitted to the Commission in the form of a complete, legible copy of the entire ODCM as a part of or concurrent with the Annual Radioactive Effluent Release Report for the period of the report in which any change to the ODCM was made.

7.0 RECORDS

7.1 The following is a lifetime QA Record:

7.1.1 AP 07B-003, OFFSITE DOSE CALCULATION MANUAL

8.0 FORMS

8.1 None

ATTACHMENT A
(Page 1 of 160)
OFFSITE DOSE CALCULATION MANUAL

Wolf Creek Generating Station



Offsite Dose Calculation Manual

ATTACHMENT A
(Page 2 of 160)
OFFSITE DOSE CALCULATION MANUAL

TABLE OF CONTENTS

		Page
1.0	INTRODUCTION	10
2.0	LIQUID EFFLUENTS	11
	2.1 CONCENTRATION - COMPLIANCE WITH 10 CFR 20	11
	2.2 DOSE - COMPLIANCE WITH 10 CFR 50 APPENDIX I	16
	2.3 PROJECTED DOSE	18
	2.4 INSTRUMENTATION	19
3.0	GASEOUS EFFLUENTS	36
	3.1 DOSE RATE - COMPLIANCE WITH 10 CFR 20	37
	3.2 DOSE - COMPLIANCE WITH 10 CFR 50 APPENDIX I	44
	3.3 PROJECTED DOSE	54
	3.4 INSTRUMENTATION	56
4.0	TOTAL DOSE	70
	4.1 REMEDIAL ACTION	70
	4.2 SURVEILLANCE REQUIREMENTS	71
5.0	RADIOLOGICAL ENVIRONMENTAL MONITORING PROGRAM (Contained in AP 07B-004)	
6.0	BASES	72
7.0	REPORTS	
	7.1 ANNUAL RADIOLOGICAL ENVIRONMENTAL OPERATING REPORT (contained in AP 07B-004)	
	7.2 ANNUAL RADIOACTIVE EFFLUENT RELEASE REPORT	80
APPENDIX A:	DOSE CONVERSION FACTOR TABLES	83
APPENDIX B:	METEOROLOGICAL MODEL	159

ATTACHMENT A
(Page 3 of 160)
OFFSITE DOSE CALCULATION MANUAL

LIST OF TABLES

<u>Table</u>		<u>Page</u>
2-1	RADIOACTIVE LIQUID WASTE SAMPLING AND ANALYSIS PROGRAM	12
2-2	RADIOACTIVE LIQUID EFFLUENT MONITORING INSTRUMENTATION	21
2-3	RADIOACTIVE LIQUID EFFLUENT MONITORING INSTRUMENTATION SURVEILLANCE REQUIREMENTS	24
3-1	RADIOACTIVE GASEOUS WASTE SAMPLING AND ANALYSIS PROGRAM	40
3-2	RADIOACTIVE GASEOUS EFFLUENT MONITORING INSTRUMENTATION	57
3-3	RADIOACTIVE GASEOUS EFFLUENT MONITORING INSTRUMENTATION SURVEILLANCE REQUIREMENTS	59
A.1-1	BIOACCUMULATION FACTORS TO BE USED IN THE ABSENCE OF SITE SPECIFIC DATA	84
A.1-2	DOSE FACTORS FOR NOBLE GASES AND DAUGHTERS	85
A.2-1	INHALATION DOSE FACTORS FOR ADULTS	86
A.2-2	INHALATION DOSE FACTORS FOR TEENAGERS	88
A.2-3	INHALATION DOSE FACTORS FOR CHILD	90
A.2-4	INHALATION DOSE FACTORS FOR INFANT	92
A.2-5	EXTERNAL DOSE FACTOR FOR STANDING ON CONTAMINATED GROUND	94
A.3-1	INGESTION DOSE FACTOR FOR ADULTS	96
A.3-2	INGESTION DOSE FACTOR FOR TEENAGERS	99
A.3-3	INGESTION DOSE FACTOR FOR CHILD	102
A.3-4	INGESTION DOSE FACTOR FOR INFANT	105
A.3-5	STABLE ELEMENT TRANSFER DATA	108
A.4-1	SITE RELATED INGESTION DOSE COMMITMENT FOR ADULT	109
A.4-2	SITE RELATED INGESTION DOSE COMMITMENT FACTOR FOR TEENAGER	112
A.4-3	SITE RELATED INGESTION DOSE COMMITMENT FACTOR FOR CHILD	115
A.4-4	SITE RELATED INGESTION DOSE COMMITMENT FACTOR FOR INFANT	118

ATTACHMENT A
(Page 4 of 160)
OFFSITE DOSE CALCULATION MANUAL

LIST OF TABLES

<u>Table</u>		<u>Page</u>
A.5-1	INHALATION DOSE PARAMETER FOR THE CHILD	121
A.5-2	INHALATION PATHWAY FACTOR FOR ADULT (RI FACTOR)	122
A.5-3	INHALATION PATHWAY FACTOR FOR TEENAGER (RI FACTOR)	124
A.5-4	INHALATION PATHWAY FACTOR FOR CHILD (RI FACTOR)	126
A.5-5	INHALATION PATHWAY FACTOR FOR INFANT (RI FACTOR)	128
A.5-6	GRASS-COW-MILK PATHWAY FACTOR ADULT (RI FACTOR) OF SITE SPECIFIC DATA	130
A.5-7	GRASS-COW-MILK PATHWAY FACTOR TEEN (RI FACTOR)	132
A.5-8	GRASS-COW-MILK PATHWAY FACTOR CHILD (RI FACTOR)	134
A.5-9	GRASS-COW-MILK PATHWAY FACTOR INFANT (RI FACTOR)	136
A.5-10	GRASS-COW-MEAT PATHWAY FACTOR ADULT (RI FACTOR)	138
A.5-11	GRASS-COW-MEAT PATHWAY FACTOR TEEN (RI FACTOR)	140
A.5-12	GRASS-COW-MEAT PATHWAY FACTOR INFANT (RI FACTOR)	142
A.5-13	VEGETATION PATHWAY FACTOR ADULT (RI FACTOR)	144
A.5-14	VEGETATION PATHWAY FACTOR TEEN (RI FACTOR)	146
A.5-15	VEGETATION PATHWAY FACTOR CHILD (RI FACTOR)	148
A.5-16	GROUND PLANE PATHWAY FACTOR (RI FACTOR)	150
A.5-17	GRASS-GOAT-MILK PATHWAY FACTOR ADULT (RI FACTOR)	151
A.5-18	GRASS-GOAT-MILK PATHWAY FACTOR TEEN (RI FACTOR)	153
A.5-19	GRASS-GOAT-MILK PATHWAY FACTOR CHILD (RI FACTOR)	155
A.5-20	GRASS-GOAT-MILK PATHWAY FACTOR INFANT (RI FACTOR)	157

LIST OF FIGURES

<u>Figure</u>		<u>Page</u>
B-1	VERTICAL STANDARD DEVIATION OF MATERIAL IN A PLUME	163
B-2	PLUME TRAVEL DISTANCE VERSUS FRACTION REMAINING IN PLUME	164
B-3	PLUME TRAVEL DISTANCE VERSUS RELATIVE DEPOSITION RATE	165

ATTACHMENT A
(Page 5 of 160)
OFFSITE DOSE CALCULATION MANUAL

1.0 Introduction

The Offsite Dose Calculation Manual describes the Radioactive Effluent Controls Program. The implementation of this program ensures compliance with the requirements of 10 CFR 50.36, 10 CFR 20.106, 10 CFR 20.1302, 10 CFR 50 Appendix I and 40 CFR 190.

On January 1, 1994, 10CFR20.20.1001-20.2402 was implemented. Wolf Creek continues to maintain the existing level of gaseous effluent control, 10 CFR 20.106. Compliance with 10 CFR 20.106 has been determined by the NRC to be ALARA.

On December 18, 1999 Wolf Creek implemented 10 CFR 20.1302 limits for radioactive liquid effluents. The concentration of radioactive material released in liquid effluents to unrestricted area conforms to 10 times the concentration values in Appendix B, Table 2, Column 2, to 10 CFR 20.1001-20.2402.

The ODCM describes the methodology and parameters used in the calculation of offsite doses due to radioactive liquid and gaseous effluents. The ODCM contents for calculation of dose are based on "Preparation of Radiological Effluent Technical Specifications for Nuclear Power Plants (NUREG-0133)," and Regulatory Guide 1.109, Revision 1.

Dose calculations are performed for the limiting age group i.e., Adult age group for the liquid pathway, and the Child age group for gaseous effluent organ doses.

The ODCM provides the limitations on the operability of radioactive liquid and gaseous monitoring instrumentation including surveillance tests and setpoint determination. Each Surveillance Requirement shall be performed within the specified surveillance interval with a maximum allowable extension not to exceed 25% of the specified interval.

The ODCM provides descriptions of the information that should be included in the Annual Radioactive Effluent Release Reports.

ATTACHMENT A
(Page 6 of 160)

OFFSITE DOSE CALCULATION MANUAL

2.0 Liquid Effluents**2.1 Concentration - Compliance With 10 CFR 20**

The concentration of radioactive material released in liquid effluents to UNRESTRICTED AREAS shall be limited to the concentration specified in 10 CFR Part 20, Appendix B, Table II, Column 2, for radionuclides other than dissolved or entrained noble gases. For dissolved or entrained noble gases, the concentration shall be limited to 2×10^{-4} microCurie/mL total activity. (USAR Chapter 11) 6/01

2.1.1 Remedial Action

With the concentration of radioactive material released in liquid effluents to UNRESTRICTED AREAS exceeding the above limits, immediately restore the concentration to within the above limits.

2.1.2 Surveillance Requirements

To show compliance with this requirement, concentrations of actual liquid effluents will be determined by performing Isotopic Analyses. Radioactive liquid wastes shall be sampled and analyzed according to the sampling and analysis program of Table 2-1.

ATTACHMENT A
(Page 7 of 160)
OFFSITE DOSE CALCULATION MANUAL

TABLE 2-1
RADIOACTIVE LIQUID WASTE SAMPLING AND ANALYSIS PROGRAM

LIQUID RELEASE TYPE	SAMPLE FREQUENCY	PRINCIPAL GAMMA EMITTERS	I-131	DISSOLVED/ ENTRAINED GASES (GAMMA)	GROSS ALPHA AND H-3	Sr-89, Sr-90	Fe-55
1. Batch Tanks (2)							
a. THB07A&B LLD (1)	P	P(3) 5E-7	P 1E-6	M 1E-5	M Composite(4) 1E-7 for Alpha 1E-5 for H-3	Q Composite(4) 5E-8	Q Composite(4) 1E-6
b. THF04A&B LLD (1)	P	P(3) 5E-7	P 1E-6	M 1E-5	M Composite(4) 1E-7 for Alpha 1E-5 for H-3	Q Composite(4) 5E-8	Q Composite(4) 1E-6
2. Continuous Releases (5)							
a. Steam Generator Blowdown LLD(1)	Daily (6)	W(3) Composite(4) 5E-7	W Composite(4) 1E-6	M 1E-5	M Composite(4) 1E-7 for Alpha 1E-5 for H-3	Q Composite(4) 5E-8	Q Composite(4) 1E-6
b. Turbine Building Sump LLD(1)	Daily (6)	W(3) Composite(4) 5E-7	W Composite(4) 1E-6	M 1E-5	M Composite(4) 1E-7 for Alpha 1E-5 for H-3	Q Composite(4) 5E-8	Q Composite(4) 1E-6
c. Waste Water Treatment LLD(1)	Daily (6)	W(3) Composite(4) 5E-7	W Composite(4) 1E-6	M 1E-5	M Composite(4) 1E-7 for Alpha 1E-5 for H-3	Q Composite(4) 5E-8	Q Composite(4) 1E-6
d. Lime Sludge Pond LLD (1)	Daily (6)	W(3) Composite(4) 5E-7	W Composite(4) 1E-6	M 1E-5	M Composite(4) 1E-7 for Alpha 1E-5 for H-3	Q Composite(4) 5E-8	Q Composite(4) 1E-6

LLD = ($\mu\text{Ci/mL}$)

ATTACHMENT A
(Page 8 of 160)
OFFSITE DOSE CALCULATION MANUAL

TABLE 2-1 (Continued)

TABLE NOTATIONS

- (1) The LLD is defined, as the smallest concentration of radioactive material in a sample that will yield a net count, above system background, that will be detected with 95% probability with only 5% probability of falsely concluding that a blank observation represents a "real" signal.

For a particular measurement system, which may include radiochemical separation:

$$LLD = \frac{4.66 s_b}{E \times V \times 2.22 \times 10^6 \times Y \times \text{Decay}}$$

Where:

LLD = the "a priori" lower limit of detection (microCuries per unit mass or volume),

s_b = the standard deviation of the background counting rate or of the counting rate of a blank sample as appropriate, (counts per minute), $s_b = \sqrt{B} / LT$

Where: B = background sum (counts)

LT = live time (minutes),

E = the counting efficiency (counts per disintegration),

V = the sample size (units of mass or volume),

2.22×10^6 = the number of disintegrations per minute per microCurie,

Y = the fractional radiochemical yield, when applicable,

Decay = decay factor(s), There are three decay factors that may be appropriate for use depending on the nature of the sample and the half life of the nuclide. Any combination of the three may be used. The factors are as follows:

- A) This decay factor corrects for decay from the time of sampling to the start of the analysis.

$e^{-\lambda \Delta t_s}$, where:

Δt_s = decay time = acquisition start time - sample time

ATTACHMENT A
(Page 9 of 160)
OFFSITE DOSE CALCULATION MANUAL

TABLE 2-1 (Continued)
TABLE NOTATIONS

$$\lambda = \ln 2 / \text{half-life}$$

- B) This decay factor corrects for decay during the analysis.

$$\frac{1 - e^{-\lambda RT}}{\lambda \times RT}$$

$$\lambda = \ln 2 / \text{half-life}$$

RT = real time of counting

- C) This decay factor corrects for decay during sampling.

$$\frac{1 - e^{-\lambda \Delta t_d}}{\lambda \Delta t_d}$$

$$\lambda = \ln 2 / \text{half-life}$$

t_d = deposition time = sample time - deposition start time

NOTE

All times used in decay calculations should be in the same units.

Typical values of E, V, Y, t_g, t_d should be used in the calculation.

It should be recognized that the LLD is defined as an a priori (before the fact) limit representing the capability of a measurement system and not as an a posteriori (after the fact) limit for a particular measurement.

- (2) A batch release is the discharge of liquid wastes of a discrete volume. Prior to sampling for analyses, each batch shall be isolated, and then thoroughly mixed by a method described in plant procedures to assure representative sampling.

ATTACHMENT A
(Page 10 of 160)
OFFSITE DOSE CALCULATION MANUAL

TABLE 2-1 (Continued)
TABLE NOTATIONS

- (3) The principal gamma emitters for which the LLD specification applies include the following radionuclides: Mn-54, Fe-59, Co-58, Co-60, Zn-65, Mo-99, Cs-134, Cs-137, Ce-141 and Ce-144. This list does not mean that only these nuclides are to be considered. Other gamma peaks that are identifiable, together with those of the above nuclides, shall also be analyzed and reported in the annual Radioactive Effluent Release Report in the format outlined in Regulatory Guide 1.21, Appendix B, Revision 1, June 1974.
- (4) A composite sample is one in which the quantity of liquid sampled is proportional to the quantity of liquid waste discharged and in which the method of sampling employed results in a specimen that is representative of the liquids released. Prior to analysis, all samples taken for the composite shall be thoroughly mixed in order for the composite samples to be representative of the effluent release.
- (5) A continuous release is the discharge of liquid wastes of a nondiscrete volume, e.g., from a volume of a system that has an input flow during the continuous release.
- (6) Samples shall be taken at the initiation of effluent flow and at least once per 24 hours thereafter while the release is occurring. To be representative of the liquid effluent, the sample volume shall be proportioned to the effluent stream discharge volume. The ratio of sample volume to effluent discharge volume shall be maintained constant for all samples taken for the composite sample.

FREQUENCY NOTATION

<u>NOTATION</u>	<u>FREQUENCY</u>
S	At least once per 12 hours.
D	At least once per 24 hours.
W	At least once per 7 days
M	At least once per 31 days.
Q	At least once per 92 days.
SA	At least once per 184 days.
R	At least once per 18 months.
S/U	Prior to each reactor startup.
N.A.	Not applicable.
P	Completed prior to each release.

ATTACHMENT A
(Page 11 of 160)
OFFSITE DOSE CALCULATION MANUAL

2.2 Dose - Compliance With 10 CFR 50 Appendix I

The dose or dose commitment to a MEMBER OF THE PUBLIC from radioactive materials in liquid effluents released, from each unit, to UNRESTRICTED AREAS shall be limited: 1/01

- a. During any calendar quarter to less than or equal to 1.5 mrems to the whole body and to less than or equal to 5 mrems to any organ, and
- b. During any calendar year to less than or equal to 3 mrems to the whole body and to less than or equal to 10 mrems to any organ.

2.2.1 Remedial Action

With the calculated dose from the release of radioactive materials in liquid effluents exceeding any of the above limits, prepare and submit to the Commission within 30 days, a Special Report that identifies the cause(s) for exceeding the limit(s) and defines the corrective actions that have been taken to reduce the releases and the proposed corrective actions to be taken to assure that subsequent releases will be in compliance with the above limits. This Special Report shall also include the results of radiological analyses of the drinking water source, and the radiological impact on finished drinking water supplies with regard to the requirements of 40 CFR Part 141, Clean Drinking Water Act. This requirement of (1.) and (2.) are applicable only if drinking water supply is taken from the receiving body within 3 miles of the plant discharge.

2.2.2 Surveillance Requirements

Cumulative dose contributions from liquid effluents for the current calendar quarter and the current calendar year shall be determined using the following methodology at least once per 31 days.

$$D_T = \sum_i \left(A_{i\pi} \sum_{L=1}^m \Delta t_L C_{iL} F_L \right)$$

ATTACHMENT A
(Page 12 of 160)
OFFSITE DOSE CALCULATION MANUAL

Where,

D_T = the cumulative dose commitment to the total body or any organ, T, from the liquid effluent for the total

$$\text{time period } \sum_{L=1}^m \Delta t_L, \text{ in mrem}$$

Δt_L = the length of the Lth time period over which C_{iL} and F_L are averaged for all liquid releases, in hours.

C_{iL} = the average concentration of radionuclide, 'i', in undiluted liquid effluent flow during time period Δt_L , in $\mu\text{Ci/mL}$.

F_L = the near field average dilution factor for C_{iL} during any liquid effluent release where:

$$F_L = \frac{f}{(F)K}$$

Where:

f = Liquid Radioactive Waste Flow

F = Discharge Structure Exit Flow, the sum of the release and dilution flow.

K = Applicable factor; the site dependent value for the mixing effect of the discharge structure. This value is conservatively assumed to be 1 (one) for this section.

A_{iT} = The site related ingestion dose commitment factor to the total body or any organ, 'T', for each identified principal gamma and beta emitter, mrem/hr per $\mu\text{Ci/mL}$. See Tables A.4-1 through A.4-4.

The limiting age group for liquid dose calculations is the Adult age group.

$$A_{iT} = 1.14E5 (U_w / D_w + U_f \times BF_i) DF_i$$

ATTACHMENT A
(Page 13 of 160)
OFFSITE DOSE CALCULATION MANUAL

Where,

DW = Dilution factor from the near field area to the potable water intake for water consumption, for Wolf Creek Generating Station this factor is 1 (one).

BF_i = Bioaccumulation factor for radionuclide 'i', in fish, pCi/Kg per pCi/l, from Table A.1-1 from Regulatory Guide 1.109 (Rev. 1).

DF_i = Adult dose Conversion factor for radionuclide, 'i', in mrem/pCi, from Table A.3-1 through A.3-4, from Regulatory Guide 1.109 (Rev. 1).

U_w = Adult water consumption, (730 l/yr. from Reg. Guide 1.109)

U_F = Adult fish consumption, (21 kg/yr. from Reg. Guide 1.109)

$$1.14E5 = \text{Units conversion factor} = \frac{10^6 \text{ pCi} / \mu\text{Ci} \times 10^3 \text{ ml} / \text{Kg}}{8760 \text{ hr} / \text{yr}}$$

The dose calculations are based on the actual isotopic analysis of the radioactive liquid effluents, the radioactive liquid effluent flow, and the dilution flow.

2.3 Projected Dose

The Liquid Radwaste Treatment System shall be OPERABLE and appropriate portions of the system shall be used to reduce releases of radioactivity when the projected doses due the liquid effluent, from each unit, to UNRESTRICTED AREAS would exceed 0.06 mrem to the whole body or 0.2 mrem to any organ in a 31 day period.

1/01

2.3.1 Remedial Action

With radioactive liquid waste being discharged without treatment and in excess of the above limits and any portion of the Liquid Radwaste Treatment System not in operation, prepare and submit to the Commission within 30 days, a Special Report that includes the following information:

Revision: 4	OFFSITE DOSE CALCULATION MANUAL	AP 07B-003
Reference Use		Page 19 of 165

ATTACHMENT A
(Page 14 of 160)
OFFSITE DOSE CALCULATION MANUAL

- a. Explanation of why liquid radwaste was being discharged without treatment, identification of any inoperable equipment or subsystems, and the reason for the inoperability,
- b. Action(s) taken to restore the inoperable equipment to OPERABLE status, and
- c. Summary description of action(s) taken to prevent a recurrence.

2.3.2 Surveillance Requirements

- 2.3.2.1 Doses due to liquid releases from each unit to UNRESTRICTED AREAS shall be projected at least once per 31 days in accordance with the following methodology when Liquid Radwaste Treatment Systems are not being fully utilized.

$$D_{31} = \left[\frac{A}{T} \right] \times 31$$

Where,

D_{31} = Projected 31 day dose

A = Cumulative dose for previous three months

T = Number of days that the cumulative dose occurred in A above

- 2.3.2.2 The installed Liquid Radwaste Treatment System shall be considered OPERABLE by meeting the requirements of Sections 2.1 and 2.2.

2.4 Instrumentation

The radioactive liquid effluent monitoring instrumentation channels shown in Table 2-2 shall be OPERABLE with their Alarm/Trip Setpoints set to ensure that the limits of Section 2.1 are not exceeded. The Alarm/Trip Setpoints of these channels shall be determined and adjusted in accordance with the methodology and parameters described in Section 2.4.4.

ATTACHMENT A
(Page 15 of 160)
OFFSITE DOSE CALCULATION MANUAL

2.4.1 Remedial Action

- 2.4.1.1 With a radioactive liquid effluent monitoring instrumentation channel Alarm/Trip Setpoint less conservative than required by the above, immediately suspend the release of radioactive liquid effluents monitored by the affected channel, or declare the channel inoperable.
- 2.4.1.2 With less than the minimum number of radioactive liquid effluent monitoring instrumentation channels OPERABLE, take the ACTION shown in Table 2-2. Restore the inoperable instrumentation to OPERABLE status within the time specified in the ACTION, or explain in the next annual Radioactive Effluent Release Report, why this inoperability was not corrected within the time specified.

2.4.2 Surveillance Requirements

Each radioactive liquid effluent monitoring instrumentation channel shall be demonstrated OPERABLE by performance of the CHANNEL CHECK, SOURCE CHECK, CHANNEL CALIBRATION and CHANNEL OPERATIONAL TEST at the frequencies shown in Table 2-3.

ATTACHMENT A
(Page 16 of 160)
OFFSITE DOSE CALCULATION MANUAL

TABLE 2-2
RADIOACTIVE LIQUID EFFLUENT MONITORING INSTRUMENTATION

<u>INSTRUMENT</u>	<u>MINIMUM CHANNELS OPERABLE</u>	<u>ACTION</u>
1. Radioactivity Monitors Providing Alarm and Automatic Termination of Release		
a. Liquid Radwaste Discharge Monitor (HB-RE-18)	1	31
b. Steam Generator Blowdown Discharge Monitor (BM-RE-52)	1	32
c. Turbine Building Drain Monitor (LE-RE-59)	1	32
d. Secondary Liquid Waste System Monitor (HF-RE-45)	1	31
e. Wastewater Treatment System Influent Monitor (HF-RE-95)	1	6/01 32
2. Flow Rate Measurement Devices		
a. Liquid Radwaste Discharge Line		
1) Waste Monitor Tank A Discharge Line	1	33
2) Waste Monitor Tank B Discharge Line	1	33
b. Steam Generator Blowdown Discharge Line	1	33
c. Secondary Liquid Waste System Discharge Line	1	33 6/01

ATTACHMENT A
(Page 17 of 160)
OFFSITE DOSE CALCULATION MANUAL

TABLE 2-2 (Continued)
ACTION STATEMENTS

Action 31 - With the number of channels OPERABLE less than required by the Minimum Channels OPERABLE requirement, effluent releases via this pathway may continue for up to 14 days provided that prior to initiating a release:

- a. At least two independent samples are analyzed in accordance with Section 2.1.2, and
- b. At least two technically qualified members of the facility staff independently verify the release rate calculations and discharge line valving.

Otherwise, suspend release of radioactive effluents via this pathway.

Action 32 - With the number of channels OPERABLE less than required by the Minimum Channels OPERABLE requirement, effluent releases via this pathway may continue for up to 30 days provided grab samples are analyzed for principle gamma emitters and I-131 at a lower limit of detection as specified in Table 2-1.

- a. At least once per 12 hours when the specific activity of the secondary coolant is greater than 0.01 microCurie/gram DOSE EQUIVALENT I-131, or
- b. At least once per 24 hours when the specific activity of the secondary coolant is less than or equal to 0.01 microCurie/gram DOSE EQUIVALENT I-131.

ATTACHMENT A
(Page 18 of 160)
OFFSITE DOSE CALCULATION MANUAL

TABLE 2-2 (Continued)
ACTION STATEMENTS

Action 33 - With the number of channels OPERABLE less than required by the Minimum Channels OPERABLE requirement, effluent releases via this pathway may continue for up to 30 days provided the flow rate is estimated at least once per 4 hours during actual releases. Pump performance curves generated in place may be used to estimate flow.

ATTACHMENT A
(Page 19 of 160)
OFFSITE DOSE CALCULATION MANUAL

TABLE 2-3
RADIOACTIVE LIQUID EFFLUENT MONITORING INSTRUMENTATION
SURVEILLANCE REQUIREMENTS

<u>INSTRUMENT</u>	<u>CHANNEL CHECK</u>	<u>SOURCE CHECK</u>	<u>CHANNEL CALIBRATION</u>	<u>CHANNEL OPERATIONAL TEST</u>
1. Radioactivity Monitors providing alarm and automatic termination of release				
a. Liquid Radwaste Discharge Monitor (HB-RE-18)	D	P	R(2)	Q(1)
b. Steam Generator Blowdown Discharge Monitor (BM-RE-52)	D	M	R(2)	Q(1)
c. Turbine Building Drain Monitor (LE-RE-59)	D	M	R(2)	Q(1)
d. Secondary Liquid Waste System Monitor (HF-RE-45)	D	P	R(2)	Q(1)
e. Wastewater Treatment System Influent Monitor (HF-RE-95)	D	M	R(2)	Q(1)
2. Flow Rate Measurement Devices				
a. Liquid Radwaste Discharge Line	D(3)	N.A.	R	N.A.
b. Steam Generator Blowdown Discharge Line	D(3)	N.A.	R	N.A.
c. Secondary Liquid Waste System Discharge Line	D(3)	N.A.	R	N.A.

ATTACHMENT A
(Page 20 of 160)
OFFSITE DOSE CALCULATION MANUAL

TABLE 2-3 (Continued)

TABLE NOTATIONS

- (1) The CHANNEL OPERATIONAL TEST shall also demonstrate that automatic isolation of this pathway and control room alarm annunciation occur as appropriate if any of the following conditions exists:
 - a. Instrument indicates measured levels above the Alarm/Trip Setpoint (isolation and alarm), or
 - b. Circuit failure (alarm only), or
 - c. Instrument indicates a downscale failure (alarm only), or
 - d. Instrument controls not set in operate mode (alarm only).
- (2) The initial CHANNEL CALIBRATION shall be performed using one or more of the reference (gas or liquid and solid) standards certified by the National Institute of Standards and Technology (NIST) or using standards that have been obtained from suppliers that participate in measurement assurance activities with NIST. These standards shall permit calibrating the system over its intended range or energy, measurement range, and establish monitor response to a solid calibration source. For subsequent CHANNEL CALIBRATION, NIST traceable standard (gas, liquid, or solid) may be used; or a gas, liquid, or solid source that has been calibrated by relating it to equipment that was previously (within 30 days) calibrated by the same geometry and type of source standard traceable to NIST.
- (3) CHANNEL CHECK shall consist of verifying indication of flow during periods of release. CHANNEL CHECK shall be made at least once per 24 hours on days on which continuous, periodic, or batch releases are made.

ATTACHMENT A
(Page 21 of 160)
OFFSITE DOSE CALCULATION MANUAL

2.4.3 Liquid Monitor Calibration Methodology

The five monitors associated with liquid releases are listed below:

<u>Monitor ID</u>	<u>Description</u>
0-BM-RE-52	Steam Generator Blowdown Discharge Monitor
0-LE-RE-59	Turbine Building Drain Monitor
0-HF-RE-45	Secondary Liquid Waste System Monitor
0-HB-RE-18	Liquid Radwaste Discharge Monitor
0-HF-RE-95	Wastewater Treatment System Influent Monitor

Liquid effluent streams are monitored by an NaI(Tl) Detector. The detector operates in a gross counting mode and is gamma sensitive.

Calibration of the liquid monitors shall be performed using three standard solutions of Cs-137. The solutions shall cover the appropriate range of the detector and have concentrations of approximately 5×10^{-7} $\mu\text{Ci/cc}$, 1×10^{-5} $\mu\text{Ci/cc}$, and 1×10^{-3} $\mu\text{Ci/cc}$. The solutions shall be presented to the detector and the meter reading in counts per minute shall be recorded. A determination of linearity shall be produced using the counts per minute vs. concentration data.

2.4.4 Liquid Effluent Monitor Setpoints

The Alarm/Trip Setpoints for the Liquid Effluent Radiation Monitors are based on instantaneous concentration limits of 10 CFR 20, Appendix B, Table 2, Column 2 applied at the boundary of the restricted area. Specifically, the High Alarm Setpoint will correspond to the 10 CFR Part 20 limits at the Boundary of the restricted area; the Alert Alarm Setpoint is set to 80% of the High Alarm/Trip Setpoint. Since the high alarm/trip initiates isolation of the particular system and termination of the release, this setpoint represents assurance that the instantaneous liquid release limit of 10 CFR Part 20 is not exceeded. Auditable records shall be maintained indicating the actual setpoints used at all times.

ATTACHMENT A
(Page 22 of 160)
OFFSITE DOSE CALCULATION MANUAL

The calculated Alarm and Trip Action Setpoints for the Liquid Effluent Line Monitors must satisfy the following equation:

$$\frac{cf}{F+f} \leq C$$

Where:

C = The liquid effluent concentration limit (ECL) implementing Section 2.1 in $\mu\text{Ci/mL}$.

c = The Setpoint, in $\mu\text{Ci/mL}$, of the Radioactivity Monitor measuring the radioactivity concentration in the effluent line prior to dilution and subsequent release; the Setpoint, which is inversely proportional to the Volumetric Flow of the effluent line and directly proportional to the Volumetric Flow of the dilution stream plus the effluent stream, represents a Value, which if exceeded would result in concentrations exceeding the limits of 10 CFR 20 in the restricted area.

f = The Pump Flow Rate as measured at the Radiation Monitor Location, in Volume per Unit Time, but in the same units as F, below.

F = The Dilution Water Flow Rate as measured prior to the release point, in Volume per Unit Time.

Thus, the expression for determining the setpoint on the Liquid Radwaste Effluent Line Monitor becomes:

$$c \leq \frac{C(F+f)}{f} (\mu\text{Ci/ml})$$

If no gamma activity is detected calculate the monitor setpoint by assigning the available ECL fraction to I-131.

2.4.4.1 Continuous Liquid Effluent Monitors

The three monitors associated with continuous liquid releases are listed below:

<u>Monitor ID</u>	<u>Description</u>
0-BM-RE-52	Stm Generator Blowdown Discharge Monitor
0-LE-RE-59	Turbine Building Drain Monitor
0-HF-RE-95	Waste Water Treatment System Influent Monitor

ATTACHMENT A
(Page 23 of 160)
OFFSITE DOSE CALCULATION MANUAL

The Steam Generator Blowdown Discharge Effluent Monitor continuously monitors the Blowdown Discharge Pump Outlet to detect excess radioactivity due to System Demineralizer breakthrough or abnormal Primary to Secondary leakage. The Blowdown Discharge Monitor's High Alarm Setpoint initiates CLOSURE of the Blowdown Isolation Valves and the Blowdown Discharge Valve. Similarly, the High Radiation Alarm on the Turbine Building Drain Monitor and Waste Water Treatment Monitor initiates CLOSURE of the Drain Line Isolation Valves to prevent the release of radioactive effluents.

Monitor setpoints will be conservatively based on I-131, the most restrictive isotope expected to be present. This is particularly appropriate for the Turbine Building Drain Line Monitor since the most probable source is the Secondary Steam System which is expected to have negligible activity unless there is a significant Primary to Secondary leak. Due to changing activities, it will not be possible to select a radionuclide distribution on which to base the monitor setpoint. Additionally, maximum effluent flows and minimum dilution flows will normally be assumed.

The High Alarm/Trip Setpoint will be set to correspond to the I-131 ECL limit at the boundary of the restricted area from 10 CFR Part 20, Appendix B, Table 2, Column 2. The alert alarm is set one order of magnitude below the High Alarm/Trip Setpoint for release points that have dilution and to the High Alarm value for those without dilution. This High Alarm/Trip Setpoint assures the limits of Section 2.1 are not exceeded at the boundary of the restricted area.

In the event that an alarm is TRIPPED, an evaluation of the system will be made by taking an actual isotopic and flow analysis of the discharge.

Revision: 4	OFFSITE DOSE CALCULATION MANUAL	AP 07B-003
Reference Use		Page 29 of 165

ATTACHMENT A
(Page 24 of 160)
OFFSITE DOSE CALCULATION MANUAL

The above continuous liquid effluents are not radioactive effluents until activity has been detected by the Liquid Effluent Monitor, a Tritium analysis of the Secondary system, or a gross Beta analysis of the Secondary system. At that time an analysis of the effluent will be made to verify activity in the system effluent. During periods of time when the above liquid effluents are not radioactive the High Alarm/Trip Setpoint may be set to 1.5 times the background count rate.

2.4.4.1.1 Steam Generator Blowdown Discharge Monitor

$$\text{SETPOINT } (\mu\text{Ci/ml}) = \text{ECL}_{\text{I-131}} \times \frac{F_m + F_B}{F_B}$$

where,

$\text{ECL}_{\text{I-131}}$ = Effluent Concentration Limit of I-131, 1E-5
(10 times concentration limit of I-131)

F_m = Dilution flow rate.

F_B = Blowdown flow rate.

The setpoint calculation is based on the minimum dilution flow rate, the maximum possible blowdown flow rate, and, due to changing conditions, I-131 which is the most restrictive isotope expected to be present.

On the event that an alarm is reached, the setpoint will be reevaluated using the actual dilution flow rate, the actual blowdown flow rate, and the actual isotopic analysis as outlined in Section 2.4.4.2. This evaluation will be used to ensure the limit of Section 2.1 was not exceeded. The setpoint will still be based on 10 times the concentration limit of I-131 due to the changing conditions of activity and I-131 being the most restrictive isotope.

ATTACHMENT A
(Page 25 of 160)
OFFSITE DOSE CALCULATION MANUAL

2.4.4.1.2 Turbine Building Drain Monitor And Waste Water Treatment System Influent Monitor

$$\text{SETPOINT } (\mu\text{Ci/ml}) = \text{ECL}_{\text{I-131}} \times \frac{F_m + F_T}{F_T}$$

$\text{ECL}_{\text{I-131}} = 1\text{E-5}$ (10 times concentration limit of I-131)

F_m = Dilution flow rate

F_t = Effluent flow rate

The setpoint is based on the minimum dilution flow rate, the maximum possible effluent flow rate, and the most restrictive isotope expected to be present, I-131.

On the event that an alarm is reached, the release will be evaluated to see if the limit of Section 2.1 was exceeded by using the actual Dilution Flow Rate, the actual Effluent Flow Rate, and the actual isotopic analysis as outlined in Section 2.4.4.2. The setpoint will still be based on the 10 times the ECL of I-131 due to the changing conditions of activity and I-131 being the most restrictive isotope.

2.4.4.2 Batch Radioactive Liquid Effluent Monitor

The two monitors associated with liquid batch releases are listed below:

<u>Monitor ID</u>	<u>Description</u>
0-HF-RE-45	Secondary Liquid Waste System Monitor
0-HB-RE-18	Liquid Radwaste Discharge Monitor

The setpoint is a function of dilution flow rate, tank flow rate, and isotopic composition. A laboratory isotopic analysis is made of each batch prior to discharge. Based on the isotopic analysis and existing flow condition, the setpoint will be calculated and set on the appropriate monitor to ensure the concentration limits of 10 CFR 20, Appendix B, Table 2, Column 2 is not exceeded.

ATTACHMENT A
(Page 26 of 160)
OFFSITE DOSE CALCULATION MANUAL

The setpoints are determined using the following methodology:

- 1) Determine concentrations of radioactivity of the batch being considered for release.

The isotopic concentration of the batch is the sum of the concentrations for the isotopes present as determined from the analysis required in Table 2-1.

$$\sum_i C_i = \sum_g C_g + C_a + C_s + C_t + C_f$$

Where:

C_i = The concentration of nuclide i as determined by the analysis of the waste sample.

C_g = The sum of the concentrations C_g of each measured gamma emitting nuclide observed by gamma-ray spectroscopy of the waste sample.

* C_a = The measured concentration C_a of alpha emitting nuclides observed by gross alpha analysis of the monthly composite sample.

* C_s = The measured concentrations of Sr-89 and Sr-90 in liquid waste as determined by analysis of the quarterly composite sample.

* C_t = The measured concentration of H-3 in liquid waste.

* C_f = The measured concentration of Fe-55 in liquid waste as determined by analysis of the quarterly composite.

*Values for these concentrations will be based on previous composite sample analysis as required by Table 2-1.

ATTACHMENT A
(Page 27 of 160)
OFFSITE DOSE CALCULATION MANUAL

- 2) The measured radionuclide concentrations are used to calculate a dilution factor, F_d , which is the ratio of total dilution flow rate to tank flow rate required to assure that the limiting concentrations of Section 2.1 are met at the point of discharge. This is referred to as the required dilution factor and is determined according to:

$$F_d = \left(\sum_i \frac{C_i}{ECL_i} \right) \times F_s$$

Where:

C_i = Measured concentrations of C_g , C_a , C_s , C_t and C_f , as defined in Step 1. Terms C_a , C_s , C_t and C_f , will be included in the calculation as appropriate.

ECL_i = ECL_g , ECL_a , ECL_s , ECL_t and ECL_f , are limiting concentrations of the appropriate radionuclide from 10 CFR 20, Appendix B, Table 2, Column 2. For dissolved or entrained noble gases, the concentration shall be limited to 2.0E-04, $\mu\text{Ci/mL}$ total activity.

F_s = The safety factor; a conservative factor used to compensate for statistical fluctuations and errors of measurement default value is 0.5.

- 3) For the case $F_d < 1$, the waste tank effluent concentration meets the limits of 10 CFR 20 without dilution and the effluent may be released at any desired flow rate. For the case $F_d > 1$, a modified dilution factor, F_{dn} , must be determined so that available dilution flow may be apportioned among simultaneous discharge pathways.

$$F_m = F_d / F_a$$

Where F_a is the allocation factor which will modify the required dilution factor so that simultaneous liquid releases may be made without exceeding 10 CFR 20 limits.

ATTACHMENT A
(Page 28 of 160)
OFFSITE DOSE CALCULATION MANUAL

The most straight-forward determination of allocation factor is:

$$F_a = 1/n$$

Where:

n = The number of liquid discharge pathways for which $F_d > 1$ and which is planned for simultaneous release.

However, this value for F_a may be unnecessarily restrictive in that all release pathways are apportioned the same fraction of the available dilution stream, regardless of the relative concentrations of each of the sources.

Since the radionuclide concentration of the two continuous sources is expected to be less than that of the batch release source, it is acceptable to allocate smaller portions of the dilution stream to the continuous releases and a larger portion to the batch releases.

Therefore, F_a is defined as a flexible quantity with a default value of $1/n$. Prior to initiating simultaneous release, a check will be made to assure that the sum of the allocation factors assigned to pathways for the simultaneous release is < 1 .

- 4) The calculated maximum permissible waste tank effluent flow rate, F_{max} , is based on the modified dilution factor, F_{dn} , and the effective dilution flow rate, F_{eff} .

The cooling lake into which the effluent is discharged is also the source of the dilution stream. It is therefore necessary to take into account the recirculation of previously emitted radionuclides should they be detected by sample analysis of the cooling lake water. This is accomplished by defining an effective dilution flow rate as:

$$F_{eff} = F_m \left[1 - \sum_i \frac{LC_i}{ECL_i} \right]$$

ATTACHMENT A
(Page 29 of 160)
OFFSITE DOSE CALCULATION MANUAL

Where:

F_m = The expected minimum dilution water flow rate.

LC_i = Measured concentration of nuclide i in the cooling lake water sample.

ECL_i = Effluent concentration limit of radionuclide i from 10CFR20, Appendix B, Table 2, Column 2.

For the purpose of setpoint calculations the expected minimum dilution flow rate is assigned a value based upon the type and number of pumps RUNNING into the circulating water piping.

Having established the values of F_{dn} and F_{eff} , the calculated maximum permissible waste tank flow rate is given by

$$f_{max} \leq \frac{F_{eff} + f_p}{F_{dn}} \frac{F_{eff}}{f_{dn}} \text{ for } f_p \ll F_{eff}$$

Where f_p is the expected effluent flow rate; normally the rated capacity of the effluent pump. Thus the pump flow rate is set at or below f_{max} . Even though the value of f_{max} may be larger than the actual effluent pump capacity, f_p , it does represent the upper limit to the effluent flow rate, whereby the requirement of 10CFR20 may still be met. If $F_d \leq 1$, the effluent pump flow rate may be assigned any value since the waste tank effluent concentration meets the limits of 10CFR20 without dilution and the release may be made without regard to the setpoints for other release pathways. For those discharge pathways selected to be secured during the release under consideration, the pump flow rate should be set at as low a value as practicable to detect any inadvertent release.

A setpoint for the dilution stream flow rate is not applicable since the minimum flow rate is administratively set.

ATTACHMENT A
(Page 30 of 160)
OFFSITE DOSE CALCULATION MANUAL

- 5) The liquid radiation monitor setpoint may now be determined based on the values of Σ_i , C_i , and f_{max} . The monitor response is primarily to gamma radiation, therefore, the actual setpoint is based on Σ_g , C_g . The calculated monitor setpoint concentration is determined as follows:

$$c = A \sum_i C_g (\mu\text{Ci/ml})$$

Where:

A = Adjustment factor which will allow the setpoint to be established in a practical manner for convenience and to prevent spurious alarms.

$$A = \frac{f_{max}}{f_p}$$

If $A > 1$, calculated c and determine the maximum value for the actual monitor setpoint ($\mu\text{Ci/mL}$).

If $A < 1$, no release may be made.

If $F_d < 1$, no further dilution is required and the release may be made without regard to available dilution or to other releases made simultaneously. However, it is necessary to establish a monitor setpoint which will provide alarm should the release concentration inadvertently exceed 10CFR20 limits. This can be accomplished by establishing the adjustment factor as follows:

$$A = 1/F_d$$

ATTACHMENT A
(Page 31 of 160)
OFFSITE DOSE CALCULATION MANUAL

3.0 Gaseous Effluents

Gaseous effluent releases from the Unit Vent and Radwaste Building Vent are monitored continuously. The Unit Vent is the release point for the Fuel/Auxiliary Building, access control area, containment purge, and condenser air discharge. The Radwaste Building Vent is the release point for Waste Gas Decay Tanks and the Radwaste Building Ventilation System.

Waste Gas Decay Tank releases and Containment Building releases are treated as batch releases. Waste Gas Decay Tank releases are monitored by the Radwaste Building Exhaust Monitor. Containment Building releases (purges) are monitored by the Containment Purge System monitors and the Plant Unit Vent Monitor.

Monitor identifications are as follows:

<u>Monitor ID</u>	<u>Release Point Description</u>
O-GT-RE-21 A and B	Unit Vent (Fuel/Auxiliary Building, access control area, containment purge, condenser air discharge)
O-GH-RE-10 A and B	Radwaste Building vent (Radwaste Building, waste gas decay tank discharge. Acts to isolate Waste Gas Decay Tank discharge)
O-GT-RE-22 & 33	Containment Purge System Monitor (acts to isolate the purge; is not an effluent monitor)
O-GT-RE-31 & 32	Containment Atmosphere Monitor (acts to isolate purge; not an effluent monitor)

The setpoint for monitors may be determined either based on total body dose or skin dose rate. The dose rate limits are for dose rates at the unrestricted area boundary. The monitor setpoint is the lesser of the total body dose rate or skin dose rate.

ATTACHMENT A
(Page 32 of 160)
OFFSITE DOSE CALCULATION MANUAL

3.1 Dose Rate - Compliance With 10 CFR 20

The dose rate due to radioactive materials released in gaseous effluents from the site to areas at and beyond the SITE BOUNDARY shall be limited to the following: 1/01

- a. For noble gases: Less than or equal to 500 mrems/yr to the whole body and less than or equal to 3000 mrems/yr to the skin, and
- b. For Iodine-131 and 133, for tritium, and for all radionuclides in particulate form with half-lives greater than 8 days: Less than or equal to 1500 mrems/yr to any organ.

3.1.1 Remedial Action

With the dose rate(s) exceeding the above limits, immediately restore the release to within the above limit(s).

3.1.2 Surveillance Requirements

The dose rate to radionuclides in gaseous effluents shall be determined to be within the above limits in accordance with the methodology described below by obtaining representative samples and performing analyses in accordance with the sampling and analysis program specified in Table 3-1.

Based on the methodology of NUREG-0133;

- a. Release rate limit for nobles gases:

$$\sum_i K_i (\bar{X}/Q) Q_i < 500 \text{ mrem/yr for the total body,}$$

and

$$\sum_i (L_i + 1.1 M_i)(X/Q) Q_i < 3000 \text{ mrem/yr for the skin}$$

Where:

K_i = Total body dose factor due to gamma emissions for each identified noble gas radionuclide, in mrem/yr per $\mu\text{Ci}/\text{m}^3$, from Table A.1-2.

ATTACHMENT A
(Page 33 of 160)
OFFSITE DOSE CALCULATION MANUAL

$(\overline{X/Q}) = 2.2E-06 \text{ sec/m}^3$, the highest calculated annual average relative concentration at the restricted area boundary in the north sector.

Q_i = Release rate of radionuclide i from vent, in $\mu\text{Ci/sec}$.

L_i = Skin dose factor due to beta emissions for each identified noble gas radionuclide, in mrem/yr per $\mu\text{Ci/m}^3$, from Table A.1-2.

M_i = Air dose factor due to gamma emissions for each identified noble gas radionuclide, in mrad/yr per $\mu\text{Ci/m}^3$ from Table A.1-2.

1.1 = Conversion constant of air dose to skin dose.

- b. Release rate limit for all radionuclides and radioactive materials in particulate form and radionuclides other than noble gases:

$$\sum_i (P_i) IN \times (\overline{X/Q}) \times Q_i < 1500 \text{ mrem/yr to any organ.}$$

Where:

Q_i = The release rate of radionuclides, i , in gaseous effluent from all vent releases, in $\mu\text{Ci/sec}$.

$P(i) IN$ = The dose parameter for radionuclides other than nobles gases for the inhalation pathway, in mrem/yr per $\mu\text{Ci/m}^3$. See Table A.5-1.

$(\overline{X/Q}) = 2.2E-06 \text{ sec/m}^3$ (the highest annual average).
The highest calculated annual average relative concentration for estimating the dose to any individual at the unrestricted area boundary in the N sector.

ATTACHMENT A
(Page 34 of 160)
OFFSITE DOSE CALCULATION MANUAL

All radionuclides are assumed to be released in elemental form. The limit is applicable to the location (unrestricted area boundary or beyond), characterized by the value of X/Q which results in the maximum total body or skin dose commitment. The factors K_i , L_i , and M_i relate the radionuclide airborne concentrations to various dose rates assuming a semi-infinite cloud. These factors are taken from Table B-1 of the Regulatory Guide 1.109 and multiplied by 10^6 to convert pCi^{-1} to μCi^{-1} and listed in Table A.1-2.

The following equation for $P(i)_{\text{IN}}$ was taken from NUREG 0133:

$P(i)_{\text{IN}}$ (Inhalation);

$$P(i)_{\text{IN}} = K' (\text{BR}) \text{DFA}_i (\text{mrem} / \text{yr per } \mu\text{Ci} / \text{m}^3)$$

Where:

K' = a constant of unit conversion, $10^6 \text{ pCi}/\mu\text{Ci}$.

BR = the breathing rate of the child age group in m^3/yr

DFA_i = the maximum organ inhalation dose factor for the child age group for the i th radionuclide, in mrem/pCi . The total body is considered as an organ in the selection of DFA_i .

The age group considered is the child group. The child's breathing rate is taken as $3700 \text{ m}^3/\text{yr}$ from Table E-5 of Regulatory Guide 1.109. The inhalation dose factors for the child, DFA_i are presented in Table E-9 of Regulatory Guide 1.109, in units of mrem/pCi .

Resolutions of the units yield:

$$P_i (\text{Inhalation}) = 3.7 \times 10^9 \text{ DFA}_i$$

The P_i value for tritium is:

$$P_i (\text{Inhalation}) = 3.7 \times 10^9 \text{ DFA}_i$$

ATTACHMENT A
(Page 35 of 160)
OFFSITE DOSE CALCULATION MANUAL

TABLE 3-1
RADIOACTIVE GASEOUS WASTE SAMPLING AND ANALYSIS PROGRAM

Gaseous Release Type	Sample Frequency	Principal Gamma Emitters	H-3 (Oxide)	I-131/ I-133	Gross Alpha	Sr-89, Sr-90
1. Unit Vent Gas LLD(1)	M	M(3) (2) 1E-4	M(4) 1E-6			
Particulate LLD(1)	Continuous (6)	W(7) 1E-11 (2)			M 1E-11	Q Composite 1E-11
Charcoal LLD(1)	Continuous (6)			W(7) 1E-12/ 1E-10		
2. Radwaste Building Vent Gas LLD(1)	M	M(2) 1E-4	M 1E-6			
Particulate LLD(1)	Continuous (6)	W(7) (2) 1E-11			M 1E-11	Q (Composite) 1E-11
Charcoal LLD(1)	Continuous (6)			W(7) 1E-12/ 1E-10		
3. Containment Purge or Vent Gas LLD(1)	P(3)	P(3) (2) 1E-4	M 1E-6			
4. Waste Gas Decay Tanks Gas LLD(1)	P	P(2) 1E-4				

LLD = ($\mu\text{Ci/ml}$)

ATTACHMENT A
(Page 36 of 160)
OFFSITE DOSE CALCULATION MANUAL

TABLE 3-1 (Continued)

TABLE NOTATIONS

- (1) The LLD is defined, as the smallest concentration of radioactive material in a sample that will yield a net count, above system background, that will be detected with 95% probability with only 5% probability of falsely concluding that a blank observation represents a "real" signal.

For a particular measurement system, which may include radiochemical separation:

$$LLD = \frac{4.66 s_b}{E \times V \times (2.22E+6) \times Y \times Decay}$$

Where:

LLD = the "a priori" lower limit of detection (microCuries per unit mass or volume),

s_b = the standard deviation of the background counting rate or of the counting rate of a blank sample as appropriate, (counts per minute), $s_b = \sqrt{B / LT}$

Where: B = background sum (counts)

LT = live time (minutes),

E = the counting efficiency (counts per disintegration),

V = the sample size (units of mass or volume),

2.22E+6 = the number of disintegrations per minute per microCurie,

Y = the fractional radiochemical yield, when applicable,

Decay = decay factor(s), There are three decay factors that may be appropriate for use depending on the nature of the sample and the half life of the nuclide. Any combination of the three may be used. The factors are as follows:

- A) This decay factor corrects for decay from the time of sampling to the start of the analysis.

$e^{-\lambda \Delta t_s}$, where:

Δt_s = decay time = acquisition start time - sample time

ATTACHMENT A
(Page 37 of 160)
OFFSITE DOSE CALCULATION MANUAL

TABLE 3-1 (Continued)

TABLE NOTATIONS

$$\lambda = \ln 2 / \text{half-life}$$

- B) This decay factor corrects for decay during the analysis.

$$\frac{1 - e^{-\lambda RT}}{\lambda \times RT}$$

$$\lambda = \ln 2 / \text{half-life}$$

RT = real time of counting

- C) This decay factor corrects for decay during sampling.

$$\frac{1 - e^{-\lambda \Delta t d}}{\lambda \Delta t d}$$

$$\lambda = \ln 2 / \text{half-life}$$

$\Delta t d$ = deposition time = sample time - deposition start time

NOTE

All times used in decay calculations should be in the same units.

Typical values of E, V, Y, t_g , t_d should be used in the calculation.

It should be recognized that the LLD is defined as an a priori (before the fact) limit representing the capability of a measurement system and not as an a posteriori (after the fact) limit for a particular measurement.

ATTACHMENT A
(Page 38 of 160)
OFFSITE DOSE CALCULATION MANUAL

TABLE 3-1 (Continued)

TABLE NOTATIONS

- (2) The principal gamma emitters for which the LLD specification applies include the following radionuclides: Kr-87, Kr-88, Xe-133, Xe-133m, Xe-135, and Xe-138 in noble gas releases and Mn-54, Fe-59, Co-58, Co-60, Zn-65, Mo-99, I-131, Cs-134, Cs-137, Ce-141 and Ce-144 in iodine and particulate releases. This list does not mean that only these nuclides are to be considered. Other gamma peaks that are identifiable, together with those of the above nuclides, shall also be analyzed and reported in the annual Radioactive Effluent Release Report in the format outlined in Regulatory Guide 1.21, Appendix B, Revision 1, June 1974.
- (3) Sampling and analysis shall also be performed following shutdown, startup, or a THERMAL POWER change greater than or equal to 15% of RATED THERMAL POWER within 1 hour period.
- (4) Tritium grab samples shall be taken and analyzed at least once per 24 hours when the refueling canal is flooded.
- (6) The ratio of the sample flow rate to the sampled stream flow rate shall be known for the time period covered by each dose or dose rate calculation made in accordance with Sections 3.1, 3.2 and 3.3.
- (7) Samples shall be changed at least once per 7 days and analyses shall be completed within 48 hours after changing, or after removal from sampler. For unit vent, sampling shall also be performed at least once per 24 hours for at least 7 days following each shutdown, startup or THERMAL POWER change exceeding 15% of RATED THERMAL POWER within a 1-hour period, and analyses shall be completed within 48 hours of changing. When samples collected for 24 hours are analyzed, the corresponding LLDs may be increased by a factor of 10. This requirement to sample once per 24 hours does not apply if analysis shows that both the DOSE EQUIVALENT I-131 concentration in the reactor coolant and the unit vent noble gas monitor activity have not increased more than a factor of 3.

FREQUENCY NOTATION

<u>NOTATION</u>	<u>FREQUENCY</u>
S	At least once per 12 hours.
D	At least once per 24 hours.
W	At least once per 7 days
M	At least once per 31 days.
Q	At least once per 92 days.
SA	At least once per 184 days.
R	At least once per 18 months.
S/U	Prior to each reactor startup.
N.A.	Not applicable.
P	Completed prior to each release.

Revision: 4	OFFSITE DOSE CALCULATION MANUAL	AP 07B-003
Reference Use		Page 44 of 165

ATTACHMENT A
(Page 39 of 160)
OFFSITE DOSE CALCULATION MANUAL

3.2 Dose - Compliance With 10 CFR 50 Appendix I

3.2.1 Noble Gases

The air dose due to noble gases released in gaseous effluents, from each unit, to areas at and beyond the SITE BOUNDARY shall be limited to the following: 1/01

- a. During any calendar quarter: Less than or equal to 5 mrad for gamma radiation and less than or equal to 10 mrad for beta radiation, and
- b. During any calendar year: Less than or equal to 10 mrad for gamma radiation and less than or equal to 20 mrad for beta radiation.

3.2.1.1 Remedial Action

With the calculated air dose from radioactive noble gases in gaseous effluents exceeding any of the above limits, prepare and submit to the Commission within 30 days, a special report that identifies the cause(s) for exceeding the limit(s) and defines the corrective actions that have been taken to reduce the releases and the proposed corrective actions to be taken to assure that subsequent releases will be in compliance with the above limits.

3.2.1.2 Surveillance Requirements

Cumulative dose contributions for the current calendar quarter and calendar year for noble gases shall be determined in accordance with the following methodology at least once per 31 days. The dose calculations for the actual releases of radioactive noble gases in gaseous effluent will be consistent with the methodology provided in Reg. Guide 1.109, Rev. 1. The following dose calculations will be performed:

- a. During any calendar quarter;

For gamma radiation;

$$D = 3.17E-8 \sum_{i=1} M_i \left[\left(\overline{X/Q} \right) \times Q_i \right] \leq 5 \text{ mrad.}$$

ATTACHMENT A
(Page 40 of 160)
OFFSITE DOSE CALCULATION MANUAL

For beta radiation:

$$D = 3.17E-8 \sum_{i=1} N_i \left[\left(\overline{X/Q} \right) \times Q_i \right] \leq 10 \text{ mrad.}$$

b. During any calendar year:

For gamma radiation;

$$D = 3.17E-8 \sum_{i=1} M_i \left[\left(\overline{X/Q} \right) \times Q_i \right] \leq 10 \text{ mrad.}$$

For beta radiation:

$$D = 3.17E-8 \sum_{i=1} N_i \left[\left(\overline{X/Q} \right) \times Q_i \right] \leq 20 \text{ mrad.}$$

Where:

3.17 E-8 = The inverse of the number of seconds in a year.

M_i = The air dose factor due to gamma emissions for each identified noble gas radionuclide, in mrad/yr per $\mu\text{Ci}/\text{m}^3$ from Table A.1-2 (Reg. Guide 1.109, Table B-1, Col. 4).

N_i = The air dose factor due to beta emissions for each identified noble gas radionuclide, in mrad/year per $\mu\text{Ci}/\text{m}^3$ from Table A.1-2 (Reg. Guide 1.109, Table B-1, Column 2).

$\left(\overline{X/Q} \right)$ = $2.2E-06 \text{ sec}/\text{m}^3$, the highest calculated annual average relative concentration at the restricted area boundary in the north sector.

Q_i = The release of noble gas radionuclides, 'i', in gaseous effluents, in μCi . Releases shall be cumulative over the calendar quarter or year as appropriate.

An average monthly air dose schedule should be setup to ensure section 3.2.1 is not exceeded. The average monthly air dose should be as follows:

Revision: 4	OFFSITE DOSE CALCULATION MANUAL	AP 07B-003
Reference Use		Page 46 of 165

ATTACHMENT A
(Page 41 of 160)
OFFSITE DOSE CALCULATION MANUAL

- a. For gamma radiation ≤ 1.6 mrad/mo.
For beta radiation ≤ 3.3 mrad/mo.

If the monthly average air doses for: (a) is exceeded, it should be noted that if the release is continued at the same (or higher) frequencies or activities the quarterly limit of Section 3.2.1.A will be exceeded.

- b. For gamma radiation ≤ 0.8 mrad/mo.
For beta radiation ≤ 1.6 mrad/mo.

If the monthly average air doses for: (b) is exceeded, it should be noted that if the release is continued at the same (or higher) frequencies or activities the annual limit of Section 3.2.1.B will be exceeded.

If any of the above monthly average air doses are exceeded, evaluation of the causes of the high air dose should be performed and steps should be taken to reduce the activity or frequency (e.g. delay the release of a Waste Gas Decay Tank) of the release.

3.2.2 Radioiodines, Particulates and Other Radionuclides

The dose to a MEMBER OF THE PUBLIC from Iodine-131 and 133, tritium, and all radionuclides in particulate form with half-lives greater than 8 days in gaseous effluents released, from each unit, to areas at and beyond the SITE BOUNDARY shall be limited to the following: 1/01

- a. During any calendar quarter: Less than or equal to 7.5 mrems to any organ; and
- b. During any calendar year: Less than or equal to 15 mrems to any organ.

Revision: 4	OFFSITE DOSE CALCULATION MANUAL	AP 07B-003
Reference Use		Page 47 of 165

ATTACHMENT A
(Page 42 of 160)
OFFSITE DOSE CALCULATION MANUAL

3.2.2.1 Remedial Action

With the calculated dose from the release of Iodine-131 and 133, tritium, and radionuclides in particulate form with half-lives greater than 8 days, in gaseous effluents exceeding any of the above limits, prepare and submit to the Commission within 30 days, a special report that identifies the cause(s) for exceeding the limits and defines the corrective actions that have been taken to reduce the releases and the proposed corrective actions to be taken to assure that subsequent releases will be in compliance with the above limits.

3.2.2.2 Surveillance Requirements

Cumulative dose contributions for the current calendar quarter and current calendar year for Iodine-131 and 133, tritium, and radionuclides in particulate form with half-lives greater than 8 days shall be determined in accordance with the following methodology at least once per 31 days. To show compliance, the dose calculations for the actual releases of the subject materials are consistent with the methodology provided in Regulation Guide 1.109, Revision 1. The following dose calculations will be performed:

a. $D \text{ (mrem)} = 3.17E-8 \sum_i R_i [(WQ_i)] \leq 7.5 \text{ mrem}$

b. $D \text{ (mrem)} = 3.17E-8 \sum_i R_i [(WQ_i)] \leq 15 \text{ mrem}$

Where:

3.17 E-8 = The inverse of the number of seconds in a year.

ATTACHMENT A
(Page 43 of 160)
OFFSITE DOSE CALCULATION MANUAL

Q_i = The release of radioiodines, radioactive materials in particulate form and radionuclides other than noble gases in gaseous effluents, 'i', in μCi . Releases shall be cumulative over the calendar quarter or year as appropriate. The Q_i value shall be determined as the product of the flow rate through the release point and grab samples of the effluent analyzed in accordance with Table 3-1.

W = The annual average dispersion parameter for estimating the dose to an individual at the controlling location.

$W = (X/Q)$, 2.2×10^{-6} sec/ m^3 for the inhalation pathway.

$W = (D/Q)$, $1.8 \text{ E-}8$ m^{-2} , for the food and ground plane pathways.

R_i = The dose factor for each identified radionuclide, 'i', in mrem/yr per $\mu\text{Ci}/\text{m}^3$. See Table A.5-2 through Table A.5-20.

Where:

Inhalation Pathway Factor, R^I_i [X/Q]

$$R^I_i [X/Q] = K' (BR)_a (DFA)_i \left(\text{mrem/yr per } \mu\text{Ci}/\text{m}^3 \right)$$

Where:

K' = a constant of unit conversion, $10^6 \text{pCi}/\mu\text{Ci}$.

$(BR)_a$ = The breathing rate of the receptor of age group (a), in m^3/yr .

The breathing rates $(BR)_a$ for the various age groups are tabulated below, as given in Regulatory Guide 1.109, Table E-5.

<u>AGE GROUP (a)</u>	<u>BREATHING RATE (m^3/yr)</u>
Infant	1400
Child	3700
Teen	8000
Adult	8000

Revision: 4	OFFSITE DOSE CALCULATION MANUAL	AP 07B-003
Reference Use		Page 49 of 165

ATTACHMENT A
(Page 44 of 160)
OFFSITE DOSE CALCULATION MANUAL

$(DFA_i)_a$ = The maximum organ inhalation dose factor for the receptor of age group (a) for the i th radionuclide, in mrem/pCi. The body is considered as an organ in the selection of $(DFA_i)_a$. See Tables A.2-1, A.2-2, A.2-3, & A.2-4. From Regulatory Guide 1.109, Tables E-7, E-8, E-9 and E-10.

Ground Plane Pathway Factor, R^G_i [D/Q]

$$R^G_i [D/Q] = K'K'' (SF) DFG_i \left[\frac{(1 - e^{-\lambda_i t})}{\lambda_i} \right] (m^2 \times mrem / yr \text{ per } \mu Ci / sec)$$

Where:

K' = A constant of unit conversion, 10^6 pCi/ μ Ci.

K'' = A constant of unit conversion, 8760 hr/year.

λ_i = The decay constant for the i th radionuclide, sec^{-1} .

t = The exposure time, 4.73 E8 sec (15 years).

DFG_i = The ground plane dose conversion factor for the i th radionuclide (mrem/hr per pCi/ m^2). See Table A.2-5. (Regulatory Guide 1.109, Table E-6).

SF = The shielding factor (dimensionless), 0.7 (Reg. Guide 1.109)

Grass-Cow-Milk Pathway Factor, R^C_i [D/Q]

$$R^C_i [D/Q] = K' \left(\frac{Q_F (U_{ap})}{\lambda_i + \lambda_w} \right) F_m(r) (DFL_i)_a \left(\frac{1}{Y_p} \right) (e^{-\lambda_i t}) (m^2 mrem / yr \text{ per } \mu Ci / sec)$$

Where:

K' = A constant of unit conversion, 10^6 pCi/ μ Ci.

Q_F = The cow's consumption rate, in Kg/day (wet weight), 50 kg/day. (Reg. Guide 1.109, Table E-3).

U_{ap} = The receptor's milk consumption rate for age (a), in liters/yr. (Reg. Guide 1.109, Table E-5).

ATTACHMENT A
(Page 45 of 160)
OFFSITE DOSE CALCULATION MANUAL

Infant	=	330 1/yr
Child	=	330 1/yr
Teen	=	400 1/yr
Adult	=	310 1/yr

Y_p = The agricultural productivity by unit area of pasture feed grass, in kg/m^2 , $0.7 \text{ kg}/\text{m}^2$. (Reg. Guide 1.109, Table E-15)

F_m = The stable element transfer coefficients, in days/liter, see Table A.3-5. (Reg. Guide 1.109, Table E-1)

r = Fraction of deposited activity retained on cow's feed grass, $r=1$ for radioiodine and $r=0.2$ for particulates. (Reg. Guide 1.109, Table E-15)

$(DFL_i)_a$ = The maximum organ ingestion dose factor for the i th radionuclide for the receptor in age group 'a', in mrem/pCi . See Tables A.3-1, A.3-2, A.3-3, and A.3-4. (Reg. Guide 1.109, Table E-11, E-12, E-13, and E-14)

λ_i = The decay constant for the i th radionuclide, in sec^{-1} .

λ_w = The decay constant for removal of activity on leaf and plant surfaces by weathering, $5.73 \text{ E-}7 \text{ sec}^{-1}$ (corresponding to a 14 day half-life).

NOTE

The fraction of the year that the cow is on pasture and the fraction of the cow feed that is pasture grass is assumed to be 1.0, which is the most restrictive case.

t_f = The transport time from pasture to cow, to milk, to receptor, in sec, $1.73 \text{ E}5 \text{ sec}$ (2 days). (Reg. Guide 1.109, Table E-15).

ATTACHMENT A
(Page 46 of 160)
OFFSITE DOSE CALCULATION MANUAL

Grass-Goat-Milk Pathway Factor, $R^C_i[D/Q]$

$$R^C_i[D/Q] = K' \left(\frac{Q_F(U_{sp})}{\lambda_i + \lambda_w} \right) F_m(r) (DFL_i)_a \left(\frac{1}{Y_p} \right) (e^{-\lambda_i t_f}) (m^2 \text{ mrem/yr per } \mu\text{Ci/sec})$$

Where:

Q_F = The goat's consumption rate, in Kg/day (wet weight), 6 Kg/day. (Reg. Guide 1.109, Table E-3).

t_f = The transport time from pasture to goat, to milk, to receptor, in sec, $1.73 \text{ E}5 \text{ sec}$ (2 days). (Reg. Guide 1.109, Table E-15).

all other terms are defined under the Grass-Cow-Milk-Pathway Factor.

NOTE

The fraction of the year that the goat is on pasture and the fraction of the goat feed that is pasture grass is assumed to be 1.0, which is the most restrictive case.

The concentration of tritium in milk is based on the airborne concentration rather than the deposition. Therefore, the R^C_i is based on (X/Q) ,

$$R^C_i[X/Q] = K' K'' F_m Q_F U_{sp} (DFL_i)_a [0.75 (0.5/H)] (\text{mrem/yr per } \mu\text{Ci/m}^3)$$

Where:

K'' = a constant of unit conversion, 10^3 gm/Kg .

H = Absolute humidity of the atmosphere, 8 gm/m^3 (Reg. Guide 1.109).

0.75 = The fraction of total feed that is water. (NUREG 0133)

0.5 = The ratio of the specific activity of the feed grass water to the atmospheric water. (NUREG 0133)

ATTACHMENT A
(Page 47 of 160)
OFFSITE DOSE CALCULATION MANUAL

Grass-Cow-Meat Pathway Factor, $R^{M_i} [D/Q]$

$$R^{M_i} [D/Q] = K' \left(\frac{Q_f U_{ap}}{\lambda_i + \lambda_w} \right) F_f(r) (DFL_i)_a (1/Y_p) (e^{-\lambda_i t_f}) (m^2 \text{ mrem/yr per mCi/sec})$$

Where:

F_f = The stable element transfer coefficients, in days/kg, Table A.3-5. (Reg. Guide 1.109, Table E-1).

U_{ap} = The receptor's meat consumption rate for age (a), in kg/yr. (Reg. Guide 1.109, Table E-5).

Infant	=	0
Child	=	41
Teen	=	65
Adult	=	110

t_f = The transport time from pasture to receptor, in sec., $1.73 \text{ E}6$ (20 days) (Reg. Guide 1,109, Table E-15).

The concentration of tritium in meat is based on its airborne concentration rather than the deposition. Therefore, the R^{M_i} is based on (X/Q):

$$R^{M_i} [X/Q] = K' K'' \cdot F_f Q_f U_{ap} (DFL_i)_a [0.75 (0.5/H)] (mrem/yr per \mu\text{Ci/m}^3)$$

Where:

All terms defined above.

Vegetation Pathway Factor, $R^V_i [D/Q]$

Man is considered to consume two types of vegetation (fresh and stored) that differs only in the time period between harvest and consumption, therefore:

$$R^V_i [D/Q] = K' \left[\frac{r}{Y_v (\lambda_i + \lambda_w)} \right] (DFL_i)_a \left[(U^L)_a (f_L) (e^{-\lambda_i L}) + (U^S)_a (f_s) (e^{-\lambda_i h}) \right] (m^2 \times \text{mrem/yr per } \mu\text{Ci/sec})$$

Where:

K' = A constant of unit conversion, $10^6 \text{ pCi}/\mu\text{Ci}$.

ATTACHMENT A
(Page 48 of 160)
OFFSITE DOSE CALCULATION MANUAL

U_a^L = The consumption rate of fresh leafy vegetation by the receptor in age group (a), in kg/yr. (Reg. Guide 1.109, Table E-5).

Infant	=	0	kg/yr
Child	=	26	kg/yr
Teen	=	42	kg/yr
Adult	=	64	kg/yr

U_a^S = The consumption rate of stored vegetation by the receptor in age group (a), Kg/yr. (Reg. Guide 1.109, Table E-5).

Infant	=	0	kg/yr
Child	=	520	kg/yr
Teen	=	630	kg/yr
Adult	=	520	kg/yr

f_L = The fraction of the annual intake of fresh leafy vegetation grown locally. (default = 1.0) (Reg. Guide 1.109).

f_G = The fraction of the annual intake of stored vegetation grown locally (default = 0.76) (Reg. Guide 1.109).

t_L = The average time between harvest of leafy vegetation and its consumption, in seconds, $8.6 \text{ E}4 \text{ sec}$ (1 day). (Reg. Guide 1.109).

t_h = The average time between harvest of stored vegetation and its consumption, in seconds, $5.18 \text{ E}6 \text{ sec}$ (60 days) (Reg. Guide 1.109, Table E-15).

Y_V = The vegetation area density, 2.0 kg/m^2 . (Reg. Guide 1.109, Table E-15).

All other factors previously defined.

ATTACHMENT A
(Page 49 of 160)
OFFSITE DOSE CALCULATION MANUAL

The concentration of tritium in vegetation is based on the airborne concentration rather than the deposition. Therefore, the R^V_i is based on (X/Q):

$$R^V_i[X/Q] = K'K'' \cdot [U^L \cdot f_L + U^S \cdot f_S] (DFL_i)_s [0.75 (0.5/H)] (\text{mrem/yr per } \mu\text{Ci/m}^3)$$

Where:

All terms defined previously. All values indicated are default values from Reg. Guide 1.109, Rev. 1.

An average monthly dose schedule should be setup to ensure Section 3.2.2 is not exceeded. The average monthly dose due to radioiodines, particulates, and other radionuclides which are included in this section should be as follows:

- a. < 2.5 mrem/mo.

If the monthly average dose for (a) is exceeded, it should be noted that if the release is continued at the same (or higher) frequencies or activities the quarterly limit of Section 3.2.2.a will be exceeded.

- b. < 1.25 mrem/mo.

If the monthly average dose for (b) is exceeded, it should be noted that if the release is continued at the same (or higher) frequencies or activities the yearly limit of Section 3.2.2.b will be exceeded.

If any of the above monthly doses are exceeded, evaluation of the causes should be performed and steps taken to reduce the activity or frequency of the release.

3.3 Projected Dose

The VENTILATION EXHAUST TREATMENT SYSTEM and the WASTE GAS HOLDUP SYSTEM shall be OPERABLE and appropriate portions of these systems shall be used to reduce releases of radioactivity when the projected doses in 31 days due to gaseous effluent releases, from each unit, to areas at and beyond the SITE BOUNDARY would exceed:

1/01

- a. 0.2 mrad to air from gamma radiation, or

Revision: 4	OFFSITE DOSE CALCULATION MANUAL	AP 07B-003
Reference Use		Page 55 of 165

ATTACHMENT A
(Page 50 of 160)
OFFSITE DOSE CALCULATION MANUAL

- b. 0.4 mrad to air from beta radiation, or
- c. 0.3 mrem to any organ of a MEMBER OF THE PUBLIC.

3.3.1 Remedial Action

With radioactive gaseous waste being discharged without treatment and in excess of the above limits, prepare and submit to the Commission within 30 days, a special report that includes the following information:

- a. Identification of any inoperable equipment or subsystems, and the reason for the inoperability,
- b. Action(s) taken to restore the inoperable equipment to OPERABLE status, and
- c. Summary description of action(s) taken to prevent a recurrence.

3.3.2 Surveillance Requirements

- 3.3.2.1** Doses due to gaseous releases from each unit to areas at and beyond the SITE BOUNDARY shall be projected at least once per 31 days in accordance with the following methodology when Gaseous Radwaste Treatment Systems are not being fully utilized.

$$D_{31} = \left[\frac{A}{T} \right] \times 31$$

Where:

D_{31} = Projected 31 day dose

A = Cumulative dose for previous three months

T = Number of days that the cumulative dose occurred in A above

- 3.3.2.2** The installed VENTILATION EXHAUST TREATMENT SYSTEM and WASTE GAS HOLDUP SYSTEM shall be considered OPERABLE by meeting Section 3.1 and 3.2 limits.

ATTACHMENT A
(Page 51 of 160)
OFFSITE DOSE CALCULATION MANUAL

3.4 Instrumentation

The radioactive gaseous effluent monitoring instrumentation channels shown in Table 3-2 shall be OPERABLE with their Alarm/Trip Setpoints set to ensure that the limits of Section 3.1 are not exceeded. The Alarm/Trip Setpoints of these channels meeting Section 3.1 shall be determined and adjusted in accordance with the methodology and parameters of Section 3.4.4 below.

3.4.1 Remedial Action

- a. With a radioactive gaseous effluent monitoring instrumentation channel Alarm/Trip Setpoint less conservative than required by the above specification, immediately suspend the release of radioactive gaseous effluents monitored by the affected channel, or declare the channel inoperable.
- b. With less than the minimum number of radioactive gaseous effluent monitoring instrumentation channels OPERABLE take the ACTION shown in Table 3-2. Restore the inoperable instrumentation to OPERABLE status within the time specified in the ACTION, or explain in the next annual Radioactive Effluent Release Report, why this inoperability was not corrected within the time specified.

3.4.2 Surveillance Requirements

Each radioactive gaseous effluent monitoring instrumentation channel shall be demonstrated OPERABLE by performance of the CHANNEL CHECK, SOURCE CHECK, CHANNEL CALIBRATION and CHANNEL OPERATIONAL TEST at the frequencies shown in Table 3-3.

ATTACHMENT A
(Page 52 of 160)
OFFSITE DOSE CALCULATION MANUAL

TABLE 3-2
RADIOACTIVE GASEOUS EFFLUENT MONITORING INSTRUMENTATION

<u>INSTRUMENT</u>	<u>MINIMUM CHANNELS OPERABLE</u>	<u>APPLICABILITY</u>	<u>ACTION</u>
1. Unit Vent System			
a. Noble Gas Activity Monitor - Providing Alarm (GT-RE-21B)	1	*	40
b. Iodine Sampler (GT-RE-21A)	1	*	43
c. Particulate Sampler (GT-RE-21A)	1	*	43
d. Flow Rate	N.A.	*	45
e. Sampler Flow Rate Monitor	1	*	39
2. Containment Purge System			
a. Noble Gas Activity Monitor - Providing Alarm and Automatic Termination of Release (GT-RE-22, GT-RE-33)	1	*	41
b. Flow Rate	N.A.	*	45
3. Radwaste Building Vent System			
a. Noble Gas Activity Monitor - Providing Alarm and Automatic Termination of Release (GH-RE-10B)	1	*	38, 40
b. Iodine Sampler (GH-RE-10A)	1	*	43
c. Particulate Sampler (GH-RE-10A)	1	*	43
d. Flow Rate	N.A.	*	45
e. Sampler Flow Rate Monitor	1	*	39

* At all times.

ATTACHMENT A
(Page 53 of 160)
OFFSITE DOSE CALCULATION MANUAL

TABLE 3-2 (Continued)
TABLE NOTATIONS
ACTION STATEMENTS

ACTION 38 - With the number of channels OPERABLE less than required by the minimum channels OPERABLE requirement, the contents of the tank(s) may be released to the environment for up to 14 days provided that prior to initiating the release:

- a. At least two independent samples of the tank's contents are analyzed, and
- b. At least two technically qualified members of the facility staff independently verify the release rate calculations and discharge valve lineup.

Otherwise, suspend release of radioactive effluents via this pathway.

ACTION 39 - With the number of channels OPERABLE less than required by the minimum channels OPERABLE requirement, effluent releases via this pathway may continue for up to 30 days provided the flow rate is estimated at least once per 4 hours.

ACTION 40 - With the number of channels OPERABLE less than required by the minimum channels OPERABLE requirement, effluent releases via this pathway may continue for up to 30 days provided grab samples are taken at least once per 12 hours and these samples are analyzed for radioactivity within 24 hours.

ACTION 41 - With the number of channels OPERABLE less than required by the minimum channels OPERABLE requirement, immediately suspend PURGING of radioactive effluents via this pathway.

ACTION 43 - With the number of channels OPERABLE less than required by the minimum channels OPERABLE requirement, effluent releases via the affected pathway may continue for up to 30 days provided samples are continuously collected with auxiliary sample equipment as required in Table 3-1.

ACTION 45 - Flow rate for this system shall be based on fan status and operating curves or actual measurements.

ATTACHMENT A
(Page 54 of 160)
OFFSITE DOSE CALCULATION MANUAL

TABLE 3-3
RADIOACTIVE GASEOUS EFFLUENT MONITORING INSTRUMENTATION SURVEILLANCE
REQUIREMENTS

<u>INSTRUMENT</u>	<u>CHANNEL CHECK</u>	<u>SOURCE CHECK</u>	<u>CHANNEL CALIBRATION</u>	<u>CHANNEL OPERATIONAL TEST</u>	<u>MODES FOR WHICH SURVEILLANCE IS REQUIRED</u>
1. Unit Vent System					
a. Noble Gas Activity Monitor- Providing Alarm (GT-RE-21)	D	M	R(3)	Q(2)	*
b. Iodine Sampler	W	N.A.	N.A.	N.A.	*
c. Particulate Sampler	W	N.A.	N.A.	N.A.	*
d. Flow Rate	N.A.	N.A.	R(4)	N.A.	*
e. Sampler Flow Rate Monitor	D	N.A.	R	Q	*
2. Containment Purge System					
a. Noble Gas Activity Monitor- Providing Alarm and Auto- matic Termination of Re- lease (GT-RE-22, GT-RE-33)	D	P	R(3)	Q(1)	*
b. Iodine Sampler	W	N.A.	N.A.	N.A.	*
c. Particulate Sampler	W	N.A.	N.A.	N.A.	*
d. Flow Rate	N.A.	N.A.	R(4)	N.A.	*
e. Sampler Flow Rate Monitor	D	N.A.	R	N.A.	*
3. Radwaste Building Vent System					
a. Noble Gas Activity Monitor- Providing Alarm and Auto- matic Termination of Release (GH-RE-10)	D,P	M,P	R(3)	Q(1)	*
b. Iodine Sampler	W	N.A.	N.A.	N.A.	*
c. Particulate Sampler	W	N.A.	N.A.	N.A.	*
d. Flow Rate	N.A.	N.A.	R(4)	N.A.	*
e. Sampler Flow Rate Monitor	D	N.A.	R	N.A.	*

*At all times.

ATTACHMENT A
(Page 55 of 160)
OFFSITE DOSE CALCULATION MANUAL

TABLE 3-3 (Continued)
TABLE NOTATIONS

- (1) The CHANNEL OPERATIONAL TEST shall also demonstrate that automatic isolation of this pathway and control room alarm annunciation as appropriate occur if any of the following conditions exists:
- a. Instrument indicates measured levels above the Alarm/Trip Setpoint (isolation and alarm), or
 - b. Circuit failure (alarm only), or
 - c. Instrument indicates a downscale failure (alarm only) or
 - d. Instrument controls not set in operate mode (alarm only).
- (2) The CHANNEL OPERATIONAL TEST shall also demonstrate that control room alarm annunciation occurs if any one or combination of the following conditions exists:
- a. Instrument indicates measured levels above the alarm setpoint
 - b. Circuit failure
 - c. Instrument indicates a downscale failure
 - d. Instrument controls not set in operate mode.
- (3) The initial CHANNEL CALIBRATION shall be performed using one or more of the reference (gas or liquid and solid) standards certified by the National Institute of Standards and Technology (NIST) or using standards that have been obtained from suppliers that participate in measurement assurance activities with NIST. These standards shall permit calibrating the system over its intended range of energy, measurement range, and establish monitor response to a solid calibration source. For subsequent CHANNEL CALIBRATION, NIST traceable standard (gas, liquid or solid) may be used; or a gas, liquid, or solid source that has been calibrated by relating it to equipment that was previously (within 30 days) calibrated by the same geometry and type of source traceable to NIST.
- (4) If flow rate is determined by exhaust fan status and fan performance curves, the following surveillance operations shall be performed at least once per 18 months:
- a. The specific vent flows by direct measurement, or
 - b. The differential pressure across the exhaust fan and vent flow established by the fan's "flow- P" curve, or
 - c. The fan motor horsepower measured and vent flow established by the fan's "flow-horsepower" curve.

ATTACHMENT A
(Page 56 of 160)
OFFSITE DOSE CALCULATION MANUAL

3.4.3 Airborne Radiation Monitor Calibration Methodology

The following monitors are associated with gaseous releases

<u>Monitor ID</u>	<u>Monitor Description</u>	<u>Monitor Type</u>
O-GT-RE-21A	Plant Unit Vent	Particulate, Iodine
O-GH-RE-10A	Radwaste Building Effluent	Particulate, Iodine
O-GT-RE-21B	Plant Unit Vent	Wide Range Gas
O-GH-RE-10B	Radwaste Building Effluent	Wide Range Gas
O-GT-RE-22 & 33	Containment Purge Exhaust	Particulate, Iodine, Gas
O-GT-RE-31 & 32	Containment Atmosphere	Particulate, Iodine, Gas

3.4.3.1 Particulate Detector

Beta particulate is monitored by a 50 mm diameter by 0.25 mm thick plastic scintillator optically coupled to a 50 mm diameter photomultiplier tube. This detector shall be calibrated over its range of energy and rate capabilities.

For energy range calibration four sources shall be used. Each source consists of a filter paper impregnated with a beta emitting radionuclide. The radionuclides used should be Tc-99, Cs-137, Cl-36, and Rh-106. Each source shall be positioned in the filter paper retaining ring and counted separately. The count rates for each radionuclide source shall be recorded and the data plotted on a graph of cpm/ μ Ci versus average beta energy. This curve represents the detectors response characteristics over the range of beta energies observed. The efficiency for setpoint calculations shall be based on the efficiency of the detector for Cs-137.

The detector shall be calibrated for its rate capabilities using a filter paper impregnated with standard activities of Cs-137. Increasing amounts of a standard Cs-137 solution shall be impregnated on a filter paper. The counts per minute for each Cs-137 standard shall be recorded. A determination of linearity shall be produced using the counts per minute vs. concentration data. At least three sources covering approximately $\frac{1}{4}$, $\frac{1}{2}$, and $\frac{3}{4}$ of full scale shall be checked.

3.4.3.2 Iodine Detector

Iodine gas is monitored by absorbing the gas on a charcoal filter element. The charcoal filter is viewed by an NaI(Tl) integral line gamma scintillator assembly.

ATTACHMENT A
(Page 57 of 160)
OFFSITE DOSE CALCULATION MANUAL

Because of its short half-life and the difficulty in handling gaseous iodine, barium sources shall be used for calibration. The photo peaks of interest are as follows:

- a. Ba-133: 356 KeV gamma is 0.69 efficient/disintegration
- b. I-131: 364 KeV gamma is 0.82 efficient/disintegration

Therefore, each iodine disintegration will produce $0.82/0.69 \times$ barium disintegrations. Assuming that the detector efficiency for 356 KeV is the same as for the 364 KeV, the sensitivity for I-131 equals $1.19 \times$ Ba-133 (counts/min) μCi . The standard sources shall be constructed by impregnating a standard Ba-133 solution into the charcoal filter element. The geometry shall simulate the iodine retention on the first surface of the charcoal. Sources shall be prepared to cover approximately $\frac{1}{4}$, $\frac{1}{2}$ and $\frac{3}{4}$ of full scale. The barium counts per minute for each standard shall be adjusted to iodine counts per minute as described above. A determination of linearity shall be produced using the corrected counts per minute vs. concentration data.

3.4.3.3 Gas Detector

The gas detectors associated with monitors O-GT-RE-22 & 33, O-GT-RE-31 & 32 and the low-range detectors of monitors O-GT-RE-21B and O-GH-RE-10B are a plastic scintillator identical to the particulate detector. The mid-range and high-range detectors of monitors O-GT-RE-21B and O-GH-RE-10B are cadmium telluride, solid state sensors.

ATTACHMENT A
(Page 58 of 160)
OFFSITE DOSE CALCULATION MANUAL

Sources for all gas detectors shall be produced by evacuating the sample chamber with a vacuum pump. The sample chamber then shall be backfilled to the desired pressure with a source of standard Xe-133. The source is then counted and the counts per minute recorded. A determination of linearity shall be produced using the counts per minute vs. concentration data. Sources shall be prepared to cover approximately ¼, ½ and ¾ of full scale for the detectors associated with monitors O-GT-RE-22 and 33, O-GT-RE-31 and 32 and the low-range detectors of monitors O-GT-RE-21B and O-GH-RE-10B. Sources shall be prepared for the mid/high range detector to cover two points on the mid-range scale. For ALARA purposes, response for the high-range scale shall be extrapolated using the data from the mid-range calibration.

3.4.4 Airborne Monitor Setpoints

3.4.4.1 Total Body Dose Rate Setpoint Calculations

The limit of the total body dose rate is 500 mrem/yr at the unrestricted area boundary. The monitor alarm/trip setpoint based on total body dose will be calculated as follows:

$$S_{tb} \leq (SF \times AF) \times D_{tb} \times R_t$$

Where:

S_{tb} = The monitors alarm/trip setpoint based on the total body dose rate. ($\mu\text{Ci}/\text{cc}$)

NOTE

If the monitor setpoint units needed are ($\mu\text{Ci}/\text{sec}$), multiply ($\mu\text{Ci}/\text{cc}$) calculated setpoint by the waste gas stream flow rate (cc/sec).

D_{tb} = Limit of 500 mrem/yr total body, conservatively interpreted as a continuous release over a one year period.

ATTACHMENT A
(Page 59 of 160)
OFFSITE DOSE CALCULATION MANUAL

SF = Normally will be set to 0.85. This number is chosen since the gaseous monitors are set using Xe-133 energy level. Xe-133 comprises 85% of total noble gaseous activity expected. (See USAR Table 11.1-1). If necessary the 0.85 can be further modified to compensate for statistical fluctuations and errors of measurement.

AF = Allocation factor for each release so that simultaneous releases can be made without exceeding the limit. Normally AF is calculated as follows:

$$AF = \frac{RF}{TF}$$

Where:

RF = Release flow rate of the release point under consideration.

TF = Total flow rate of all release points including release under consideration.

R_t = monitor response per mrem/yr to the total body, determined according to:

$$R_t = \frac{c}{\left(\overline{X/Q} \sum_i K_i Q_i \right)}$$

Where:

c = The monitor response to the gaseous effluent noble gas (μCi/cc) corresponding to grab sample radionuclide concentrations.

$\left(\overline{X/Q} \right)$ = The highest calculated annual average atmospheric dispersion (sec/m³) at the restricted area boundary.

K_i = The total body dose factor due to gamma emissions from isotope i (mrem/yr per μCi/m³) from Table A.1-2.

ATTACHMENT A
(Page 60 of 160)
OFFSITE DOSE CALCULATION MANUAL

Q_i = Rate of release of noble gas radionuclide i ($\mu\text{Ci}/\text{sec}$) (concentration of radionuclide i x release flow rate)

3.4.4.2 Skin Dose Rate Calculation

The limit of the skin dose rate is 3000 mrem/yr at the restricted area boundary. The monitor alarm/trip setpoint is calculated as follows:

$$S_s \leq (SF \times AF) \times D_s \times R_s$$

Where:

S_s = The monitors alarm/trip setpoint based on the skin dose rate. ($\mu\text{Ci}/\text{cc}$)

NOTE

If the monitor setpoint units needed are ($\mu\text{Ci}/\text{sec}$), multiply the ($\mu\text{Ci}/\text{cc}$), calculated setpoint by the waste gas stream flow rate (cc/sec).

D_s = Limit of 3000 mrem/yr to the skin of the body, conservatively interpreted as a continuous release over a one year period.

R_s = Monitor response per mrem/yr to the skin of the body.

$$R_s = \frac{c}{\left(\frac{\bar{X}}{Q} \right) \sum_i (L_i + 1.1M_i) Q_i}$$

Where:

L_i = Skin dose factor due to beta emissions from isotope i (mrem/yr per $\mu\text{Ci}/\text{m}^3$) from Table A.1-2.

1.1 = Conversion factor to mrem skin dose per mrad air dose.

ATTACHMENT A
(Page 61 of 160)
OFFSITE DOSE CALCULATION MANUAL

M_i = Air dose factor due to gamma emissions from isotope i (mrad/yr per $\mu\text{Ci}/\text{m}^3$) from Table A.1-2.

The factors SF, AF, c , $(\overline{X/Q})$ and Q_i are as defined in Section 3.4.4.1.

The results of equations from Sections 3.4.4.1 and 3.4.4.2 are compared to determine the smaller setpoint. The actual monitor setpoint is the lower of the two values.

A pre-release isotopic analysis is performed for batch releases from Waste Gas Decay Tanks and Containment Building purges to determine the identity and quantity of the principal radionuclides. The appropriate alarm/trip setpoint(s) are adjusted accordingly to ensure that the limits of 3.1 are not exceeded.

3.4.4.3 Alert Alarm Setpoint Calculations

The Noble Gas Alert Alarm for the Plant Unit Vent (O-GT-RE-21) and Radwaste Building Exhaust Monitor (O-GH-RE-10), is set to alert operators to that average concentration which if maintained for a full year would result in the 10 CFR 50, Appendix I Annual Dose Guidelines being reached. Section 3.2.1 limits the annual dose due to noble gases to < 10 mrad for gamma radiation and ≤ 20 mrad for beta radiation. Section 3.2.2 limits the annual dose to a MEMBER OF THE PUBLIC from Iodine-131, Iodine-133, tritium and all radionuclides in particulate form with half-lives greater than 8 days in gaseous effluents to ≤ 15 mrem to any organ. These two sections contain the annual dose limits due to gaseous releases found in 10 CFR 50, Appendix I.

3.4.4.3.1 Noble Gas Alert Alarm Setpoint Calculation

The alert alarm setpoint is the lesser of

$$S_\gamma \leq (SF \times AF) \times D_\gamma \times R_\gamma$$

$$S_\beta \leq (SF \times AF) \times D_\beta \times R_\beta$$

Where:

S_γ = Monitor setpoint based on gamma radiation.

ATTACHMENT A
(Page 62 of 160)
OFFSITE DOSE CALCULATION MANUAL

D_γ = Limit of 10 mrad/yr conservatively interpreted as a continuous release over a one year period.

R_γ = Monitor response per mrad/yr determined according to:

$$R_\gamma = \frac{c}{\left(\overline{X/Q} \sum_i M_i \times Q_i \right)}$$

Where:

M_i = Gamma air dose factor (mrad/yr per $\mu\text{Ci}/\text{m}^3$).
See Table A.1-2.

S_β = Monitor setpoint based on beta radiation.

D_β = Limit of 20 mrad/yr conservatively interpreted as a continuous release over a one year period.

R_β = Monitor response per mrad/yr determined according to:

$$R_\beta = \frac{c}{\left(\overline{X/Q} \sum_i N_i \times Q_i \right)}$$

Where:

N_i = Beta air dose factor (mrad/yr per $\mu\text{Ci}/\text{m}^3$).
See Table A.1-2.

A semi-fixed alert alarm setpoint for the Plant Unit Vent Monitor (O-GT-RE-21) and Radwaste Building Vent Monitor (O-GH-RE-10) is calculated using the following:

$$\text{Setpoint } (\mu\text{Ci/cc}) = \left(\frac{(10 \text{ mrad/yr})(.85)(AF)}{\left(\overline{X/Q} \sum_i P_i \times M_i \times Q \right)} \right)$$

Where:

P_i = Fractional value of isotope expected, C_i/C_T .

ATTACHMENT A
(Page 63 of 160)
OFFSITE DOSE CALCULATION MANUAL

Where:

C_i = Concentration in $\mu\text{Ci}/\text{cc}$ of isotope.

C_T = Total Gaseous Activity from USAR Table 11.1-1

AF = Either unit vent flow or Radwaste Building vent flow divided by the combined flow of the unit vent and Radwaste Building vent.

Q = Vent flow rate in cc/sec .

Isotopes used and P_i values are as follows:

<u>ISOTOPE</u>	<u>P_i</u>
Kr-85M	.018
Kr-87	.010
Kr-88	.033
Xe-133M	.017
Xe-133	.851
Xe-135	.051

Should this semi-fixed alert alarm cause a continuous alarm condition, then actual setpoints will be calculated.

3.4.4.4 Particulate And Iodine Alarm Setpoints

Setpoints for the gaseous effluent particulate and iodine channels are set using Cs-137 MPC for particulates and I-131 MPC for iodines. The following is the calculation used:

$$\text{Setpoint } (\mu\text{Ci}/\text{cc}) = \frac{(\text{MPC}_i)(\text{AF})(\text{SF})}{(Q)(\bar{X}/Q)}$$

Where:

$$\begin{aligned} \text{MPC}_i &= 5 \times 10^{-10} \mu\text{Ci}/\text{cc} \text{ for Cs-137} \\ &= 1 \times 10^{-10} \mu\text{Ci}/\text{cc} \text{ for I-131} \end{aligned}$$

ATTACHMENT A
(Page 64 of 160)
OFFSITE DOSE CALCULATION MANUAL

AF = as defined previously

SF = .0625 for I-131 *

= .9375 for Cs-137 *

*derived from ratio of isotope activity (either I-131 or Cs-137) to sum of activity of Cs-137 and I-131 found in USAR Table 11.1-1 for reactor coolant.

Q = Vent flow in M³/sec

This will provide the hi alarm setpoint. The alert alarm setpoint is 10% of the hi alarm setpoint.

ATTACHMENT A
(Page 65 of 160)
OFFSITE DOSE CALCULATION MANUAL

4.0 Total Dose

The annual (Calendar year) dose or dose commitment to any MEMBER OF THE PUBLIC due to releases of radioactivity and to radiation from uranium fuel cycle sources shall be limited to less than or equal to 25 mrems to the whole body or any organ, except the thyroid, which shall be limited to less than or equal to 75 mrems.

4.1 Remedial Action

With the calculated doses from the release of radioactive materials in liquid or gaseous effluents exceeding twice the limits of Section 2.2a, 2.2b, 3.2.1a, 3.2.1b, 3.2.2a and 3.2.2b calculation should be made including direct radiation contributions from the units and from outside storage tanks to determine whether the above limits of Section 4.0 above has been exceeded. If such is the case, prepare and submit to the Commission within 30 days, a special report that defines the corrective action to be taken to reduce subsequent releases to prevent recurrence of exceeding the above limits. This special report, as defined in 10 CFR 20.405e and 10CFR20.2203, shall include an analysis that estimates the radiation exposure (dose) to a MEMBER OF THE PUBLIC from uranium fuel cycle sources, including all effluent pathways and direct radiation, for the calendar year that includes the release(s) covered by this report. It shall also describe levels of radiation and concentrations of radioactive material involved, and the cause of the exposure levels or concentrations. If the estimated dose(s) exceeds the above limits, and if the release condition resulting in violation of 40 CFR Part 190 has not already been corrected, the special report shall include a request for a variance in accordance with the provisions of 40 CFR Part 190. Submittal of the report is considered a timely request, and a variance is granted until staff action on the request is complete.

Revision: 4	OFFSITE DOSE CALCULATION MANUAL	AP 07B-003
Reference Use		Page 71 of 165

ATTACHMENT A
(Page 66 of 160)
OFFSITE DOSE CALCULATION MANUAL

4.2 Surveillance Requirements

- 4.2.1 Cumulative dose contributions from liquid and gaseous effluents shall be determined in accordance with the methodology of Sections 2.2 and 3.2 at least once per 31 days when the release of radioactive materials in liquid or gaseous effluents exceed twice the limits of Section 2.2a, 2.2b, 3.2.1a, 3.2.1b, 3.2.2a and 3.2.2b. Otherwise, no further evaluation is required.
- 4.2.2 Cumulative dose contribution from direct radiation from the reactor unit and from Radwaste storage tanks shall be determined utilizing the results of routine plane perimeter surveys, TLD data or a combination of both, when necessary. This requirement is applicable only under conditions set forth in the remedial action above.

ATTACHMENT A
(Page 67 of 160)
OFFSITE DOSE CALCULATION MANUAL

6.0 Bases

The bases contained on the succeeding pages summarizes the general requirements of Section 2.0, 3.0, 4.0 and 5.0 of the ODCM.

Section 2.0 Liquid Effluents

Section 2.1 Concentration

This section is provided to ensure that the concentration of radioactive materials released in liquid waste effluents to UNRESTRICTED AREAS will be less than the concentration levels specified in 10 CFR Part 20, Appendix B, Table 2, Column 2. This limitation provides additional assurance that the levels of radioactive materials in bodies of water in UNRESTRICTED AREAS will result in exposures within: (1) the Section II. A design objective of Appendix I, 10 CFR Part 50, to a MEMBER OF THE PUBLIC, and (2) the limits of 10 CFR Part 20.1301(e) to the population. The concentration limit for dissolved or entrained noble gases are based upon the assumption that Xe-135 is the controlling radioisotope and its ECL in air (submersion) was converted to an equivalent concentration in water using the methods described in International Commission on Radiological Protection (ICRP) Publication 2.

The required detection capabilities for radioactive materials in liquid waste samples are tabulated in terms of the lower limits of detection (LLDs). Detailed discussion of the LLD, and other detection limits can be found in HASL Procedures Manual, HASL-300 (revised annually), Currie, L.A., "Limits for Qualitative Detection and Quantitative Determination - Application to Radiochemistry," Anal. Chem. 40, 586-93 (1968), and Hartwell, J.K., "Detection Limits for Radioanalytical Counting Techniques," Atlantic Richfield Hanford Company Report ARH-SA-215 (June 1975).

ATTACHMENT A
(Page 68 of 160)
OFFSITE DOSE CALCULATION MANUAL

Section 2.2 Dose

This section is provided to implement the requirements of Section II.A, III.A and IV.A of Appendix I, 10 CFR Part 50. The remedial action implements the guides set forth in Section II.A of Appendix I and provides the required operating flexibility and at the same time implement the guides set forth in Section IV.A of Appendix I to assure that the releases of radioactive material in liquid effluents to UNRESTRICTED AREAS will be kept "as low as is reasonably achievable." Also, for fresh water sites with drinking water supplies that can be potentially affected by plant operations, there is reasonable assurance that the operation of the facility will not result in radionuclide concentrations in the finished drinking water that are in excess of the requirements of 40 CFR Part 141. The dose calculation methodology and parameters in the ODCM implement the requirements in Section III.A of Appendix I which specify that conformance with the guides of Appendix I be shown by calculational procedures based on models and data, such that the actual exposure of a MEMBER OF THE PUBLIC through appropriate pathways is unlikely to be substantially underestimated. The equations specified in the ODCM for calculating the doses due to the actual release rates of radioactive materials in liquid effluents are consistent with the methodology provided in Regulatory Guide 1.109, "Calculation of Annual Doses to Man from Routine Releases of Reactor Effluents for the Purpose of Evaluating Compliance with 10 CFR Part 50, Appendix I, "Revision 1, October 1977 and Regulatory Guide 1.113, "Estimating Aquatic Dispersion of Effluents from Accidental and Routine Reactor Releases for the Purpose of Implementing Appendix I," April 1977.

Revision: 4	OFFSITE DOSE CALCULATION MANUAL	AP 07B-003
Reference Use		Page 74 of 165

ATTACHMENT A
(Page 69 of 160)
OFFSITE DOSE CALCULATION MANUAL

Section 2.3 Liquid Radwaste Treatment System

The OPERABILITY of the Liquid Radwaste Treatment Systems ensures that this system will be available for use whenever liquid effluents require treatment prior to release to the environment. The requirement that the appropriate portions of this system be used when specified provides assurance that the releases of radioactive materials in liquid effluents will be kept "as low as is reasonably achievable." This section implements the requirements of 10 CFR Part 50.36a, General Design Criterion 60 of Appendix A to 10 CFR Part 50 and design objective given in Section II.D of Appendix I to 10 CFR Part 50. The specified limits governing the use of appropriate portions of the Liquid Radwaste Treatment System were specified as a suitable fraction of the dose design objective set forth in Section II.A of Appendix I, 10 CFR Part 50, for liquid effluents.

Section 2.4 Radioactive Liquid Effluent Monitoring Instrumentation

The radioactive liquid effluent instrumentation is provided to monitor and control, as applicable, the releases of radioactive materials in liquid effluents during actual or potential releases of liquid effluents. The Alarm/Trip Setpoints for these instruments shall be calculated and adjusted in accordance with the methodology and parameters in the ODCM to ensure that the alarm/trip will occur prior to exceeding the limits of 10 CFR Part 20. The OPERABILITY and use of this instrumentation is consistent with the requirements of General Design Criteria 60, 63, and 64 of Appendix A to 10 CFR Part 50.

ATTACHMENT A
(Page 70 of 160)
OFFSITE DOSE CALCULATION MANUAL

Section 3.0 Gaseous Effluents

Section 3.1 Dose Rate

This section is provided to ensure that the dose at any time at and beyond the SITE BOUNDARY from gaseous effluents from all units on the site will be within the annual dose limits of 10 CFR Part 20 to UNRESTRICTED AREAS (USAR, Chapter 11). The annual dose limits are the doses associated with the concentrations of 10 CFR Part 20, Appendix B, Table II, Column 1. These limits provide reasonable assurance that radioactive material discharged in gaseous effluents will not result in the exposure of a MEMBER OF THE PUBLIC in an UNRESTRICTED AREA, either within or outside the SITE BOUNDARY, to annual average concentrations exceeding the limits specified in Appendix B, Table II of 10 CFR Part 20 (10 CFR 20.106(b)). For MEMBERS OF THE PUBLIC who may at times be within the SITE BOUNDARY, the occupancy of that MEMBER OF THE PUBLIC will usually be sufficiently low to compensate for any increase in the atmospheric diffusion factor above that for the SITE BOUNDARY. The specified release rate limits restrict, at all times, the corresponding gamma and beta dose rates above background to a MEMBER OF THE PUBLIC at or beyond the SITE BOUNDARY to less than or equal to 500 mrems/year to the whole body or to less than or equal to 3000 mrems/year to the skin. These release rate limits also restrict, at all times the corresponding thyroid dose rate above background to a child via the inhalation pathway to less than or equal to 1500 mrems/year. 6/01

The required detection capabilities for radioactive materials in gaseous waste samples are tabulated in terms of the lower limits of detection (LLDs). Detailed discussion of the LLD, and other detection limits can be found in HASL Procedures Manual, HASL-300 (revised annually), Currie, L.A., "Limits for Qualitative Detection and Quantitative Determination - Application to Radiochemistry," Anal. Chem 40, 586-93 (1968), and Hartwell, J.K., "Detection Limits for Radioanalytical Counting Techniques," Atlantic Richfield Hanford Company Report ARH-SA-215 (June 1975).

Revision: 4	OFFSITE DOSE CALCULATION MANUAL	AP 07B-003
Reference Use		Page 76 of 165

ATTACHMENT A
(Page 71 of 160)
OFFSITE DOSE CALCULATION MANUAL

Section 3.2.1 Dose - Noble Gases

This section is provided to implement the requirements of Section II.B, III.A and IV.A of Appendix I, 10 CFR Part 50. The remedial action implements the guides set forth in Section II.B of Appendix I and provides the required operating flexibility and at the same time implement the guides set forth in Section IV.A of Appendix I to assure that the releases of radioactive material in gaseous effluents to UNRESTRICTED AREAS will be kept "as low as is reasonably achievable." The surveillance requirements implement the requirements in Section III.A of Appendix I that conformance with the guides of Appendix I be shown by calculational procedures based on models and data such that the actual exposure of a MEMBER OF THE PUBLIC through appropriate pathways is unlikely to be substantially underestimated. The dose calculation methodology and parameters established in the ODCM for calculating the doses due to the actual release rates of radioactive materials in gaseous effluents are consistent with the methodology provided in Regulatory Guide 1.109, "Calculation of Annual Doses to Man from Routine Releases of Reactor Effluents for the Purpose of Evaluating Compliance with 10 CFR Part 50, Appendix I," Revision 1, October 1977 and Regulatory Guide 1.111, "Methods for Estimating Atmospheric Transport and Dispersion of Gaseous Effluents in Routine Releases from Light-Water Cooled Reactors," Revision 1, July 1977. The ODCM equations provided for determining the air doses at and beyond the SITE BOUNDARY are based upon either the historical average or real time atmospheric conditions.

Revision: 4	OFFSITE DOSE CALCULATION MANUAL	AP 07B-003
Reference Use		Page 77 of 165

ATTACHMENT A
(Page 72 of 160)
OFFSITE DOSE CALCULATION MANUAL

Section 3.2.2 Dose - Iodine-131 and 133, Tritium and Radioactive Material in Particulate Form

This section is provided to implement the requirements of Sections II.C, III.A and IV.A of Appendix I, 10 CFR Part 50. The remedial actions are the guides set forth in Section II.C of Appendix I, and provide the required operating flexibility and at the same time implement the guides set forth in Section IV.A of Appendix I to assure that the releases of radioactive materials in gaseous effluents to UNRESTRICTED AREAS will be kept "as low as is reasonably achievable." The ODCM calculational methods specified in the surveillance requirements implement the requirements in Section III.A of Appendix I that conformance with the guides of Appendix I be shown by calculational procedures based on models and data, such that the actual exposure of a MEMBER OF THE PUBLIC through appropriate pathways is unlikely to be substantially underestimated. The ODCM calculational methodology and parameters for calculating the doses due to the actual release rates of the subject materials are consistent with the methodology provided in Regulatory Guide 1.109, "Calculational of Annual Doses to Man from Routine Releases of Reactor Effluents for the Purpose of Evaluating Compliance with 10 CFR Part 50, Appendix I," Revision 1, October 1977 and Regulatory Guide 1.111, "Methods for Estimating Atmospheric Transport and Dispersion of Gaseous Effluents in Routine Releases from Light-Water-Cooled Reactors," Revision 1, July 1977. These equations also provide for determining the actual doses based upon either the historical average or real time conditions. The release rate limits for Iodine-131 and 133, tritium, and radionuclides in particulate form with half lives greater than 8 days are dependent upon the existing radionuclide pathways to man, in the areas at and beyond the SITE BOUNDARY. The pathways that were examined in the development of these calculations were: (1) individual inhalation of airborne radionuclides, (2) deposition of radionuclides onto green leafy vegetation with subsequent consumption by man, (3) deposition onto grassy areas where milk animals and meat producing animals graze with consumption of the milk and meat by man, (4) deposition on the ground with subsequent exposure of man.

Revision: 4	OFFSITE DOSE CALCULATION MANUAL	AP 07B-003
Reference Use		Page 78 of 165

ATTACHMENT A
(Page 73 of 160)
OFFSITE DOSE CALCULATION MANUAL

Section 3.3 Gaseous Radwaste Treatment System

The OPERABILITY of the WASTE GAS HOLDUP SYSTEM and the VENTILATION EXHAUST TREATMENT SYSTEM ensures that the systems will be available for use whenever gaseous effluents require treatment prior to release to the environment. The requirement that the appropriate portions of this system be used when specified provides reasonable assurance that the releases of radioactive materials in gaseous effluents will be kept "as low as is reasonably achievable." This section implements the requirements of 10 CFR 50.36a, General Design Criterion 60 of Appendix A to 10 CFR Part 50 and the design objectives given in Section II.D of Appendix I to 10 CFR Part 50. The specified limits governing the use of appropriate portions of the systems were specified as a suitable fraction of the dose design objectives set forth in Section II.B and II.C of Appendix I, 10 CFR Part 50, for gaseous effluents.

**Section 3.4 Radioactive Gaseous Effluent Monitoring
Instrumentation**

The radioactive gaseous effluent instrumentation is provided to monitor and control, as applicable, the releases of radioactive materials in gaseous effluents during actual or potential releases of gaseous effluents. The Alarm/Trip Setpoints for these instruments shall be adjusted to values calculated in accordance with the methodology and parameters in the ODCM to ensure that the alarm/trip will occur prior to exceeding the limits of 10 CFR Part 20. The OPERABILITY and use of this instrumentation is consistent with the requirements of General Design Criteria 60, 63 and 64 of Appendix A to 10 CFR Part 50. The sensitivity of any noble gas activity monitor used to show compliance with the gaseous effluent release requirements of Section 3.2 shall be such that concentrations as low as 1×10^{-6} $\mu\text{Ci/cc}$ are measurable.

Revision: 4	OFFSITE DOSE CALCULATION MANUAL	AP 07B-003
Reference Use		Page 79 of 165

ATTACHMENT A
(Page 74 of 160)
OFFSITE DOSE CALCULATION MANUAL

Section 4.0 Total Dose

This section is provided to meet the dose limitations of 40 CFR Part 190 that have been incorporated into 10 CFR Part 20 by 46 FR 18525. The section requires the preparation and submittal of a special report whenever the calculated doses due to releases of radioactivity and the radiation from uranium fuel cycle sources exceed 25 mremS to the whole body or any organ, except the thyroid, which shall be limited to less than or equal to 75 mremS. For sites containing up to four reactors, it is highly unlikely that the resultant dose to a MEMBER OF THE PUBLIC will exceed the dose limits of 40 CFR Part 190 if the individual reactors remain within twice the dose design objectives of Appendix I, and if direct radiation doses from the reactor Units and from outside storage tanks are kept small. The Special Report will describe a course of action that should result in the limitation of the annual dose to a MEMBER OF THE PUBLIC to within the 40 CFR Part 190 limits. For the purposes of the Special Report, it may be assumed that the dose commitment to the MEMBER OF THE PUBLIC from other uranium fuel cycle sources is negligible, with the exception that dose contributions from other nuclear fuel cycle facilities at the same site or within a radius of 8 km must be considered. If the dose to any MEMBER OF THE PUBLIC is estimated to exceed the requirements of 40 CFR Part 190, the Special Report with a request for a variance (provided the release conditions resulting in violation of 40 CFR Part 190 have not already been corrected), in accordance with the provisions of 40 CFR 190.11, 10 CFR 20.405c, and 10 CFR 20.2203, is considered to be a timely request and fulfills the requirements of 40 CFR Part 190 until NRC staff action is completed. The variance only relates to the limits of 40 CFR Part 190, and does not apply in any way to the other requirements for dose limitation of 10 CFR Part 20. An individual is not considered a MEMBER OF THE PUBLIC during any period in which he/she is engaged in carrying out any operation that is part of the nuclear fuel cycle.

ATTACHMENT A
(Page 75 of 160)
OFFSITE DOSE CALCULATION MANUAL

7.2 Annual Radioactive Effluent Release Report

The Annual Radioactive Effluent Release Report shall include a summary of the quantities of radioactive liquid and gaseous effluents and solid waste released from the Unit as outlined in Regulatory Guide 1.21, "Measuring, Evaluating, and Reporting Radioactivity in Solid Wastes and Releases of Radioactive Materials in Liquid and Gaseous Effluents from Light Water-Cooled Nuclear Power Plants," Revision 1, June 1974, with data summarized on a quarterly basis following the format of Appendix B thereof. For solid wastes, the format for Table 3 in Appendix B shall be supplemented with three additional categories: class of solid waste (as defined by 10 CFR Part 60), type of container (e.g., LSA, Type A, Type B, Large Quantity), and SOLIDIFICATION agent or absorbent (e.g., cement, urea formaldehyde).

The Annual Radioactive Effluent Release Report to be submitted before May 1 of each year shall also include an annual summary of hourly meteorological data collected over the previous year. This annual summary may be either in the form of an hour-by-hour listing on magnetic tape of wind speed, wind direction, and atmospheric stability, and precipitation (if measured), or in the form of joint frequency distributions of wind speed, wind direction, and atmospheric stability.* This same report shall include an assessment of the radiation doses due to the radioactive liquid and gaseous effluents released from the Unit or Station during the previous calendar year. This same report shall also include an assessment of the radiation doses from radioactive liquid and gaseous effluents to MEMBERS OF THE PUBLIC due to their activities inside the SITE BOUNDARY during the report period. All assumptions used in making these assessments, i.e., specific activity, exposure time and location, shall be included in these reports. Historical average meteorological conditions or the meteorological conditions concurrent with the time of release of radioactive materials in gaseous effluents, as determined by sampling frequency and measurement, shall be used for determining the gaseous pathway doses. The assessment of radiation doses shall be performed in accordance with the methodology and parameters in the ODCM.

ATTACHMENT A
(Page 76 of 160)
OFFSITE DOSE CALCULATION MANUAL

The Annual Radioactive Effluent Release Report to be submitted before May 1 of each year shall also include an assessment of radiation doses to the likely most exposed MEMBER OF THE PUBLIC from reactor releases and other nearby uranium fuel cycle sources, including doses from primary effluent pathways and direct radiation, for the previous calendar year to show conformance with 40 CFR Part 190, "Environmental Radiation Protection Standards for Nuclear Power Operation." Acceptable methods for calculating the dose contribution from liquid and gaseous effluents are given in Regulatory Guide 1.109, Rev. 1, October 1977.

The Annual Radioactive Effluent Release Report shall include:

- a. A list and description of unplanned releases from the site to UNRESTRICTED AREAS of radioactive materials in gaseous and liquid effluents made during the reporting period.

*In lieu of submission with the Annual Radioactive Effluent Release Report, the licensee has the option of retaining this summary of required meteorological data on site in a file that shall be provided to the NRC upon request.

- b. Any changes made during the reporting period to the ODCM, pursuant to Technical Specification 5.5.1.
- c. Major changes to the Radwaste Treatment Systems for the period in which the evaluation was reviewed and accepted by the PSRC. The discussion of each change shall contain:
 - 1) A summary of the evaluation that led to the determination that the change could be made in accordance with 10 CFR 50.59;
 - 2) Sufficient detailed information to totally support the reason for the change without benefit of additional and supplemental information;
 - 3) A detailed description of the equipment, components, and processes involved and the interfaces with other plant systems.

ATTACHMENT A
(Page 77 of 160)
OFFSITE DOSE CALCULATION MANUAL

- 4) An evaluation of the change which shows the predicted releases of radioactive materials in liquid and gaseous effluents and/or quantity of solid waste that differ from those previously predicted in the license application and amendments thereto;
 - 5) An evaluation of the change, which shows the expected maximum exposures to a MEMBER OF THE PUBLIC in the UNRESTRICTED AREA and to the general population that differ from those previously estimated in the license application and amendments thereto;
 - 6) A comparison of the predicted releases of radioactive materials, in liquid and gaseous effluents and in solid waste, to the actual releases for the period prior to when the changes are to be made;
 - 7) An estimate of the exposure to plant operating personnel as a result of the change; and
 - 8) Documentation of the fact that the change was reviewed and found acceptable by the PSRC.
- d. A listing of new locations for dose calculations identified by the Land Use Census,
 - e. A description of the events leading to liquid holdup tanks or gas storage tanks exceeding the limits of TR 3.10.1 OR TSR 3.10.3.1.
 - f. An explanation as to why the inoperability of a liquid or gaseous effluent monitoring instrumentation was not corrected within the time specified.
 - g. A description of the events leading to a missed sample required by Table 2-1 or 3-1.