Bryce L. Shriver Senior Vice President and Chief Nuclear Officer PPL Susquehanna, LLC 769 Salem Boulevard Berwick, PA 18603 Tel 570.542 3120 Fax 570 542.1504 blshriver@pplweb.com



APR 2 8 2003

U. S. Nuclear Regulatory Commission Attn: Document Control Desk Mail Station OP1-17 Washington, DC 20555

SUSQUEHANNA STEAM ELECTRIC STATION ANNUAL PERSONNEL EXPOSURE REPORT PLA-5616

Docket Nos. 50-387 and 50-388

In accordance with the Susquehanna SES Unit 1 and 2 Technical Specifications, Section 5.6.1, the attached annual personnel exposure report is provided for calendar year 2002 for SSES Units 1 and 2. The report includes only those individuals whose cumulative dose for calendar year 2002 was greater than 100 mrem.

Also, in accordance with Regulation Guide 1.16, Special Maintenance is described as the performance of all plant modifications or changeouts of any plant equipment, piping, etc. that were not a part of the original plant.

Please contact Mr. Duane L. Filchner at (610) 774-7819 if you have any questions concerning this submittal.

Sincerely,

B. L. Shriver

Attachment

copy: NRC Region I

Mr. R. V. Guzman, NRC Project Manager Mr. S. Hansell, NRC Sr. Resident Inspector

Mr. R. Janati, DEP/BRP

JE56

Attachment 1 to PLA-5616 Annual Personnel Exposure Report for Calendar Year 2002

ANNUAL REG. GUIDE 1.16 NUMBER OF PERSONNEL AND PERSON-REM BY WORK CODE AND JOB 12002

Work Code	Job Function Code	Static Personnel		Utilitv Personnel Person-Rem	Contrac Personnel I			tal erson-Rem
Reactor Operations And	Maintenance	5	0.963		1	0.250	6	1.213
Surv	Operating	66	14.639				66	14.639
	Health Physics	23	9.696		11	3.289	34	12.985
	Supervisory	5	0.993		4	1.049	9	2.042
	Engineering							
	**** Total ****	99	26.291		16	4.588	115	30.879
Routine Maintenance	Maintenance	176	55.488		163	43.925	339	99.413
	Operating	37	9.252				37	9.252
	Health Physics	30	11.253		32	14.342	62	25.595
	Supervisory	14	2.581		15	5.829	29	8.410
	Engineering	2	0.310		40	12.718	42	13.028
	**** Total ****	259	78.884		250	76.814	509	155.698
In Service Inspection	Maintenance	11	3.608		8	1.289	19	4.897
	Operating	1	0.341				1	0.341
	Health Physics							
	Supervisory							
	Engineering				6	1.458	6	1.458
	**** Total ****	12	3.949		14	2.747	26	6.696
Special Maintenance	Maintenance	4	0.867		23	5.344	27	6.211
	Operating							
	Health Physics							
	Supervisory							
	Engineering				1	0.218	1	0.218
	**** Total ****	4	0.867		24	5.562	28	6.429
Waste Processing	Maintenance	4	1.518		4	0.632	8	2.150
	Operating				1	1.050	1	1.050
	Health Physics	4	1.711		1	0.228	5	1.939
	Supervisory							
	Engineering							
	THE TOTAL THE	8	3.229		6	1.910	14	5.139.
Refueling	Maintenance	2	0.361				2	0.361
	Operating	5	0.641				5	0.641
	Health Physics							
	Supervisory	1	0.153				1	0.153
	Engineering							
	**** Total ****	8	1.155				8	1.155
	TOTAL							
	Maintenance	202 62.805			199	51.440	4	01 114.245
	Operating	109 2	4.873		1	1.050) 1	10 25.923
	Health Physics		22.660		44	17.859	1	01 40.519
	Supervisory	20	3.727		19	6.878	3	39 10.605
	Engineering	2	0.310		47			49 14.704
	**** Grand Total ****	390 11	4.375		310	91.621	7	205.996
