CERTIFICATE

This is to certify that the attached proceedings before the United States Nuclear Regulatory Commission in the matter of:

Name of Proceeding: Advisory Committee on

Reactor Safeguards Materials and Metallurgy & Plant Operations

Joint Subcommittee Meeting

Docket Number: n/a Location: Rockville, MD

were held as herein appears, and that this is the original transcript thereof for the file of the United States Nuclear Regulatory Commission taken by me and, thereafter reduced to typewriting by me or under the direction of the court reporting company, and that the transcript is a true and accurate record of the foregoing proceedings.

ham

Matt Needham Official Reporter Neal R. Gross & Co., Inc.

NEAL R. GROSS COURT REPORTERS AND TRANSCRIBERS 1323 RHODE ISLAND AVE., N W WASHINGTON, D C 20005-3701

(202) 234-4433

www nealrgross com

ADVISORY COMMITTEE ON REACTOR SAFEGUARDS MATERIALS & METALLURGY AND PLANT OPERATIONS SUBCOMMITTEES VHP CRACKING AND RPV HEAD DEGRADATION ROOM T-2B3, 11545 ROCKVILLE PIKE, ROCKVILLE, MARYLAND

1

Ł

April 22, 2003

- PROPOSED AGENDA -

	SUBJECT	PRESENTER	TIME
Ι.	Introductory Remarks Subcommittee Chairmen	F.P. Ford, ACRS J.D. Sieber, ACRS	8:30 - 8:35 a.m.
11.	Overview of NRC Activities	Richard Barrett, NRR	8:35 - 8:50 a.m.
111.	Industry Positions on RPV Head and VHP Nozzle Inspections	Christine King, MRP Larry Mathews, MRP Craig Harrington, MRP Tom Alley, MRP	8:50 - 10:15 a.m.
		*****BREAK*****	10:15 - 10:30 a.m.
IV.	Industry Positions on RPV Head and VHP Nozzle Inspections (Continued)	Christine King, MRP Larry Mathews, MRP Craig Harrington, MRP Tom Alley, MRP	10:30 - 12:00 noon
		*****LUNCH*****	12:00 - 1:00 p.m.
V.	Industry Positions on RPV Head and VHP Nozzle Inspections (Continued)	Christine King, MRP Larry Mathews, MRP Craig Harrington, MRP Tom Alley, MRP	1:00 - 2:30 p.m.
		*****BREAK*****	2:30 - 2:45 p.m.
VI.	NRC Sponsored Research	William Cullen, RES	2:45 - 4:45 p.m.
VII.	General Discussion and Adjour	rnment	4:45 - 5:30 p.m.
Note:	Presentation time should not ex	xceed 50% of the total time alloc	ated for a specific item.

Number of copies of presentation materials to be provided to the ACRS - 40.

ACRS CONTACT: Maggalean W. Weston, <u>mww@nrc.gov</u> or (301) 415-3151.

.







The overview table graphically shows:
The extent to which the fleet has been inspected
The extent of detected cracking, leakage, and wastage correlated with effective degradation time (EDYs) and position on the head
Key operating and design data
Refueling outage schedule and current head replacement plans
The overview table complements more detailed outage-specific and defect-specific inspection results tables that are used to generate statistical (i.e., Weibull) fits
The MRP plans to release a revision to the table at the end of each outage season

													·				•					· • •												÷ 7	÷									
-	1.00																				1.1	·									- x	A 19		- A - A		1.1.1						1.0		10.0
																	A	1.6	· · · ·	100		- C C												10.00								1.00		
						N 1													·				1.00														100	. A		A 4		10.00		100
	1.40									And James			A	÷												- C.			2.1.2						· ·			and the second		· · ·		1.00	· · ·	1.5
	1			· • . * *			• •			1000					- G - S						×										× :							÷.		39.15				100
					e			10.0												st		- N - 1		- 1.1			- 61					N		Sec. 1		- A. I						100	1.00	22.0
				1.0		· · · ·		·			1.12			· · ·		- e - e - e - e - e - e - e - e - e - e													., 1 :	5 m P			- C -		- A.	S. 199	1		1.1					
					- · ·		- 1 C													- i - i - i - i - i - i - i - i - i - i	1.1.2	1	1.1.1.1								10.00				- 1 - C	- 4 a f - 4	· • • •			10-5 .				
													- a-			· · · ·									· . ·					1.00	- 51				10.00			24.40						
			C				1.00	1.1.1	- A.A.A.A.A.A.A.A.A.A.A.A.A.A.A.A.A.A.A.	_		· · ·			5 C 1							0.53	1 C 1 Z		1.50	1.12		1.11			· · ·			100.00	1.1	1.1				1.1		A 19 1		
							. 2 .	1.22		100							100	3 H I				S 27		S											1.1.1	1.11	63.44				·	10.00	. TY .	
											- T. P.								. 100					100													- C. I		•			100.00		
	1.1					100				2.00	6 E I				1.4 1.						1.1	÷ 14.				1			1.1.2		1.4.1	A	1 1		12.0	1.0	1.0	1.1	- 14 C	11100	c	· · · ·		
e 1		1.5								- 2.5		· · · ·	/	1.1.1				e 1		- e e e e e		÷ *								1.2	· 64.1			1.46.7									1.1.1	100
				1. 1. 1	1.1					2.0					1.000								1.1		-			100	1.0							1.1.1				G.A	1.0			2.1

Nozzles Inspecied by Non-Visual No. Leaking No. Cracked Na Nozzles with Base Na. Nottles with Weld Number of Norsles/ Welds Nottles/ Welds Notiles on Head ۸a. No. Notiles wwh Axial Cracks Northes with Circ Cracks % of Total Inspected Cracked X of Total Inspected Totel X Appres, EDYs at Leaking CEDM CRDM Metal Cracks Metal Cracks NSSS Total Total ž Supplier B&W Unit Date Inspection 196 I ANO I 2 ANO I 3 Cook 2 Mar 2001 Oct 2002 Jan 2002 69 69 78 1 100 0°. 1 14% 0 0 0% 1 14% 69 100 0% 78 100 0% 14% 1 100 04 69 B&W W 211 69 78 R 116% 2 2.6% . ¢ Jan 2002 Oct-2001 Apr 2002 Feb-2002 Oct 2001 Nov 2001 B& W B& W 4 Crystal River 3 5 Davis-Besse 16.2 69 69 69 69 9 13 0% 69 100 0% 6 Millstone 2 7 North Anna 1 8 North Anna 2
 69
 8
 77
 77
 100 0%

 65
 30
 46.2%
 65
 3
 46%
 CE 112 1 65 W 20.0 65
 65
 3
 4 6%

 65
 65
 100 0%

 69
 18
 26 1%

 69
 5
 7 2%

 69
 4
 5.8%

 69
 69
 18

 69
 8
 26 1%

 69
 4
 5.8%

 69
 8
 26 1%

 69
 18
 26 1%

 69
 27.5 4%
 55

 65
 16
 24 6%

 69
 12
 17 4%
 9 North Anna 2 10 Oconee 1 Sep 2002 65 Nov-2000 69 W 197 218 232 222 237 217 225 191 47 B&W B&W B&W B&W B&W Mar 2002 69 Apr 2001 69 Oct-2002 69 11 Oconee 1 12 Oconee 2 13 Oconee 2 15 IG Feb 2001 69 Nov-2001 69 Oct 2003 65 14 Oconce 1 15 Oconce 3 10 10 B&W 22.5 W 191 B&W 181 7 16 Surry 1 17 TMI 1 Oct-2001 69 7 Totals fur Inspections Since First U.S. Leakage (11/2000) 3871 1090 94 5055 1462 28 9% 47 3.2% 120 8 2% 12 75 71 \$9 NOTE The table does not reflect the small-diameter thermocouple nozzles found to be cracked and leaking at Oconec 1 and 1 M1 1 (These are the only two plants that have this type of nozzle) ere 🛵

٠

ACRS Subcommittee Meeting - Feb 18-19, 2003 5

÷ --

46- 994 CM

.

3 .53	and a standard and a standard and a standard and a standard a standard a standard a standard a standard a stand	1.24 1.24 2.27 2.27 2.27	BN	1V	Nozzle Tu	be ET/UT	Weld	ET/PT
	EDY at Next RFO	No. Units	No. Units 100% Inspected	No. Nozzles Inspected	No. Units 100% Inspected	No. Nozzles Inspected	No. Units 100% Inspected	No. Welds Inspected
-	>12 EDY	30	27 (90%)	1898 (92%)	13 (43%)	1016 (49%)	3 (10%)	338 (16%)
_	8–12 EDY	15	8 (53%)	510 (49%)	4 (27%)	354 (34%)	0 (0%)	61 (6%)
_	< 8 EDY	24	17 (71%)	1327 (71%)	0 (0%)	92 (5%)	0 (0%)	l (0%)
	Totals	69	52 (75%)	3735 (75%)	17 (25%)	1462 (29%)	3 (4%)	400 (8%)
A(CRS Subcommitte	e Meetu	ng – Feb 18-19,	2003 6		•	EPI	ei 🛵

targot g	(* 151.25× 0112	hall to be a first of the second s	Leaking N	Nozzles	Nozzle Tube	s Cracked	Welds Ci	
	EDY at Next RFO	No Nozzles	Nozzles Leakıng (Inspected)	% Leaking	Nozzles Cracked (Inspected)	% Cracked	Welds Cracked (Inspected)	% Cracked
	>12 EDY	2069	47 (1898)	2 5%	82 (1016)	8.1%	75 (338)	22.2%
	8–12 EDY	1035	0 (510)	0 0%	0 (354)	0.0%	0 (61)	0.0%
	< 8 EDY	1857	0 (1327)	0 0%	0 (92)	0 0%	0 (1)	0.0%
	Totals	4961	47 (3735)	1 3%	82 (1462)	5 6%	75 (400)	18 8%
	ACRS Subcom	mittee Mee	tıng – Feb 18-19,	2003 7			CPR	= ▲



			•			(c.)		
	NSSS		BN	4V	Nozzle Tu	be ET/UT	Weld	ET/PT
_	Supplier / ·EDY at Next RFO	No. Units	No. Units 100% Inspected	No Nozzles Inspected	No. Units 100% Inspected	No. Nozzles Inspected	No. Units 100% Inspected	No. Welds Inspected
_	B&W NSSS	7	7 (100%)	483 (100%)	4 (57%)	320 (66%)	0 (0%)	39 (8%)
_	non-B&W > 8 EDY	38	28 (74%)	1925 (73%)	13 (34%)	1050 (40%)	3 (8%)	360 (14%)
_	non-B&W < 8 EDY	24	17 (71%)	1327 (71%)	0 (0%)	92 (5%)	0 (0%)	1 (0%)
_	Totals	69	52 (75%)	3735 (75%)	17 (25%)	1462 (29%)	3 (4%)	400 (8%)
,	ACRS Subcommitte	e Meetir	ng – Feb 18-19, :	2003 9			EPI	ei 🖾

							1 1	
	NSSS		Leaking N	lozzles	Nozzle Tube	s Cracked	Welds Ci	racked
	Supplier / EDY at Next RFO	No. Nozzles	Nozzles Leakıng (Inspected)	% Leaking	Nozzles Cracked (Inspected)	% Cracked	Welds Cracked (Inspected)	% Cracked
	B&W NSSS	483	37 (483)	7.7%	61 (320)	19.1%	26 (39)	66.7%
1	non-B&W > 8 EDY	2621	10 (1925)	0.5%	21 (1050)	2.0%	49 (360)	13.6%
1	non-B&W < 8 EDY	1857	0 (1327)	0 0%	0 (92)	0.0%	0 (1)	0.0%
	Totals	4961	47 (3735)	1.3%	82 (1462)	5.6%	75 (400)	18 8%
A	CRS Subcomm	utlee Meeb	ng – Feb 18-19, 2	003 10			EPe	



The total RVH nozzle population includes 3871 CRDM nozzles, 1090 CEDM nozzles, and 94 ICI nozzles at 69 ٠ units . Bare-metal visual (BMV) and/or non-visual NDE inspections have now been performed on about 81% of the RVH nozzles About 47 nozzles have been found to be leaking Almost 8% of the nozzles in B&W plants have leaked, but leakage in non-B&W plants is limited to North Anna 2 and Surry 1 leakage, which is primarily due to weld cracking Non-visual examinations have been performed on: . - About half of the ">12 EDY" nozzles and a third of the "8-12 EDY" nozzles About two-thirds of the nozzles in B&W plants and 25% of the nozzles in non-B&W plants EPRI A ACRS Subcommittee Meeting - Feb 18-19, 2003 12



ACRS Subcommittee Meeting - Feb 18-19, 2003 13

					N						
10-00-01-0			-	10010 (D.C.10)				100 - 100 - 100 - 100 - 100 - 100 - 100 - 100 - 100 - 100 - 100 - 100 - 100 - 100 - 100 - 100 - 100 - 100 - 100			
EDYs			(1	Previous Inspections		Plans f	or Soring Y	DOJ REO	T
al		1.000	Maternal	Vessel		(Since 11/2000)			(Note 4)		Current
Spring	Unit Name	NSSS	Supplier	Fabra ator	Visual	A600	A182	Visual	A600	A182	Head
RFO		vendor	(Note 2)	(Note 3)	fa	Nozzle	Weld	for	Nozzle	Weld	Replacemen
(Note 1)					Leakage	Tubes	Metal	Leakape	Tubes	Metal	Plans
22.5	Oconee 3	BW	В	BW	BMV	UT ET(18),PT(12)	PT(12)	Head Re	placement	anth A690	Spring 200
214	North Anna I	W	S	RDM	BMV	ET(30) UT(8).PT(4)	PT (4)	Head Re	placement	with A690	Spring 200
20.5	Surry 1	_w	н	BW RDM	BMV	UT(16)	PT(10)	Head Re	placement	with A690	Spring 200
_18.3	Turkey Point 3	<u>w</u>	н	BW	BMV	-		BMV	UT	-	Assessing
17.5	Farley I	<u>w</u>	НВ	BW CE	BMV	~	-	BMV	ET UT	~	Fall 2004
15 2*	San Onofre 3	CE	SS/H	CE	BMV(34)	-	•	BMV	ບາ	ET	Assessing
152	Calvert Chfls 2	_CE	н	CE	BMV(#ICI)			BMV	ບ	L	Assessing
- 46	Cook 2	- W-	W		BMV	ETUT	ET(10)	BMV		 	
140	SI Lucie 2	<u></u>	22 H		IBMV.		-	IBMV	דט	l	Assessing
149	Beaver valley I	<u>w</u>	<u> H B</u>	BWLE	BMV	⁻	F	BMV	ETUI	ET	Spring 2000
112	Indust Bount 2	w	118	BWLE	BMV		F	BMV	-		I
116	Palo Vendo 1		n		F	-		BMV		F	<u>-</u>
10.9	Dabla Canyon 2		as n L		ł		F	BMV(24)	01		····
< 10	Palisades	CF-		CE	[-	F	DM V	·		
45	South Texas I	- W-	н		F			DMV			<u> </u>
2 10 3	Catan ha ?	Ŵ	н	CE	i		F			f	·
21*	Shearon Harris	w-	8	CBI	1		F	BMV		t	
17	Brantwood 1	w	В	BW	1			BMV	-	L	<u> </u>
15	Sequeyah 1	w	S	RDM	I			BMV	_	t	
NOTES						•	•	•	• • • • • •	•	
1 2 3	EDYs as reported than the projected Key for Material S CL = C L. Imphy Key for Vessel Fai CL = C L. Imphy	by each p EDYs at Suppliers A = Aub bricators	blass in the the spring 2 B = B& W ert et Din al BW = B&	r responses 2003 refuelt Tubular Pro W CB1 = C	to Bulletin 204 ng outage (8-2 iducts - H = Hi bicago Bridge	02-02 The asterisks in 2002 for San Onofre 3 a untington S = Sandvik : & Iron, CE = Combus	idicate ED and 9 2002 SS = Star tion Engin	Ys at time of for Shearon idard Steel, eering RDA	f the Bullen Harris) W = Westin I = Rotterd	n 2002-02 r nghouse (Hu am Dockyar	response rathe intengton) rd.





























































Penetration	NDE results	Addresses Objective #(s)	Additional Information ,
54 ,*	Visual. Not leaking UT ID and OD Indication in Nozzie Wield ET crc and axral	1, 2, 5	OD Circ #1. Length 42 deg Depth 0 16" OD Circ #2: Length 80 deg Depth 0.23" Weld Circ #1 Length 1 5" Weld Circ #2: Length 1 22" Weld Aua Length 0.32"
59	Visual Masked UT OD circs in Nozzle Weld ET Circs	1 2, 5	OD Circ #1 Length 76 deg Depth 0 15" OD Circ #2: Length 50 deg Depth 0.32" Weld Circ #1 Length 3 05" Weld Circ #2 Length 5 31"
31	Visual Lealung UT. No detectable indications Weld: ET axiats	2, 3, 5	Weld Axial #1 Length 0 08" Weld Axial #2 Length 0 18" Weld Axial #3 Length 0.20" Weld Axial #4 Length 0.20" Weld Axial #5 Length 0.24"
51 Weid repared in 2001	Visual Leaking UT Weld Interface Indication (Evidence of leak path) Weld PT linear	2, 3, 4 5	
63 Weld repaired in 2001	Visual Masked UT tD Indication in Nozzle Probable Leak Path Weld PT linear	245	
10	Visual Learing UT Weld Interface Indication Lack of Fusion Weld None	NDE ,	r
Need to determine the CRDM nozzle numbers	Sample RPV nozzte matenal from several different heats of material Sample should capture the full circumference and be about 6 inches long	6	Heats to consider 710147, 755538, 710208, 772024 or 568011

÷







÷







MRP Approach to Demonstrations

- <u>RPV Head Working Group</u> defines NDE objectives using analytical evaluations and service experience:
 - Identify relevant flaw mechanisms
 - Define inspection locations & volumes (e g., OD, ID)
 - Define ranges of flaws to address (depth, length, orientation)
- Inspection Working Group develops demonstration program
 - Approach
 - Mockup design & procurement
 - Specifications for flaws in mockups
 - Realism of mockups (geometry, distortion, clearance, access, scratches, magnetic deposits, etc.)

No

- Demonstration protocol & schedules (blind/non-blind, scope, result reporting process)
- <u>Tiger Team</u> formed to design mock-ups
 - RPV Head Working Group
 - Inspection Working Group
- Design criteria for mock-ups



MRP Demonstration Process

Demonstration protocol

- Vendor collects data on mockups & reports findings
 - evaluates measured vs. true values
 - · Detection (# detected/total flaws)
 - · Location with respect to pressure boundary
 - · Sizing results documented
 - Faise call performance
- NDE Center documents procedure essential variables
 - Allows verification that the techniques used are the same techniques that were demonstrated
- Analysis process used in the demonstration and must be captured in the procedure

ND

- Results are provided to utilities













- ----







2002 Mock-up Selection Considerations

- Mock-up flaws must be representative and appropriate for the NDE Method(s) to be demonstrated
 - Need to provide representative responses for:
 - UT
 - Specular reflection, Tip-diffracted response, Corner-trap response
 - ET
 - Realistic electromagnetic properties, crack width
- ▲ Goal is realistic reproduction of Key detection or sizing variables
 - Any differences are monitored and considered during the demonstration
- Challenge: Numerous NDE methods are being applied & numerous flaw types/exam volumes to be considered




























▲ Detection is sensitive to weld surface conditions

- Ground Surface Condition
 - Detected 0.16" long, 0.00031" wide
- Un-ground (as-welded) Surface Condition
 - Detected 0.55" long, 0 00197" wide
 - Missed; 1.42" long, 0.00591" wide
- Continue to pursue additional/alternate techniques to improve the detection capabilities

ŇΟ

MRP/CRDM/NDE 31











RES/DET/MEB Programs and Activities to Address: 1. CRDM Cracking Issues

2. Davis-Besse Cavity Exams & Safety Assessment

ACRS Materials and Metallurgy, and Plant Operations Subcommittees

Meeting on

Vessel Head Penetration Cracking and RPV Head Degradation April 22, 2003

> William H. Cullen, Jr. 301-415-6754 whc@nrc.gov

ACRS Presentation – April 22, 2003

Page 1 of 31

i de la construcción de la constru

,

•

1

T

1

t

1

н.



RES/DET/MEB Programs and Activities to Address: CRDM Cracking Issues

A. NRC-Funded SCC Program & Products

- 1. On-going EAC Program
- 2. Testing of Davis-Besse Materials
- 3. LLTF Rec. to Review Worldwide Experience with Alloy 600 CRDMs, Boric Acid Corrosion
- **B.** Additional Programs with Expected, Relevant Products
 - 1. Japanese Coordinated Program
 - 2. ICG-EAC Round Robin
 - 3. Other Programs
- C. Heat-by-Heat Analysis of Domestic Plant CRDMs
- **D.** Stress Analysis of CRDM Penetrations
- E. NRC-Industry Collaboration on CRDM Cracking Issues
- F. Davis-Besse Cavity Exam Update What it Means To NRC/RES
- G. LLTF Recommendations Barrier Integrity Action Plan Tomorrow

ACRS Presentation – April 22, 2003

Page 2 of 31



RES/DET/MEB Programs and Activities to Address: Davis Besse Root Cause & Safety Assessment

- A. Corrosion of RPV Boundary Materials in Boric Acid Solutions
 - 1. Features of Program at Argonne Nat. Lab
 - 2. LLTF Recommendation to Review Worldwide Experience
- **B. Structural Integrity Assessment**
 - 1. Approach of Program at ORNL
- C. D-B Cavity Sample Plan, and Head Disposition
 - 1. Documented Findings to Date
 - 2. Description of Last Phase of the Program
 - 3. Salvaging of Components from Discarded Head
 - 4. Additional Tasks for Future Programs

ACRS Presentation – April 22, 2003

Page 3 of 31



NRC's SCC Programs & Products

- A. On-going EAC Program at Argonne Nat. Lab.
 - SCC Testing of Alloys 600, 182, 690 and 152 in BWR and PWR water

 Also evaluating strength, metallography for insight into mechanisms
 - 2. Been testing since 1997, NUREG/CR-6717
 - a. Letter report on SCC in 182 due 10/04, NUREG due 12/05

B. Testing of Davis-Besse Materials (part of BAC program at ANL)

1. Alloy 600 from Nozzle #3 (M3935), and Alloy 182 from #11 J-weld

C. LLTF Rec. to Review Int'l Experience with Alloy 600 CRDMs

- 1. Critique of susceptibility model [EDY = EFPY * (temp. factor)] Done 2/28/03
- 2. Report on worldwide Alloy 600 cracking experience (Dec. '03)
- 3. Report on worldwide boric acid corrosion experience (Oct. '04)

ACRS Presentation – April 22, 2003

Page 4 of 31



Additional Programs

Products (CGR Data, Mechanistics) Will Contribute to Existing Databases

1. Japanese Coordinated Program

- a. Electric Joint Research Project
 - SCC and SSRT on Alloys MA600, Alloy 132, 82, TT690, Alloys 152 & 52
- b. National Nickel-Based Alloy Material Project
 - SCC on Alloys MA600, Alloy 132, 82, TT690, Alloys 152 & 52

2. ICG-EAC Round Robin

- a. Purpose: resolve factors that cause differences in stress corrosion crack growth rate response, esp. in Alloy 182 weld
- b. Status: Specimens distributed, some tests completed, reports next month
- c. Expectations:
 - Phase 1 Collect info Completed
 - Phase 2 Test 30% CW A600 in '03, Compare results, Improve methods
 - Phase 3 Test Alloy 182
- 3. Other Programs
 - a. Tests underway in France, Spain and Sweden
- 4. Dialogue to Obtain Mockups from Replacement Head Fabrication

ACRS Presentation – April 22, 2003

Page 5 of 31



Plant-specific (heat-specific) cross-correlations starting from Davis-Besse

Heat Identification	Other Plants With Heads Containing Same Heat of Material
M3935 (3 of 5 cracked)	Oconee 3 (replace in '03), Ark. Nuclear One 1 (replace in '05)
C2649-1	Oconee 1 (replace in '03), Oconee 2 (replace in '04) Oconee 3, ANO 1
M4437	Not found in any other plant's CRDMs

So, specifics about nozzle heats from D-B are not applicable in the longterm for other licensees. However . . .

ACRS Presentation – April 22, 2003

Page 6 of 31



Plant-specific (heat-specific) cross-correlations starting from North Anna 2

Heat Identification	Other Plants With Heads Containing
	Same near of Material
755534, 755535,	
755536, 755537,	
755538, 570892,	North Anna 1, Sequoyah 1
568011, 710209	
710147	North Anna 1, Sequoyah 2
71207, 71208, 710210	North Anna 1, Sequoyah 1, Sequoyah 2
71206	North Anna 1 Surry 2 Sequeval 1 Sequeval 2
/ 1200	North Anna 1, Surry 2, Sequoyan 1, Sequoyan
772024	Watts Bar-1, Watts Bar-2, Catawba-1, McGuire-2

ACRS Presentation – April 22, 2003

Page 7 of 31



March '03 Conference on CRDM and related Issues

(Including safe ends, ICI penetrations, coolant loop repairs, etc.)

Five main session topics

- Structural Analysis and Silverure Mechanics Issues (4 papers)
- Inspection technologic disposition & sizing of flaws, new developments (9,0,0)s)
- Crack growth rate relevant nickel-base alloys & welds (8 papers)
- Mitigation & Figure Sign Experience (9 papers)
- Conting of Int Operation (8 papers)
- March 24 26 At Gaithersburg-Marriott
- Expected 140 or more attendees (11 countries) & participants
- Proceedings issued as CD and NUREG/CP
- To Be Rescheduled When Travel Restrictions Are Lifted

ACRS Presentation – April 22, 2003

Page 8 of 31



Stress Analysis of CRDM Penetrations



Pass-by-pass simulation of the weld, followed by calculation of the stress, proceed to the next pass, etc.

Calculate axial, radial & tangential, resolve to principal stress.

ACRS Presentation – April 22, 2003

Page 9 of 31



ACRS Presentation – April 22, 2003

Page 10 of 31



ACRS Presentation – April 22, 2003

Page 11 of 31





ACRS Presentation – April 22, 2003

Page 12 of 31



NRC-Industry Collaboration on CRDM Cracking Issues

Task Number	Task
1	Alloy 600/82/182 – (a) crack growth testing Alloy 600 and (b) Alloy 82/182
2	Alloy 690/52/152 – (a) crack growth testing Alloy 690, and (b) Alloy 52/152
3	Boric Acid Corrosion Testing – (a) Expert Panel to review the boric acid corrosion model in MRP-75, (b) Examine Nozzle #2 from Davis-Besse, (c) BAC program at ANL
4	(a) RPV Head Penetration PFM, PRA & Nozzle stress analysis by FEA, (b) Residual stresses in A600 CRDM tubing
5	Failure Analysis of North Anna RPV head – determine impact of findings on susceptibility models, visual inspection validity, and inspection and repair methods (Industry effort underway, '04 funding proposed for NRC collaborative research)
6	Nozzle 46 Davis-Besse RPV head – determine meaning of NDE signals (shadow, or "anomalous indication") and implication for future inspections
7	Mitigation Testing – determine viability and utility of mitigation options, both for Alloy 600 base material (penetrations, etc.) and Alloy 82/182 weld material (J-grooves, butt welds, etc.) (fully an industry effort at present)

ACRS Presentation – April 22, 2003

Page 13 of 31



ACRS Presentation – April 22, 2003

Page 14 of 31



NRC Research Programs Related to CRDM & Alloy 600 The longer term response

- Continued development of CRDM & closure weld inspection techniques
- Modeling of Residual Stresses (tube fabrication & closure weld induced)
- Improved Probabilistic Model for t_f from Leakage of Circ. Cracks
 - Summary Report on Leakage from CRDMs -----
- Continue Testing SCC Rates of A600, A690 & Welds
 - Supplemented D-B materials (A600, A182) into on-going program
- Development of an International Cooperative Group on PWSCC of Nickel-base Alloys, Including Inspection and Repair Techniques
- Workshop on March 24-26 to Discuss Issues of PWSCC in Nickel-Base Alloys

ACRS Presentation – April 22, 2003

Page 15 of 31

All feed into

improved risk

analysis models



ACRS Presentation – April 22, 2003

Page 16 of 31



Cintou Otatoo Ruoroa, nogenato, y commonica

Completion of Cavity and Exposed Clad Exams

Completion due early May, 2003 – docketed shortly after

- Axial & circumferential cracks in J-weld sectioned, opened
 - Long axial cracks, very short circumferential cracks both IGSCC
- Cracks in clad were measured, opened, characterized, deposits analyzed
 - Depth is ~1 1.5 mm; all terminate with ~5.0 mm clad remaining
 - Possibly due to stress effect, less possibly a temperature effect
 - Temp gradient in clad was 315°C (RCS side) ~100°C cavity side
 - All growth by IGSCC in conc. boric acid solution, no ductile tearing
 - Elicitation of the growth rate would shed light on cavity evolution
- Walls of the cavity examined for corrosion morphology effects

ACRS Presentation – April 22, 2003

Page 17 of 31



Exam of exposed clad & J-weld – sectioning scheme



ACRS Presentation – April 22, 2003

Page 18 of 31



ACRS Presentation – April 22, 2003

Page 19 of 31



ACRS Presentation – April 22, 2003

Page 20 of 31



29-Jan-03

ACRS Presentation – April 22, 2003

Nozzle #3. Surface was 100%

IGSCC, with substantial amounts

of oxygen and carbon in analysis.

Page 21 of 31

WD17.2mm 5.00kV x100 500um



ACRS Presentation – April 22, 2003

Page 22 of 31



Opened crack in cladding shows interdendritic growth morphology – all IGSCC, no tearing, even near the bulge.



ACRS Presentation – April 22, 2003

Page 23 of 31



ACRS Presentation – April 22, 2003

Page 24 of 31



Cracks in the exposed clad, attacked by concentrated, boric acid solutions



ACRS Presentation – April 22, 2003

Page 25 of 31



しり

ACRS Presentation – April 22, 2003

Page 26 of 31



ACRS Presentation - April 22, 2003

Page 27 of 31



Davis-Besse Root Cause and Safety Assesssment

- 1. Features of Boric Acid Corrosion Program at Argonne Nat. Lab
 - A. Crack Growth Rates of Alloys 600 & 182 from Davis-Besse Head
 - B. Computational Model, Based on Probabilistic Assessment of:
 - i. Statistics of Crack Initiation
 - ii. Probability of Detection & Accuracy of Sizing
 - iii. Crack Growth Rate Variations
 - iv. Stress Intensity Factor Gradients (Residual Stress, Interferences)
 - v. Critical Crack Sizes, Including Factor of Safety
 - C. Electrochemical Potential and Polarization Measurements of Low-Alloy Steel, Alloys 600 & 182 in Concentrated Boric Acid Solutions
 - i. Measure E_{cp} for range of solution compositions, temperatures
 - ii. Include molten boric acid species at temp. & pressure
- 2. Next two slides describe MEB Program on Structural Integrity at ORNL

ACRS Presentation – April 22, 2003

Page 28 of 31


United States Nuclear Regulatory Commission

Structural Integrity Assessment

Approach

- Created detailed finite element model of the DB head, wastage cavity, and remaining unbacked cladding.
- Developed two failure models to bound expected behavior:
 - 1. Plastic instability model calibrated by PVRC-sponsored unflawed rupture disk results.
 - 2. Ductile tearing initiation model using 3-wire, 308SS quasistatic fracture toughness properties.
- Predicted best-estimate failure probability vs pressure as a function of crack depth.
- Conducted Monte Carlo analysis to determine failure probabilities with respect to the best estimate.

Variable Modeling Categories

- Probabilistic: Crack depth, material toughness, rupture disk failure pressure.
- Conservative Deterministic: J-groove weld reinforcement; cladding thickness.
- Best-Estimate Deterministic: Cladding cavity area; low alloy steel, Alloy 600, and 308 SS constitutive behavior; vessel head geometry; operating temperature and pressure.

ACRS Presentation – April 22, 2003

Page 29 of 31



United States Nuclear Regulatory Commission

Ongoing Work for ASP Analysis (by 10/03)

Analytical Program

- Develop tearing instability model to analyze intermediate-depth flaws.
- Extend model to predict failure probabilities for the year preceding cavity discovery.
 - Monte Carlo Analysis
 - Probabilistic Variables: Pressure, cavity size, flaw size, wastage rate, material toughness, and burst pressure.
- More rigorous quantification of geometric, material, and failure model uncertainties.
- Experimental Program
 - Conduct material property testing of surrogate cladding material (PVRUF).
 - Perform burst tests on simple, circular or elliptical cavity geometries.
 - Unflawed specimens
 - Flawed specimens
 - Assess accuracy of analytical failure models.

ACRS Presentation – April 22, 2003



Page 30 of 31



United States Nuclear Regulatory Commission

Harvesting of Head for Additional Research

- Nozzle #3 and surrounding low-alloy steel at BWXT-Lynchburg
 - Optical & SEM Micrography of Cavity Surface
 - Cladding Properties, Microstructure, etc.
- Nozzles #2 and #46 removal in early 2003
 - #2 sent to Argonne for failure analysis
 - #46 sent to PNNL for research on "anomalous" UT indications
 - Additional nozzles for crack growth rate testing
- Crack Growth Rate Testing of Alloy 600 (Nozzle #3) and Alloy 182 (J-weld, from Nozzle #11) soon underway
- North Anna Unit 2 Head Being Harvested by Industry
 - Expect NRC/Industry Coordination of NA2 Research

ACRS Presentation – April 22, 2003



Page 31 of 31