

Exelon Generation  
Dresden Generating Station  
6500 North Dresden Road  
Morris, IL 60450-9765  
Tel 815-942-2920

www.exeloncorp.com

April 30, 2003

RHLTR: #03-0027

U.S. Nuclear Regulatory Commission  
Attention: Document Control Desk  
Washington, DC 20555

Dresden Nuclear Power Station, Units 2 and 3  
Facility Operating License Nos. DPR-19 and DPR-25  
Nuclear Docket Nos. 50-237 and 50-249

Subject: 2002 Regulatory Commitment Change Summary Report

The 2002 Commitment Change Summary for Dresden Nuclear Power Station is attached to this letter. Revisions to docketed correspondence were processed using Nuclear Energy Institute (NEI) 99-04, Revision 0, "Guidelines for Managing NRC Commitment Changes," dated July 1999.

Should you have any questions concerning this summary please contact Jeff Hansen, Regulatory Assurance Manager at 815-416-2800.

Respectfully,



R. J. Hovey  
Site Vice President  
Dresden Nuclear Power Station

Attachment: Dresden Nuclear Power Station Revised Commitment Summary for 2002

cc: NRC Regional Administrator, Region III  
NRC Senior Resident Inspector, Dresden Nuclear Power Station

A001

**Attachment**  
**Dresden Nuclear Power Station**  
**Commitment Change Summary for 2002**

<b>Commitment Revision Tracking No.</b>	<b>Date of Commitment Revision</b>	<b>Original Document</b>	<b>Original Commitment</b>	<b>Revised Commitment</b>	<b>Basis For Revision</b>
02-001	12/12/02	Response to NRC Bulletin 90-01, dated July 20, 1990	In response to NRC Bulletin 90-01, Exelon, then ComEd, committed to perform enhanced monitoring and trending for Rosemount Transmitters Model 1153 series B and D, and Models 1154.	Deleted the commitment for enhanced monitoring and trending for transmitters that are installed in systems with operating pressures less than 500 psig.	Supplement 1 of the NRCB 90-01, which was issued December 22, 1992, exempted transmitters that were installed in systems with operating pressures less than 500 psig.