

AmerGen Energy Company, LLC
Three Mile Island Unit 1
Route 441 South, P O Box 480
Middletown, PA 17057

Telephone 717-944-7621

An Exelon/British Energy Company

April 30, 2003
5928-03-20051

U. S. Nuclear Regulatory Commission
Washington, DC 20555

Attn: Document Control Desk

SUBJECT: THREE MILE ISLAND NUCLEAR STATION UNIT 1 AND UNIT 2
OPERATING LICENSE NO. DPR-50 AND POSSESSION ONLY LICENSE NO.
DPR 73
DOCKET NOS. 50-289 AND 50-320
COMBINED 2002 ANNUAL RADIOACTIVE EFFLUENT RELEASE REPORT

The Annual Radioactive Effluent Release Report required by TMI-1 Technical Specification 6.9.4.1, TMI-2 Technical Specifications 6.8.1.2, and 6.12, and the Off-Site Dose Calculation Manual Part 4, Section 2.1 is enclosed.

Attachment 1 contains a summary of the quantities of radioactive liquid and gaseous effluents released from the site as outlined in Reg Guide 1.21, Rev. 1, with data summarized on a quarterly basis following the format of Appendix B thereof.

Attachment 2 contains information for each type of solid waste shipped offsite during the report period including the container volume, total curie quantity (specified as determined by measurement or estimate), principal radionuclides (specified as determined by measurement or estimate), type of waste, type of shipment and solidification agent(s).

Attachment 3 includes a summary of unplanned releases from the site to unrestricted areas of radioactive materials in gaseous and liquid effluents made during the reporting period.

Attachment 4 describes any changes made during 2002 to the Process Control Program (PCP) documents or to the Offsite Dose Calculation Manual (ODCM) and a listing of new locations for dose calculations and/or environmental monitoring identified by the land use census pursuant to Part 3, Section 8.2 of the ODCM.

Attachment 5 reports all instrumentation not returned to operable status within 30 days per the TMI ODCM Part 1, Sections 2.1.1.b and 2.1.2.b and Part 2, Section 2.1.2.b.

Attachment 6 is an annual summary of hourly meteorological data collected for 2002 in the form of joint frequency distribution of wind speed, wind direction and atmospheric stability.

NMSS01
JE48
A009

Attachment 7 is an assessment of the radiation doses due to the radioactive liquid and gaseous effluents released from the respective unit during 2002.

Attachment 8 is an assessment of the radiation doses from the radioactive liquid and gaseous effluents to members of the public due to their activities inside the site boundary during 2002.

Attachment 9 is an assessment of the radiation doses to the likely most exposed real individual from reactor releases and other nearby uranium fuel cycle sources including doses from primary effluent pathways and direct radiation for 2002.

Attachment 10 is a summation of deviations from the sampling and analysis regime specified in the ODCM for TMI-1 and TMI-2.

Enclosure 1 is a copy of the TMI Offsite Dose Calculation Manual (ODCM), revision 23, which was current as of December 31, 2002. There was one revision made to the ODCM during 2002. Revision 23 was issued on March 19, 2002.

Enclosure 2 is a copy of the procedure change request that modified the ODCM from revision 22 to 23.

Please contact Adam Miller of TMI-1 Regulatory Assurance at 717-948-8128 if you have any questions concerning this report.

Sincerely,



George H. Gellrich
Plant Manager

GHG/awm

Attachments/Enclosures

cc: Region 1 Administrator
TMI Senior Resident Inspector
TMI-1 Senior Project Manager
TMI-2 Project Manager
GPU Nuclear Cognizant Officer