

May 9, 2003

LICENSEE: DUKE ENERGY COMPANY

FACILITY: OCONEE NUCLEAR STATION, UNITS 1, 2, AND 3

SUBJECT: SUMMARY OF APRIL 30, 2003, MEETING TO DISCUSS NON-SEISMIC PIPING IN THE AUXILIARY BUILDING (TAC NOS. MB6651, MB6652, AND MB6653)

On April 30, 2003, the Nuclear Regulation Commission (NRC) met with Duke Energy Company (the licensee) to discuss the licensee's November 1, 2002, submittal on non-seismic piping in the auxiliary building and the associated requests for additional information (RAIs). A list of the attendees is enclosed. The November 1, 2002, submittal; the NRC's RAIs; and the handouts provided by the licensee are accessible electronically from the Agencywide Documents Access and Management System (ADAMS) Public Electronic Reading on the internet at the NRC Web site, <http://www.nrc.gov/reading-rm/adams/html>. The accession number for the November 1, 2002, submittal is ML023180409; the accession numbers for the RAIs are ML030440183 and ML030720040; and the accession number for the licensee's handouts is ML031220331.

The licensee's November 1, 2002, submittal proposes that, in the event of the maximum hypothetical earthquake, failure of the non-seismic piping in the auxiliary building would not adversely impact safety-related equipment that is required for safe shutdown. The licensee's proposal is based on a risk-informed justification. To support this justification, the licensee developed a fragility value for the Oconee piping based on the experience of fire protection piping during the Loma Prieta earthquake.

Following are the major concerns raised by the NRC during the meeting:

1. Since the licensee used the entire seismic probabilistic risk analysis in its risk-informed justification, the NRC review will require a greater effort than what was originally anticipated.
2. The licensee has not adequately demonstrated that the piping that experienced the Loma Prieta earthquake is similar to the Oconee piping, especially in the areas of support spacing and type of support.
3. The horizontal spectrum accelerations of the Loma Prieta earthquake do not envelope the Oconee uniform hazard earthquake spectrum accelerations at frequencies other than 7

Hertz. The vertical spectrum accelerations from the Loma Prieta earthquake are significantly lower than the Oconee uniform hazard earthquake spectrum accelerations at frequencies greater than 3 Hertz.

The licensee and the NRC will continue efforts to resolve these concerns.

*/RA/*

Leonard N. Olshan, Senior Project Manager, Section 1  
Project Directorate II  
Division of Licensing Project Management  
Office of Nuclear Reactor Regulation

Docket Nos. 50-269, 50-270 and 50-287

Attachment: List of Attendees

cc w/encl: See next page

Hertz. The vertical spectrum accelerations from the Loma Prieta earthquake are significantly lower than the Oconee uniform hazard earthquake spectrum accelerations at frequencies greater than 3 Hertz.

The licensee and the NRC will continue efforts to resolve these concerns.

***/RA/***

Leonard N. Olshan, Senior Project Manager, Section 1  
Project Directorate II  
Division of Licensing Project Management  
Office of Nuclear Reactor Regulation

Docket Nos. 50-269, 50-270 and 50-287

Attachment: List of Attendees

cc w/encl: See next page

Distribution:

PUBLIC	JFair
PDII-1 Reading	MRubin
LOlshan	RidsRgn2MailCenter
OGC	SMoore
ACRS/ACNW	JZwolinski/TMarsh
JNakoski	CHawes
MKotzalas	SDinsmore

**ADAMS Accession No: ML031290131**

OFFICE	PM:PDII-1	LA:PDII-1	SC:PDII-1
NAME	LOlshan	CHawes	JNakoski
DATE	5/8/2003	5/8/2003	5/8/2003

**OFFICIAL RECORD COPY**

LIST OF ATTENDEES

MEETING TO DISCUSS NON-SEISMIC PIPING IN OCONEE AUXILIARY BUILDING

APRIL 30, 2003

NRC

S. Dinsmore  
J. Fair  
B. Lefave  
J. Nakoski  
L. Olshan  
M. Rubin

DUKE ENERGY

D. Brewer  
T. Brown  
E. Burchfield  
R. Gambrell  
G. McAninch  
S. Nader  
L. Nicholson  
J. Richards  
J. Robertson  
B. Shingleton

Oconee Nuclear Station

cc:

Ms. Lisa F. Vaughn  
Legal Department (ECIIX)  
Duke Energy Corporation  
422 South Church Street  
Charlotte, North Carolina 28201-1006

Anne W. Cottingham, Esquire  
Winston and Strawn  
1400 L Street, NW  
Washington, DC 20005

Manager, LIS  
NUS Corporation  
2650 McCormick Drive, 3rd Floor  
Clearwater, Florida 34619-1035

Senior Resident Inspector  
U. S. Nuclear Regulatory  
Commission  
7812B Rochester Highway  
Seneca, South Carolina 29672

Mr. Henry Porter, Director  
Division of Radioactive Waste Management  
Bureau of Land and Waste Management  
Department of Health and Environmental  
Control  
2600 Bull Street  
Columbia, South Carolina 29201-1708

Mr. Michael A. Schoppman  
Framatome ANP  
1911 North Ft. Myer Drive  
Suite 705  
Rosslyn, VA 22209

Mr. L. E. Nicholson  
Compliance Manager  
Duke Energy Corporation  
Oconee Nuclear Site  
7800 Rochester Highway  
Seneca, South Carolina 29672

Ms. Karen E. Long  
Assistant Attorney General  
North Carolina Department of  
Justice  
P. O. Box 629  
Raleigh, North Carolina 27602

Mr. C. Jeffrey Thomas  
Manager - Nuclear Regulatory  
Licensing  
Duke Energy Corporation  
526 South Church Street  
Charlotte, North Carolina 28201-1006

Mr. Richard M. Fry, Director  
Division of Radiation Protection  
North Carolina Department of  
Environment, Health, and  
Natural Resources  
3825 Barrett Drive  
Raleigh, North Carolina 27609-7721

Mr. Peter R. Harden, IV  
VP-Customer Relations and Sales  
Westinghouse Electric Company  
6000 Fairview Road  
12th Floor  
Charlotte, North Carolina 28210