

# Operations Department Chronological Log Unit 1

NUMBER: 6441

- 11:40 DREDGE WATCH OPERATOR REPORTS A TURTLE SWIMMING IN THE 1A2 CIRCULATING WELL. NOTIFY TURTLE RESCUE PERSONNEL.
- 11:50 DREDGE WATCH OPERATOR REPORTS TURTLE HAS BEEN CAPTURED AND PLACED IN THE TURTLE HOLDING CONTAINER.
- 12:10 TURTLE IS BEING TRANSPORTED BACK TO ITS NATURAL ENVIRONMENT. NO REPORTABLE CONDITIONS EXISTED.
- 13:25 RECEIVED ANN F-31 "CITY WATER STORAGE TANKS LEVEL HIGH/LOW. DISPATCHED OPERATOR TO INVESTIGATE.
- 13:27 ANPO REPORTS 1B CWST AT 16' 9.5". THE INLET VALVE IS THROTTLED TO APPROXIMATELY 30% OPEN PER PROCEDURE TO PREVENT PRESSURE DROP UPSTREAM IN THE THE FT. PIERCE SUPPLY. WITH ECOLOCHEM IN SERVICE TO THE TWST, THE 30% VALVE POSITION IS NOT ENOUGH TO KEEP UP WITH DEMAND WHILE THE 1A CWST IS OUT OF SERVICE. THE ANPO OPENED THE 1B CWST INLET MORE TO FILL ABOVE THE ALARM SETPOINT. ANPS REVIEWED ACTIONS OF THE FIRE PROTECTION PLAN WHICH REQUIRES THE 1B FIRE WATER SUPPLY TO BE RESTORED WITHIN 24 HOURS.
- 13:35 ANPO REPORTS 1B CWST LEVEL AT 16' 11" AND INCREASING.
- 13:50 ANN F-31 "CITY WATER STORAGE TANKS LEVEL HIGH/LOW IS CLEARED.
- 15:00 DECLARED V3452 "SDC HX 1A INLET" BACK IN SERVICE.
- 16:00 DIVER IS OUT OF THE 1A CWST. WORK WILL CONTINUE TOMORROW.

TIME REVIEWER'S COMMENTS

B/1