

OK

LAR Number	Unit	Submittal Date	Exp Issue Date/Outage	Description	Next Action
PSL Summary Status					
2001-020 SUPP	1/2	11/21/01 T 9/23/02	SL1-18	ISI PLAN - CONTINGENCY R/R 20, 21, 30, 31 OUTAGE RX HEAD RPR SUPP W/WELD PROC QUALS (ROUTING L-2002-178)	ENG
P2002-004	1	T 9/25/02	SL1-18	ISI R/R CONTINGENCY FOR PZR & RCS HOT LEG NOZZLES AS ALTERN. RPR	ENG-CSI
P2002-006	2	10/02 CNRB T 10/31/02	SL2-14	REDUCE TECH SPEC MINIMUM RCS FLOW TO ACCOMMODATE 15% S/G TUBE PLUGGING	ENG-NF WEST/CE

*** LICENSING ***
(cont'd)

LICENSEE EVENT REPORT STATUS:

UNIT 1:
NONE

UNIT 2:

LER Number	Rev	Due Date	Description	CR Number
02-002	0	10/18/02	U2 PSV SETPOINT DRIFT	CR02-1786

*** PROTECTION SERVICES ***

NAME: NWhiting DATE/TIME: 09/19/2002

ENVIRONMENTAL COMPLIANCE STATUS:

SITE

Work is underway to upgrade the support structure for the primary turtle barrier net in the intake canal. You may hear the pilings being driven.

*** SECURITY ***

NAME: J. McCullough DATE/TIME: 09/19/2002

GENERAL INFORMATION

Loggable Events: 0
Compensatory Posts: 0

COMMENTS

B/EI