

# Operations Department Chronological Log Unit 2

Mar-02

NUMBER:	6260	NUC POWER:	100
DATE:	3/9/2001	DELTA T POWER:	100
SHIFT:	DAY	MWE:	910
BOARD RCO:	de la Guardia	CEA GROUP #:	5
DESK RCO:	PRICE	POSITION:	133
NWE:	BASHWINER	T AVG:	575
ANPS:	Soule	BORON:	934
NPS:	PARKS	Xe WORTH:	-2463
		MODE:	1
		CALCULATED SD MARGIN:	>3600

**MAJOR MILESTONES OR ACTIVITIES TO BE PERFORMED DURING THE SHIFT:**

2.2 GALS. OF ACID/11.2 GALS. OF WATER. BR=5.03 TO 1.

**TIME LOG ENTRIES**

- 6:30 ASSUMED SHIFT
- 7:40 SGBDTF ROLLUP DOOR OPEN FOR MAINTENANCE, SGBDTF VENTILATION SYSTEM OOS.
- 10:09 PORV 1474 PLACED IN OVERRIDE FOR CALIBRATION OF TI-1115
- 11:15 PORV 1474 PLACED IN NORMAL, CALIBRATION COMPLETE AND SAT
- 2:45 2 TURTLES REPORTED REMOVED FROM UNIT#2, TURTLE PERSON NOTIFIED
- 3:30 TURTLE PERSON NOTIFIED US HE WILL BE RELEASING BOTH TURTLES IN APPROX 1 HOUR, NEITHER TURTLE WAS INJURED OR IN NEED OF REHABILITATION
- 4:30 TIME ENTERED IN ERROR
- 6:30 LIA-9005 BIS
- 7:15 RECEIVED E-26 (CONDENSER WATER BOX VACUUM LOW) ALARM INTERMITTANTLY, DISPATCHED NPO, DISCOVERED 2A2 VACUUM TANK CAUSING ALARM

**TIME REVIEWER'S COMMENTS**

Bh