Operations Department Chronological Log Unit 2

4-Apr-02

10:30 Received ANN-34 "GAS ANNALYZERS TROUBLE" SNPO reports while changing a light bulb the light socket grounded and caused a power supply failure for the AUTO GAS ANNALYZER. Entered ONOP 2-0530030. Contacted I&C to investigate and notified chemistry to perform grab samples every 24 hours. Entered UFSAR 13.7.1-5.

10:35 Declared the SGTBF radation monitor RM-45-1 OOS for chemisrty sample. Entered Tech Specs 3.3.3.1 B table 3.3-6 #2Ciii action 27 also entered Offsite Dose Calculation Manual 3.3.3.10 B #6 action 47 and 51.

11:05 Declared the BLOWDOWN BUILDING radation monitor RM-45-1 Back In Service. Chemisrty sample complete. Exited Tech Specs 3.3.3.1 B table 3.3-6 #2Ciii action 27 also exited Offsite Dose Calculation Manual 3.3.3.10 B #6 action 47 and 51

11:30 Declared the Plant Vent WRGM RIM-26-90 Back in Service. Completed I&C functional test in accordance with 2-IMP-26.02. Exited Tech Specs 3.3.3.1 B table 3.3-6 #2Cii action 27.

11:40 Completed the 2B EDG periodic test. Stopped the 2B EDG. Notified Maint and Chemistry to collect the appropriate samples.

12:00 Declared the 2B EDG Back in Service.

11:45 (Late Entry) Placed Clearance order 2-02-04-071 on 2-MV-08-19B B side ADV to replace the modutronics unit. ADV already OOS, OOS log entry # 6833.

12:45 Replaced blown fuses and declared the Auto Gas Analyzer Back In Service. Exited ONOP 2-0530030 and UFSAR spec 13.7.1-5. Notified Chemistry to cancel 24 hour grab samples.

13:00 Placed the Aux Feedwater Actuation System in a two of three logic for I&C replacement of the B Chan bistable switch. Entered Tech Specs 3.3.2 table 3.3-. #7 action 12 (48 hours).

13:30 Notified the NRC of an injured sea turtle requiring rehabilitation that was rescued from the intake and transported offsite. The notification to the NRC was made because the State was Notified.

13:42 Declared the SGBTF radiation monitor Rm-45-1 OOS for an I&C functional test to be performed in accordance with 2-IMP-26.05. Entered Tech Specs 3.3.3.1 B table 3.3-6 #2Ciii action 27 also entered Offsite Dose Calculation Manual 3.3.3.10 B #6 action 47 and 51.

14:45 Declared the SGBTF radiation monitor Rm-45-1 Back In Service. I&C functional test completed in accordance with 2-IMP-26.05. Exited Tech Specs 3.3.3.1 B table 3.3-6 #2Ciii action 27 also exited Offsite Dose Calculation Manual 3.3.3.10 B #6 action 47 and 51.

16:10 ANPO reports started AUX HYPO to the Unit 2 Circ wells.

18:05 ANPO reports completed AUX HYPO to the Unit 2 Circ wells.

TIME REVIEWER'S COMMENTS

B144