
Operations Department Chronological Log Unit 2

30-May-02

NUMBER:	6422	NUC POWER:	94
DATE:	5/29/2002	DELTA T POWER:	94
SHIFT:	DAY	MWE:	820
BOARD RCO:	DAVE GLISSON	CEA GROUP #:	5
DESK RCO:	LARRY HARTLEY	POSITION:	125
NWE:	BILL CASIAS	T AVG:	572
ANPS:	TIM BOLANDER	BORON:	783
NPS:	CHARLIE PIKE	Xe WORTH:	-2543
		MODE:	1
		CALCULATED SD MARGIN:	>3600

MAJOR MILESTONES OR ACTIVITIES TO BE PERFORMED DURING THE SHIFT:

25 GALS ACID OR 16 GALS OF H2O TO CHANGE RCS .1 DEGREES. BR 6.5 TO 1. COMPLETE TURBINE VALVE TEST AND RETURN UNIT TO 100% POWER.

TIME LOG ENTRIES

6:45 CONDUCTED A BOARD WALKDOWN, TURNOVER, AND ASSUMED THE SHIFT.

8:55 I&C PERFORMING CONTROL ROOM OUTSIDE AIR INTAKE MONTHLY FUNCTIONAL IAW 2-IMP-26.33. WORKING ONE TRAIN AT A TIME BEGINNING WITH THE "A" TRAIN. DECLARING "A" TRAIN OOS.

10:08 I&C FINISHED WITH THE "A" TRAIN CROAI RAD MONITORS. DECLARED BIS. DECLARING "B" TRAIN OOS THIS TIME.

11:30 COMPLETED BRIEF FOR COMMENCING WITH THE TURBINE VALVE TEST.

11:38 COMMENCING WITH TURBINE VALVE TEST IAW 2-OSP-22.04. STARTING WITH #4 GOVERNOR VALVE.

11:50 SICK SEA TURTLE FOUND AT INTAKE CANAL INTRUSION NET.

12:00 RICK HEREN OF LAND UTILIZATION NOTIFIED STATE OF FLORIDA SEA TURTLE STRANDING COORDINATOR @ 1130 OF SICK SEA TURTLE FOUND AT INTAKE CANAL INTRUSION NET. MANAGEMEN NOTIFICATIONS MADE.

12:35 DECLARED TURBINE GOVERNOR VALVE #4 BIS. EXITED FSAR SPEC 13.7.1.1 ACTION A FOR TURBINE OVERSPEED PROTECTION.

12:41 NOTIFIED NRC AND NDDO AND RESIDENT NRC INSPECTOR OF SICK SEA TURTLE FOUND AT INTAKE CANAL INTRUSION NET.

13:55 TURBINE VALVE TEST IAW 2-OSP-22.04 COMPLETED, SAT.

13:56 DECLARED RM-26-26 CONTAINMENT AIR MONITOR BIS FOLLOWING I&C REPAIR, DECLARED RM-26-25 OOS FOR MONTHLY I&C FUNCTIONAL IAW 2-IMP-26.05.

13:00 RM-26-62 CROAI MONITOR OOS DUE TO FAILED CHECK SOURCE, RM-26-66 OPERABLE, B TRAIN OUTS AIR INTAKE MONTHLY FUNCTIONAL COMPLETE.

14:10 I&C PERFORMING SPENT FUEL POOL MONITOR MONTHLY FUNCTIONAL TEST IAW 2-IMP-26.35, ONE MONITOR AT A TIME.

B/46