

## Operations Department Chronological Log Unit 1

NUMBER: 6048

NUMBER: 6048	NUC POWER: 100
DATE: 11/23/2001	DELTA T POWER: 100
SHIFT: DAYS	MWE: 910
BOARD RCO: SCOTT	CEA GROUP #: 7
DESK RCO: PRICE	POSITION: 136
NWE: STARKWEATHER/SWAN	T AVG: 573
ANPS: DIEHL	BORON: 702
NPS: EMLING	Xe WORTH: -2490
	MODE: 1
	CALCULATED SD MARGIN: >3600

**MAJOR MILESTONES OR ACTIVITIES TO BE PERFORMED DURING THE SHIFT:**

THE AMOUNT OF BORIC ACID NEEDED TO LOWER RCS TEMPERATURE BY .1 °F = 2.1 GALLONS. THE  
 AMOUNT OF PRIMARY WATER NEEDED TO RAISE RCS TEMPERATURE BY .1 °F = 14.9 GALLONS. RCS BLEND  
 RATIO = 7.1:1.

**TIME LOG ENTRIES**

7:10 VERIFIED CEA #60 AT UEL AND REED SWITCH POSITION AGREES WITH UEL DUE TO TC PULSE COUNTER OOS T.S. 3.1.3.3c

8:50 FHB DOOR#163 OPEN FOR ABB, FHB RAD MONITOR DECLARED OOS T.S. 3.3.3.1

10:25 COMMENCED HYPO TO UNIT 1 CIRC WELLS

10:35 FHB DOOR#163 SECURED, FHB RAD MONITOR BIS

10:30 (LATE ENTRY) RECEIVED ANNUNCIATOR M-20 (LETDOWN RAD MONITOR HIGH/FAILURE) CLEARED RIGHT AWAY. APPEARS TO BE A SINGLE MOMENTARY SPIKE ON CH 41. CHANNEL 40 ALSO SHOWED A SMALL SPIKE, BUT DID NOT GO INTO ALARM. NO TRENDS OR OTHER ABNORMAL INDICATIONS. NOTIFIED NPS.

12:08 SECURED HYPO TO UNIT#1

12:10 NOTIFIED STATE (STATE WAS NOTIFIED BY LAND UTILIZATION/ QUANTUM RESOURCES INC.) OF A GREEN TURTLE RECOVERED FROM UNIT#1 CIRC WELLS THAT APPEARS TO BE IN NEED OF REHABILITATION.

12:30 NOTIFIED NRC OF STATE NOTIFICATION OF TURTLE RECOVERED THAT APPEARS TO BE IN NEED OF REHABILITATION.

12:55 UPDATE ON TURTLE- TURTLE HAS DIED. NOTIFICATION ON TURTLE MORTALITY INCLUDED IN FAX SENT TO NRC.

14:00 VERIFIED CEA #60 AT UEL AND REED SWITCH POSITION AGREES WITH UEL DUE TO TC PULSE COUNTER OOS T.S. 3.1.3.3c

17:03 NPO ADDING H2 TO GENERATOR

17:18 SECURED H2 TO GENERATOR

**TIME REVIEWER'S COMMENTS**

26-Nov-01

8

B/35