

May 7, 2003

U.S. Nuclear Regulatory Commission
Attention: Document Control Desk
Washington, D.C. 20555

Subject: Duke Energy Corporation
Catawba Nuclear Station, Unit 1
Docket Number 50-413
Request for Relief Number 02-002,
Revision 1
Limited Weld Examinations for End of Cycle 13
Refueling Outage

Reference: Letter from Duke Energy Corporation to NRC,
same subject, dated August 15, 2002

Pursuant to 10 CFR 50.55a(g)(5)(iii), please find attached Request for Relief 02-002, Revision 1. This request for relief is associated with limited weld examinations for the subject outage and incorporates a response to a Request for Additional Information previously discussed with members of the NRC staff. The reference letter originally transmitted Revision 0 of this Request for Relief. Revision 1 of this Request for Relief should replace Revision 0 in its entirety. Please note that the number of welds included in Revision 1 is less than that included in Revision 0. Relief is no longer being requested for some of the welds included in Revision 0 because these welds will be examined again in a subsequent refueling outage in the interval using improved examination techniques.

The attachment to this letter contains all technical information necessary in support of this request for relief. Duke Energy Corporation is requesting NRC review and approval of this request at your earliest opportunity.


There are no regulatory commitments contained in this letter or its attachment.

A047

Document Control Desk
Page 2
May 7, 2003

If you have any questions concerning this material, please
call L.J. Rudy at (803) 831-3084.

Very truly yours,



Gary R. Peterson

LJR/s

Attachment

xc (with attachment):

L.A. Reyes, Regional Administrator
U.S. Nuclear Regulatory Commission, Region II
Atlanta Federal Center
61 Forsyth St., SW, Suite 23T85
Atlanta, GA 30303

E.F. Guthrie, Senior Resident Inspector
U.S. Nuclear Regulatory Commission
Catawba Nuclear Station

R.E. Martin, Senior Project Manager (addressee only)
U.S. Nuclear Regulatory Commission
Mail Stop 08-H12
Washington, D.C. 20555-0001

Proposed Relief in Accordance with 10 CFR 50.55a(g)(5)(iii)
Inservice Inspection Impracticability

Duke Energy Corporation

Catawba Nuclear Station – Unit 1 (EOC-13)

Second 10-Year Interval – Inservice Inspection Plan

Second Interval Start Date – June 29, 1995

Second Interval End Date – June 29, 2005

ASME Section XI Code – 1989 Edition with No Addenda

	I	II & III	IV	V	VI	VII
Limited Area/Weld I.D. Number	System / Component for Which Relief is Requested: Area or Weld to be Examined	Code Requirement from Which Relief is Requested: 100% Exam Volume Coverage and / or 4 Scan Directions Exam Category Item No. Fig. No. Limitation Percentage	Basis for Relief	Alternate Examinations or Testing	Justification for Granting Relief	Implementation Schedule
1PZR-W4ASE	RC System Pressurizer Safety Nozzle-to-Safe End Butt Weld	Exam Category B-F Item No. B05.040.004 - ASME Section XI, Appendix III, III-4420, 1989 Edition with No Addenda. Coverage from two beam path directions (See note below) 77.28% Volume Coverage	See Paragraph "A"	See Paragraph "F"	See Paragraphs "G and J"	See Paragraph "K"
1PZR-W4BSE	RC System Pressurizer Safety Nozzle-to-Safe End Butt Weld	Exam Category B-F Item No. B05.040.005 - ASME Section XI, Appendix III, III-4420, 1989 Edition with No Addenda. Coverage from two beam path directions (See note below) 86.00% Volume Coverage	See Paragraph "B"	See Paragraph "F"	See Paragraphs "G and J"	See Paragraph "K"
1PZR-W4CSE	RC System Pressurizer Safety Nozzle-to-Safe End Butt Weld	Exam Category B-F Item No. B05.040.006 - ASME Section XI, Appendix III, III-4420, 1989 Edition with No Addenda. Coverage from two beam path directions (See note below) 82.03% Volume Coverage	See Paragraph "C"	See Paragraph "F"	See Paragraphs "G and J"	See Paragraph "K"
1ND38-1	ND System Valve 1ND002A to Pipe Circumferential Weld	Exam Category B-J Item No. B09.011.104 IWB-2500-8(c), Volume C-D-E-F only 61.23% Volume Coverage	See Paragraph "D"	See Paragraph "F"	See Paragraph "H and J"	See Paragraph "K"
1BRHRHX-5-9	ND System RHR Heat Exchanger Shell-to-Flange Circum. Weld	Exam Category C-A Item No. C01.010.002 IWC-2500-1(a) 55.90% Volume Coverage	See Paragraph "E"	See Paragraph "F"	See Paragraph "I and J"	See Paragraph "K"

Notes: The examination shall be performed using a sufficiently long examination beam path to provide coverage of the required examination volume in two-beam path directions. The examination shall be performed from two sides of the weld, where practicable, or from one side of the weld, as a minimum.

See Attachment 1 for a drawing of the RHR Heat Exchanger welds listed above

See Attachment 2 for a drawing of the Pressurizer welds listed above

IV. Basis for Relief

Paragraph A: (The pressurizer safety valve nozzle material is SA-508 and the safe end is SA-182, Gr. F316L. The weld is 6.0 inches in diameter with a 0.96 inch wall thickness.)

Nozzle to Safe End Weld 1PZR-W4ASE cannot be examined from two beam path directions because the nozzle taper limits scanning from the nozzle side. This is a dissimilar metal weld joining a carbon steel nozzle to a stainless steel safe end. Coverage is limited to 77.28% of the required examination volume. This percentage of coverage represents the aggregate from all scans performed on the weld. Each scan is considered 25% of the total examination volume because four scans are required. One axial scan from the safe end side covered 100% of the examination volume in one direction; one axial scan from the nozzle side covered 9.12% of the examination volume; two circumferential scans covered 100% of the examination volume in two opposing directions. Thus, the required exam volume was fully scanned from three of the four required directions but the fourth scan from the nozzle side caused the limitation that resulted in less than 100% aggregate coverage from all scans. In order to achieve more coverage, the nozzle would have to be re-designed to allow scanning from both sides of the weld. (See note in Paragraph C below.)
(Examination data is shown in Attachment A.)

Paragraph B: (The pressurizer safety valve nozzle material is SA-508 and the safe end is SA-182, Gr. F316L. The weld is 6.0 inches in diameter with a 0.96 inch wall thickness.)

Nozzle to Safe End Weld 1PZR-W4BSE cannot be examined from two beam path directions because the nozzle taper limits scanning from the nozzle safe end. This is a dissimilar metal weld joining a carbon steel nozzle to a stainless steel safe end. Coverage is limited to 86.00% of the required examination volume. This percentage of coverage represents the aggregate from all scans performed on the weld. Each scan is considered 25% of the total examination volume because four scans are required. One axial scan from the safe end side covered 100% of the examination volume in one direction; one axial scan from the nozzle side covered 44.00% of the examination volume; two circumferential scans covered 100% of the examination volume in two opposing directions. Thus, the required exam volume was fully scanned from three of the four required directions but the fourth scan from the nozzle side caused the limitation that resulted in less than 100% aggregate coverage from all scans. In order to achieve more coverage, the nozzle would have to be re-designed to allow scanning from both sides of the weld. (See note in Paragraph C below.)
(Examination data is shown in Attachment B.)

Paragraph C: (The pressurizer safety valve nozzle material is SA-508 and the safe end is SA-182, Gr. F316L. The weld is 6.0 inches in diameter with a 0.96 inch wall thickness.)

Nozzle to Safe End Weld 1PZR-W4CSE cannot be examined from two beam path directions because the nozzle taper limits scanning from the nozzle safe end. This is a dissimilar metal weld joining a carbon steel nozzle to a stainless steel safe end. Coverage is limited to 82.03% of the required examination volume. This percentage of coverage represents the aggregate from all scans performed on the weld. Each scan is considered 25% of the total examination volume because four scans are required. One axial scan from the safe end side covered 100% of the examination volume in one direction; one axial scan from the nozzle side covered 28.15% of the examination volume; two circumferential scans covered 100% of the examination volume in two opposing directions. Thus, the required exam volume was fully scanned from three of the four required directions but the fourth scan from the nozzle side caused the limitation that resulted in less than 100% aggregate coverage from all scans. In order to achieve more coverage, the nozzle would have to be re-designed to allow scanning from both sides of the weld. (Examination data is shown in Attachment C.)

Note: Variations in the calculated coverage from the nozzle side of the three Pressurizer welds were the result of differences in the OD weld contours. These differences caused the distance from the weld centerline to the search unit exit point to change from weld to weld as shown on the attached UT profile / plot sheet sketches.

Paragraph D: [The residual heat removal (ND system) valve body and pipe material are both stainless steels. The weld is 12.0 inches in diameter with a 1.125 inch wall thickness.]

Valve 1ND002A to Pipe Weld 1ND38-1 cannot be examined from two beam path directions because the valve body taper limits scanning from the valve side. This is a similar metal weld joining a stainless steel valve to a stainless steel pipe. Coverage is limited to 61.23% of the required examination volume. This percentage of coverage represents the aggregate from all scans performed on the weld. One axial scan from the pipe side covered 54.88% of the examination volume in one direction; no axial scan was performed from the valve side. Two circumferential scans covered 100% of the examination volume in two opposing directions. Thus, the required exam volume was fully scanned from only the two circumferential directions. The partial scan from one axial direction and none from the other caused the limitation that resulted in less than 100% aggregate coverage from all scans. In order to achieve more coverage, the valve configuration would have to be re-designed to allow scanning from both sides of the weld. (Examination data is shown in Attachment D.)

Paragraph E: [The residual heat removal (ND system) heat exchanger shell material is SA-285-C and the flange is SA-105. The weld is 43.75 inches in diameter with a .875 inch wall thickness.]

This weld was radiographed to provide more exam volume coverage than was possible with ultrasonic examination. During the radiographic examination of Residual Heat Removal Heat Exchanger Shell to Flange Weld 1BRHRHX-5-9, 100% coverage of the required examination volume could not be obtained. The examination coverage was limited to 55.90%. Limitations were caused by the heat exchanger's shell-to-flange configuration. In order to achieve more coverage, the heat exchanger would have to be disassembled at the flange connection and the upper and lower sections of the vessel separated allowing access for the placement of the radiographic film on the inside surface of the weld, which is impractical. Ultrasonic examination of this weld and adjacent base metal would also require the disassembly of the flange connection; which is impractical.

(Examination data is shown in Attachment E.)

The limited radiographic (RT) examination of the Residual Heat Exchanger shell to flange weld was due to internal vessel divider plates, the external geometric configuration and limited access to the examination external surface due to the flange bolting material. Each of these specific exam interferences limited the radiographic examination of the required volume as discussed in the following paragraphs.

Internal Vessel Divider Plates

The vessel's internal divider plates are designed in a "T" configuration as shown on Attachment 1-Sheet 2, Detail A, and the Radiographic Technique sheet, in Attachment E. The internal divider plates come in contact with the examination area in three separate locations, identified as points A, B and C, which completely obstruct examination coverage of the weld and the required 0.5 inch of base metal on each side of the weld.

At point "A", 4.5 linear inches of the circumferential examination area was obstructed (film interval OR - 10, Attachment E) by the divider plate thickness and the angle through which the radiation from the source had to penetrate the divider plate to image the examination area on the opposite side.

At point "C", 4.875 linear inches of the circumferential examination area was obstructed (film interval 5E - 6) by the divider plate thickness and the angle through which the radiation from the source had to penetrate the divider plate to image the examination area on the opposite side.

At divider plate contact point "B", 0.750 linear inches of the circumferential examination area was obstructed (film interval 8 – 8X) by the divider plate thickness and by the divider plate weld metal.

External Shell to Flange Configuration and Flange Bolting

The flange weld is in close proximity to the flange bolting surface as shown on Attachment 1-Sheet 2, Detail B and has 52 flange studs with large heavy hex nuts. The close proximity of the studs and nuts to the outside surface of the vessel in conjunction with the nearness of the flange face restricted the placement of the RT film for complete examination coverage. During the examination, the radiographic film holders and backing leads were placed behind the bolting material, on the outside surface of the vessel and then slide onto the flange taper to the fullest extent possible. This provided for examination coverage of the required 0.5 inch base metal on the shell side of the weld and ~ 0.625 inches of 0.875 inch wide weld. The required 0.5 inch of base metal on the flange side, and an average of ~ 0.25 inch of the weld were not recorded on the film. The area of examination coverage and the obstructed area is shown on Attachment 1-Sheet 2, Detail B.

V. Alternate Examinations or Testing

Paragraph F:

The scheduled 10-year code examination was performed on the referenced area / weld and resulted in the noted limited coverage of the required ultrasonic volume. No alternate examinations or testing is planned for the area / weld during the current inspection interval.

VI. Justification for Granting Relief

Paragraph G:

Beginning in 1990 Duke Energy Corporation changed to refracted longitudinal wave search units to examine dissimilar metal (DM) welds based upon NRC Information Notice 90-30, "Ultrasonic Inspection Techniques for Dissimilar Metal Welds". The procedure used for DM weld examination complied with the requirements of ASME Section XI, Appendix III, 1989 Edition. The procedure required the use of refracted longitudinal waves to examine the weld and buttered material and shear waves to examine the wrought nozzle and safe end base materials. Duke Energy Corporation employed the best available manual techniques to examine DM welds prior to the implementation of Appendix VIII. Based on procedure development work using DM weld mock-ups containing thermal fatigue cracks, Duke Energy Corporation believes that ID initiated fatigue cracks exceeding the acceptance standards of IWB-3514 would have been detected.

The refracted longitudinal wave search units have an inherent limitation in that the useful portion of the sound beam lies in the first beam path leg between the transducer and the inside surface of the pipe. Beam paths beyond the inside surface of the pipe cannot be used to extend the examination coverage because of mode conversion that occurs at the inside surface. However, refracted longitudinal wave search units have better penetration through stainless steel weld metal than shear wave search units. When calibrating in accordance with ASME Section XI, Appendix III, there is not enough sound energy available to establish a distance-amplitude-correction curve beyond the inside surface notch located in the basic calibration block.

There were no examination findings and no flaws were detected during any of the previous inservice inspections. This weld was initially inspected by radiography and liquid penetrant examination during construction and verified to be free from unacceptable fabrication defects.

These Pressurizer nozzle-to-safe end butt welds are located inside containment and are part of the reactor coolant system pressure boundary. General Design Criterion 30, "Quality of Reactor Coolant Pressure Boundary," of Appendix A to 10 CFR Part 50, "General Design Criteria for Nuclear Power Plants," mandates

that means be provided for detecting and, to the extent practical, identifying the location of the source of reactor coolant leakage. If a leak were to develop at these weld locations, the instrumentation available to the operators for detection and monitoring of leakage would provide prompt and qualitative information necessary to permit them to take immediate corrective action. If a leak should develop in these aforementioned locations, the only corrective action would be to shutdown and depressurize the reactor coolant system, since the components are non-isolable.

Plant Technical Specifications dictate that a reactor coolant system water inventory balance be performed on a regular basis. A normal operating practice is to perform this computer based mass balance on a daily frequency and/or whenever the operators suspect any abnormal changes to other leakage detection systems. Plant Technical Specification requires that if the leak rate cannot be reduced below 1 gpm unidentified that the plant be put in hot standby within 6 hours and in cold shutdown within the following 30 hours. Leakage as a result of a failed weld discussed in this section would show up as unidentified leakage and be subject to the 1 gpm limit.

Other leakage detection systems available to the operator and dictated per plant technical specifications are:

- Containment Atmosphere Gaseous and Particulate Radioactivity Monitoring System (EMF monitors 38 & 39) which would detect airborne radiological activity;
- Containment Floor and Equipment Sump Level Monitoring Subsystem where unidentified accumulated water on the containment floor would be monitored and evaluated as sump level changes;
- Containment Ventilation Unit Condensate Drain Tank Level Monitoring Subsystem which collects and measures as unidentified leakage the moisture removed from the containment atmosphere.

Additionally, other indicators are also available to the operator that a leak exists:

- Containment Atmosphere Iodine Monitor (EMF 40)
- Charging / Letdown system mismatches;
- Containment humidity indications;
- Pre-Cycle walkdowns performed each outage while system is at operating temperature and pressure prior to criticality;
- Post-Cycle walkdowns performed at operating temperature and pressure performed during unit shutdown.

Potential Failure Mechanisms:

The pressurizer safety valve nozzle to safe-end butt weld joins two dissimilar metal components, a carbon steel vessel nozzle to a stainless steel forging safe end using inconel weld material. The weld is susceptible to two potential failure mechanisms, both of which are initiated from the inside diameter. The first is PWSCC due to wetted surface exposure to high temperature primary coolant system water. The second is thermal fatigue associated with high temperature differences experienced during unit heat-up and cool-down cycles.

The first mechanism, PWSCC, is eliminated by the existence of cladding material (SA-213, Gr. TP304) on the inside diameter of the nozzle that also covers the weld. The second mechanism, thermal fatigue, is not expected to result in cracking of the weld because it was accounted for by the number of acceptable unit heat-up and cool-down cycles within the primary coolant system design and is further minimized by the expected infrequent operation of the safety valves.

At the time of the inspection, Duke Power Corporation used the best available UT methodology to perform the weld examination such that evidence of thermal fatigue cracking would be expected to be detected in the areas covered by the sound beams.

See Paragraph J for additional justification information based on other code required testing.

Paragraph H:

Duke Energy Corporation does not take credit for the weld metal and far side examination volume when performing ultrasonic examination of similar metal austenitic piping welds where scanning is limited to one side of the weld. However, a best effort examination using a 60° refracted longitudinal wave search unit was conducted in one direction perpendicular to the weld covering 100% of the weld metal and 100% of the far side base. The near side was examined using a 60° shear wave search unit covering 100% of the base material volume. Circumferential scans using a 45° shear wave search unit were performed over 100% of the examination volume in two opposite directions.

ND system Valve 1ND002A to pipe weld 1ND38-1 is located inside containment. If a leak were to develop at this weld location discussed in this relief request, the instrumentation available to the operators for detection and monitoring of leakage would provide prompt and qualitative information necessary to permit them to take immediate corrective action. If a leak should develop in this aforementioned location, the probable corrective action would be shutdown and depressurize the steam generators, since the weld is non-isolable.

Other leakage detection systems available to the operator and dictated per plant technical specifications are:

- Containment Atmosphere Gaseous and Particulate Radioactivity Monitoring System (EMF monitors 38 & 39) which would detect airborne radiological activity;
- Containment Floor and Equipment Sump Level Monitoring Subsystem where unidentified accumulated water on the containment floor would be monitored and evaluated as sump level changes;
- Containment Ventilation Unit Condensate Drain Tank Level Monitoring Subsystem which collects and measures as unidentified leakage the moisture removed from the containment atmosphere.

Additionally, other indicators are also available to the operator that a leak exists or may be developing:

- Containment humidity indications;
- Low FWST Level annunciator;
- Pre-Cycle walkdowns performed each outage while system is at operating temperature and pressure prior to criticality;
- Post-Cycle walkdowns performed at operating temperature and pressure performed during unit shutdown.

See Paragraph J for additional justification information based on other code required testing.

Paragraph I:

Weld 1BRHRHX-5-9 on the ND Heat Exchanger is used to cool the water from the reactor coolant system (RCS) in Residual Heat Removal (RHR) mode or the Containment Sump in Containment Sump Recirculation. The ND System is normally in standby during power operations. When the RCS is less than 350° F, the ND system is aligned to RHR mode and the ND Heat Exchanger is used to remove decay heat during shutdown operations. In emergency core cooling mode, the Heat Exchanger is used to remove the heat energy from containment prior to the ND system returning the water back to containment.

The area that contains this Heat Exchanger to flange weld is surveyed twice a day by Operations staff during their routine rounds. One of the items that must be checked off is the general condition of the room containing

the Heat Exchanger. It is reasonable for the operator making these rounds to detect any external leaks from this weld.

This same area is also surveyed once a week by a periodic test that is used to specifically look for radioactive leaks outside containment. This area must be surveyed and signed off. If a leak were encountered, it would be written up in a work request and Problem Investigation Process form filled out. The Fluid Leak Management Process then examines the leak. The leak is either repaired or set up for periodic monitoring. A leak in the ND system would also have to be entered into the Emergency Core Cooling System Leakage Program.

Potential Failure Mechanisms:

The residual heat removal heat exchanger shell to flange circumferential weld joins two carbon steel components using compatible weld material. The weld is susceptible to one failure mechanism, thermal fatigue, that is initiated from the inside diameter of the weld and is associated with high temperature differences experienced during unit heat-up and cool-down cycles. This mechanism is not expected to result in cracking of the weld because it was accounted for by the number of acceptable heat-up and cool-down cycles factored into the system design.

At the time of the inspection, Duke Power Corporation used the best available RT methodology to perform the weld examination such that evidence of thermal fatigue cracking, consistent with the fatigue type cracks that are introduced into Performance Demonstration Initiative (PDI) UT samples, should have been detected in the areas covered by the RT exam.

See Paragraph J for additional justification information based on other code required testing.

Paragraph J:

Duke Energy proposes to use the code required pressure test and VT-2 visual examination to compliment the limited examination coverage. The Code requires, for Class 1 Components (reference Table IWB-2500-1, Item Numbers B15.20 and B15.50) that a system leakage test be performed after each refueling outage. Additionally, a system hydrostatic test (reference Table IWB-2500-1, Item Numbers B15.21 and B15.51) is required once during each 10-year inspection interval.

The Code requires, for Class 2 Components (reference Table IWC-2500-1, Item Number C7.10) that a system pressure test be performed each inspection period. Additionally a system hydrostatic test (reference Table IWC-2500-1, Item Number C07.020) is required once during each 10-year inspection interval. These tests require a VT-2 visual examination for evidence of leakage. This testing will provide adequate assurance of pressure boundary integrity.

VII. Implementation Schedule

Paragraph K:

The scheduled second 10-year interval plan code examination was performed on the referenced welds resulting in limited volumetric coverage. No additional examinations are planned for the welds during the current inspection interval. The same welds may be examined again as part of the next (third) 10-year interval plan, depending on the applicable code year edition and addenda requirements adopted in the future.

VIII. Other Information

The following individuals contributed to the development of this RFR:

Jim McArdle (NDE Level III Inspector) provided UT related information for Sections II through V

Tim Tucker (NDE Level III Inspector) provided RT related information for Sections II through V

David Goforth (CNS Systems Engineer) provided a portion of Section VI

Mark Pyne (G.O. Engineering) provided a portion of Section VI.

Andy Hogge (Sponsor) compiled the remaining sections

Sponsored By:

A. J. Hogge Jr.

Date

5/5/2003

Approved By:

R. Kevin Pyne

Date

5/5/03

Attachment A

Weld 1PZR-W4ASE Examination Data

Attachment B

Weld 1PZR-W4BSE Examination Data

Attachment C

Weld 1PZR-W4CSE Examination Data

Attachment D

Weld 1ND38-1 Examination Data

Attachment E

Weld 1BRHRHX-5-9 Examination Data

Attachment 1

RHR Heat Exchanger Equipment Drawing

Attachment 2

Pressurizer Safety Nozzle & Weld Detail Drawing

DUKE POWER COMPANY										Exam Start: 0505		Form NDE-UT-2A		
ULTRASONIC EXAMINATION DATA SHEET FOR PLANAR REFLECTORS										Exam Finish: 0532		Revision 4		
Station: Catawba			Unit: 1		Component/Weld ID: 1PZR-W4ASE						Date: 4/29/2002			
Weld Length (in.): 20.8			Surface Condition: AS GROUND			Lo: 9.1.1.4		Surface Temperature: 81 ° F						
Examiner: David Zimmerman <i>David Zimmerman</i>			Level: III		Scans: 45 <input type="checkbox"/> 72** dB 70 <input type="checkbox"/> _____ dB 45T <input type="checkbox"/> 62 dB 70T <input type="checkbox"/> _____ dB 60 <input type="checkbox"/> _____ dB 60T <input type="checkbox"/> _____ dB Other: _____ dB					Pyrometer S/N: ,MCNDE 27228				
Examiner: Gary J. Moss <i>Gary J. Moss</i>			Level: II							Cal Due: 7/3/2002				
Procedure: NDE-610 Rev: 4			FC: *							Configuration: CIRC. WELD				
Calibration Sheet No: 0201046, 0201047										S2 Flow S1				
										NOZZLE to SAFE-END				
										Scan Surface: OD				
										Applies to NDE-680 only				
										Skew Angle: N/A				

IND #	<i>4</i>	Max % Ref	Mp Max	W Max	L Max	L1	L2	W1	Mp1	W2	Mp2	Beam Dir.	Exam Surf.	Scan	Damps
		DO NOT WRITE IN THIS SPACE				20%dac HMA	20%dac HMA	20%dac HMA	20%dac HMA	20%dac HMA	20%dac HMA		DO NOT WRITE IN THIS SPACE	WRITE SPACE	
						50%dac	50%dac	50%dac	50%dac	50%dac	50%dac				
						100%dac	100%dac	100%dac	100%dac	100%dac	100%dac				
NRI	45°														

Remarks: *FC 02-10, 01-03, 98-20, 97-01. **Scanned at 72dB due to signal/noise ratio.			
Limitations: (see NDE-UT-4) <input type="checkbox"/> 90% or greater coverage obtained: yes <input type="checkbox"/> no <input type="checkbox"/>			Sheet <u>1</u> of <u>4</u>
Reviewed By: <i>DE Hansen</i>	Level: <u>III</u>	Date: <u>5/15/02</u>	Authorized Inspector: <i>Robert M. [illegible]</i>
		Date: <u>5-22-02</u>	Item No: B05.040.004

REQUEST FOR RELIEF #02-002 ATTACHMENT A
REV. 1

APR 6/18/02

DUKE POWER COMPANY

ISI LIMITATION REPORT

FORM NDE-UT-4

Revision 1

Component/Weld ID: 1PZR-W4ASE

Item No: B05.040.004

Remarks:

☐ NO SCAN SURFACE BEAM DIRECTION
☒ LIMITED SCAN ☐ 1 ☐ 2 ☐ 1 ☐ 2 ☐ cw ☐ ccw
 FROM L _____ to L _____ INCHES FROM WO _____ 1.0 _____ to _____ BEYOND _____
 ANGLE: ☐ 0 ☐ 45 ☐ 60 ☐ Other _____ FROM _____ 0 _____ DEG to _____ 360 _____ DEG

NOZZLE CONFIGURATION

☐ NO SCAN SURFACE BEAM DIRECTION
☐ LIMITED SCAN ☐ 1 ☐ 2 ☐ 1 ☐ 2 ☐ cw ☐ ccw
 FROM L _____ to L _____ INCHES FROM WO _____ to _____
 ANGLE: ☐ 0 ☐ 45 ☐ 60 ☐ Other _____ FROM _____ DEG to _____ DEG

☐ NO SCAN SURFACE BEAM DIRECTION
☐ LIMITED SCAN ☐ 1 ☐ 2 ☐ 1 ☐ 2 ☐ cw ☐ ccw
 FROM L _____ to L _____ INCHES FROM WO _____ to _____
 ANGLE: ☐ 0 ☐ 45 ☐ 60 ☐ Other _____ FROM _____ DEG to _____ DEG

☐ NO SCAN SURFACE BEAM DIRECTION
☐ LIMITED SCAN ☐ 1 ☐ 2 ☐ 1 ☐ 2 ☐ cw ☐ ccw
 FROM L _____ to L _____ INCHES FROM WO _____ to _____
 ANGLE: ☐ 0 ☐ 45 ☐ 60 ☐ Other _____ FROM _____ DEG to _____ DEG

Prepared By: *David K. F.*

Level: III

Date: 4/29/2002

Sketch(s) attached ☐ yes ☐ no

Sheet 2 of 4

Reviewed By: *DE Houser*


Date: 5/15/02

Authorized Inspector: *Robert M. L. Jr.*

Date: 5.22.02

Revision .1

EXAMINATION SURFACE 2



DUKE POWER COMPANY Limited Examination Coverage Worksheet	NDE-91-1
	Revision 0

Examination Volume/Area Defined <input type="checkbox"/> Base Metal <input type="checkbox"/> Weld <input type="checkbox"/> Near Surface <input type="checkbox"/> Bolting <input type="checkbox"/> Inner Radius	
Area Calculation .657 SQ. IN. SEE ATTACHED	Volume Calculation

Coverage Calculations							
Scan #	Angle	Beam Direction	Area Examined (sq.in.)	Length Examined (in.)	Volume Examined (cu.in.)	Volume Required (cu.in.)	Percent Coverage
1	45°	CW	.657	20.8	13.7	13.7	
2	45°	CCW	.657	20.8	13.7	13.7	
3	45°	S1	.060	20.8	1.25	13.7	
4	45°	S2	.657	20.8	13.7	13.7	
					42.35	54.8	77.28

		Item No:	B05.040.004
Prepared By:	<i>David K. Z...</i>	Level:	<i>III</i>
Date:	<i>4/29/02</i>		
Reviewed By:	<i>D.E. Hansen</i>	Level:	<i>III</i>
Date:	<i>5/15/02</i>		

pg 4 of 4

DUKE POWER COMPANY										Exam Start: 0508		Form NDE-UT-2A		
ULTRASONIC EXAMINATION DATA SHEET FOR PLANAR REFLECTORS										Exam Finish: 0527		Revision 4		
Station: Catawba			Unit: 1		Component/Weld ID: 1PZR-W4BSE						Date: 4/29/2002			
Weld Length (in.): 20.8			Surface Condition: AS GROUND			Lo: 9.1.1.4		Surface Temperature: 81 ° F						
Examiner: David Zimmerman <i>David Zimmerman</i>			Level: III		Scans: 45 <input type="checkbox"/> 72** dB 70 <input type="checkbox"/> _____ dB 45T <input type="checkbox"/> 62 dB 70T <input type="checkbox"/> _____ dB 60 <input type="checkbox"/> _____ dB 60T <input type="checkbox"/> _____ dB Other: _____ dB				Pyrometer S/N: _____, MCNDE 27228					
Examiner: Gary J. Moss <i>Gary J. Moss</i>			Level: II						Cal Due: 7/3/2002					
Procedure: NDE-610 Rev: 4			FC: *						Configuration: CIRC. WELD					
Calibration Sheet No: 0201046, 0201047									S2 _____ Flow _____ S1 _____ NOZZLE to SAFE-END Scan Surface: OD					
										Applies to NDE-680 only				
										Skew Angle: N/A				

IND #	<i>X</i>	Max % Ref	Mp Max	W Max	L Max	L1	L2	W1	Mp1	W2	Mp2	Beam Dir.	Exam Surf.	Scan	Damps
		DO NOT WRITE IN THIS SPACE				20%dac HMA	20%dac HMA	20%dac HMA	20%dac HMA	20%dac HMA	20%dac HMA		DO NOT WRITE IN THIS SPACE	WRITE SPACE	
						50%dac	50%dac	50%dac	50%dac	50%dac	50%dac				
						100%dac	100%dac	100%dac	100%dac	100%dac	100%dac				
NRI	45°														

Remarks: *FC 02-10, 01-03, 98-20, 97-01. ** Scanned at 72dB due to signal/noise ratio.			
Limitations: (see NDE-UT-4) <input type="checkbox"/> 90% or greater coverage obtained: yes <input type="checkbox"/> no <input type="checkbox"/>			Sheet <u>1</u> of <u>4</u>
Reviewed By: <i>DeHouwer</i>	Level: <u>III</u>	Date: <u>5/15/02</u>	Authorized Inspector: <i>Robert M. Sullivan</i> Date: <u>5-22-02</u> Item No: B05.040.005

REQUEST FOR RELIEF #02-002 ATTACHMENT B
REV. 1

RJH
6/18/02

DUKE POWER COMPANY

ISI LIMITATION REPORT

FORM NDE-UT-4

Revision 1

Component/Weld ID: 1PZR-W4BSE		Item No: B05.040.005		Remarks:	
<input type="checkbox"/> NO SCAN <input checked="" type="checkbox"/> LIMITED SCAN		SURFACE <input type="checkbox"/> 1 <input type="checkbox"/> 2		BEAM DIRECTION <input type="checkbox"/> 1 <input type="checkbox"/> 2 <input type="checkbox"/> cw <input type="checkbox"/> ccw	
FROM L _____ to L _____		INCHES FROM WO _____ 1.0 _____ to _____ BEYOND _____		NOZZLE CONFIGURATION	
ANGLE: <input type="checkbox"/> 0 <input checked="" type="checkbox"/> 45 <input type="checkbox"/> 60 <input type="checkbox"/> Other _____		FROM _____ 0 _____ DEG to _____ 360 _____ DEG			
<input type="checkbox"/> NO SCAN <input type="checkbox"/> LIMITED SCAN		SURFACE <input type="checkbox"/> 1 <input type="checkbox"/> 2		BEAM DIRECTION <input type="checkbox"/> 1 <input type="checkbox"/> 2 <input type="checkbox"/> cw <input type="checkbox"/> ccw	
FROM L _____ to L _____		INCHES FROM WO _____ to _____			
ANGLE: <input type="checkbox"/> 0 <input type="checkbox"/> 45 <input type="checkbox"/> 60 <input type="checkbox"/> Other _____		FROM _____ DEG to _____ DEG			
<input type="checkbox"/> NO SCAN <input type="checkbox"/> LIMITED SCAN		SURFACE <input type="checkbox"/> 1 <input type="checkbox"/> 2		BEAM DIRECTION <input type="checkbox"/> 1 <input type="checkbox"/> 2 <input type="checkbox"/> cw <input type="checkbox"/> ccw	
FROM L _____ to L _____		INCHES FROM WO _____ to _____			
ANGLE: <input type="checkbox"/> 0 <input type="checkbox"/> 45 <input type="checkbox"/> 60 <input type="checkbox"/> Other _____		FROM _____ DEG to _____ DEG			
<input type="checkbox"/> NO SCAN <input type="checkbox"/> LIMITED SCAN		SURFACE <input type="checkbox"/> 1 <input type="checkbox"/> 2		BEAM DIRECTION <input type="checkbox"/> 1 <input type="checkbox"/> 2 <input type="checkbox"/> cw <input type="checkbox"/> ccw	
FROM L _____ to L _____		INCHES FROM WO _____ to _____			
ANGLE: <input type="checkbox"/> 0 <input type="checkbox"/> 45 <input type="checkbox"/> 60 <input type="checkbox"/> Other _____		FROM _____ DEG to _____ DEG			
Prepared By: <i>David R. B.</i>		Level: III Date: 4/29/2002		Sketch(s) attached <input type="checkbox"/> yes <input type="checkbox"/> no Sheet <u>2</u> of <u>4</u>	
Reviewed By: <i>De Housen</i>		Date: <u>5/15/02</u>		Authorized Inspector: <i>Robert M. Sullivan</i> Date: <u>5.22.02</u>	

DUKE POWER COMPANY Limited Examination Coverage Worksheet	NDE-91-1
	Revision 0

Examination Volume/Area Defined <input type="checkbox"/> Base Metal <input type="checkbox"/> Weld <input type="checkbox"/> Near Surface <input type="checkbox"/> Bolting <input type="checkbox"/> Inner Radius	
Area Calculation .625 SQ. IN. SEE ATTACHED	Volume Calculation

Coverage Calculations							
Scan #	Angle	Beam Direction	Area Examined (sq.in.)	Length Examined (in.)	Volume Examined (cu.in.)	Volume Required (cu.in.)	Percent Coverage
1	45°	CW	.625	20.8	13	13	
2	45°	CCW	.625	20.8	13	13	
3	45°	S2	.625	20.8	13	13	
4	45°	S1	.275	20.8	13	13	
					44.72	52	86.00


		Item No:	B05.040.005
Prepared By:	<i>David K. Z...</i>	Level:	<i>III</i>
Date:	<i>4/29/02</i>		
Reviewed By:	<i>M.E. Hansen</i>	Level:	<i>III</i>
Date:	<i>5/15/02</i>		

PB 3 of 4

DUKE POWER COMPANY
UT PROFILE/PLOT SHEET

NDE-UT-5

Revision 1



Component ID/Weld No.

IPZR - W4BSE

Remarks:

PROFILE TAKEN FROM PREVIOUS DATA

270

Profile taken
at: ho

90

Item No: B05,040,005

Examiner: David K. Z

Level: III

Date: 4/29/02

Reviewed By: ME Dwyer

Level: III

Date: 5-15-02

Authorized Inspector:

Robert M. Lill

Date: 5-22-02

180 Sheet 4 of 4

DUKE POWER COMPANY										Exam Start: 0512		Form NDE-UT-2A		
ULTRASONIC EXAMINATION DATA SHEET FOR PLANAR REFLECTORS										Exam Finish: 0522		Revision 4		
Station: Catawba			Unit: 1		Component/Weld ID: 1PZR-W4CSE					Date: 4/29/2002				
Weld Length (in.): 20.8			Surface Condition: AS GROUND			Lo: 9.1.1.4		Surface Temperature: 81 ° F						
Examiner: Winfred C. Leeper <i>Winfred C. Leeper</i>			Level: II		Scans: 45 <input type="checkbox"/> 72** dB 70 <input type="checkbox"/> _____ dB 45T <input type="checkbox"/> 62 dB 70T <input type="checkbox"/> _____ dB 60 <input type="checkbox"/> _____ dB 60T <input type="checkbox"/> _____ dB Other: _____ dB					Pyrometer S/N: MCNDE 27228				
Examiner: Marion T. Weaver <i>Marion T. Weaver</i>			Level: II							Cal Due: 7/3/2002				
Procedure: NDE-610 Rev: 4			FC: *							Configuration: CIRC. WELD				
Calibration Sheet No: 0201046, 0201047										S2 Flow S1 NOZZLE to SAFE-END Scan Surface: OD Applies to NDE-680 only Skew Angle: N/A				

IND #	<input checked="" type="checkbox"/>	Max % Ref	Mp Max	W Max	L Max	L1	L2	W1	Mp1	W2	Mp2	Beam Dir.	Exam Surf.	Scan	Damps
		DO NOT WRITE IN THIS SPACE				20%dac HMA	20%dac HMA	20%dac HMA	20%dac HMA	20%dac HMA	20%dac HMA		DO NOT WRITE IN THIS SPACE	WRITE	
						50%dac	50%dac	50%dac	50%dac	50%dac	50%dac				
						100%dac	100%dac	100%dac	100%dac	100%dac	100%dac				
NRI	45°														

Remarks: *FC 02-10, 01-03, 98-20, 97-01. ** Scanned at 72dB due to signal/noise ratio.			
Limitations: (see NDE-UT-4) <input type="checkbox"/> 90% or greater coverage obtained: yes <input type="checkbox"/> no <input type="checkbox"/>			Sheet <u>1</u> of <u>4</u>
Reviewed By: <i>DeHansen</i>	Level: <u>III</u>	Date: <u>5/15/02</u>	Authorized Inspector: <i>Robert McNeil</i> Date: <u>5-22-02</u> Item No: B05.040.006

REQUEST FOR RELIEF #02-002 ATTACHMENT C
REV. 1

RTH 6/19/02

DUKE POWER COMPANY
ISI LIMITATION REPORT

FORM NDE-UT-4

Revision 1

Component/Weld ID: 1PZR-W4CSE

Item No: B05.040.006

Remarks:

☐ NO SCAN
☒ LIMITED SCAN

SURFACE ☐ 1 ☐ 2
 BEAM DIRECTION ☐ 1 ☐ 2 ☐ cw ☐ ccw

FROM L _____ to L _____ INCHES FROM WO 1.0 to BEYOND

ANGLE: ☐ 0 ☒ 45 ☐ 60 ☐ Other _____ FROM 0 DEG to 360 DEG

NOZZLE CONFIGURATION

☐ NO SCAN
☐ LIMITED SCAN

SURFACE ☐ 1 ☐ 2
 BEAM DIRECTION ☐ 1 ☐ 2 ☐ cw ☐ ccw

FROM L _____ to L _____ INCHES FROM WO _____ to _____

ANGLE: ☐ 0 ☐ 45 ☐ 60 ☐ Other _____ FROM _____ DEG to _____ DEG

☐ NO SCAN
☐ LIMITED SCAN

SURFACE ☐ 1 ☐ 2
 BEAM DIRECTION ☐ 1 ☐ 2 ☐ cw ☐ ccw

FROM L _____ to L _____ INCHES FROM WO _____ to _____

ANGLE: ☐ 0 ☐ 45 ☐ 60 ☐ Other _____ FROM _____ DEG to _____ DEG

☐ NO SCAN
☐ LIMITED SCAN

SURFACE ☐ 1 ☐ 2
 BEAM DIRECTION ☐ 1 ☐ 2 ☐ cw ☐ ccw

FROM L _____ to L _____ INCHES FROM WO _____ to _____

ANGLE: ☐ 0 ☐ 45 ☐ 60 ☐ Other _____ FROM _____ DEG to _____ DEG

Prepared By: Daniel G. B.

Level: III

Date: 4/29/2002

Sketch(s) attached ☐ yes ☐ no

Sheet 2 of 4

Reviewed By: M.E. Jensen

Date: 5/15/02


Authorized Inspector: Robert M. Lill

Date: 5-22-02

DUKE POWER COMPANY
UT PROFILE/PLOT SHEET

NDE-UT-5

Revision 1



Component ID/Weld No. IP2P-W4CSE

Remarks: PROFILE TAKEN FROM PREVIOUS DATA

Item No: BOS.060.006

Examiner: *David K. A.*

Level: *III*

Date: 4/29/02


Reviewed By: *De Auser*

Level: *III*

Date: 5/15/02

Authorized Inspector: *Robert McNeil*

Date: 5-22-02



DUKE POWER COMPANY Limited Examination Coverage Worksheet	NDE-91-1
	Revision 0

Examination Volume/Area Defined				
<input type="checkbox"/> Base Metal	<input type="checkbox"/> Weld	<input type="checkbox"/> Near Surface	<input type="checkbox"/> Bolting	<input type="checkbox"/> Inner Radius

Area Calculation	Volume Calculation
.675 SQ. IN. SEE ATTACHED SKETCH	

Coverage Calculations							
Scan #	Angle	Beam Direction	Area Examined (sq.in.)	Length Examined (in.)	Volume Examined (cu.in.)	Volume Required (cu.in.)	Percent Coverage
1	45°	CW	.675	20.8	14.04	14.04	
2	45°	CCW	.675	20.8	14.04	14.04	
3	45°	S2	.675	20.8	14.04	14.04	
4	45°	S1	.19	20.8	3.95	14.04	
					46.07	56.16	82.03

		Item No:	B05.040.006
Prepared By: <i>David K. B.</i>	Level: <i>III</i>	Date:	<i>4/29/02</i>
Reviewed By: <i>DE Hansen</i>	Level: <i>III</i>	Date:	<i>5/15/02</i>

PS 4 of 4

Catawba Unit #1
EOC13

Item # B09.011.104
Weld # 1N038-1

No Data Recorded. Reference Calibration Sheet #'s

0201026 45°/60°

0201027 60° L

REQUEST FOR RELIEF #02-002 ATTACHMENT D
REV.1

PG 1 OF 4 ASH 6/19/02

DUKE POWER COMPANY
ISI LIMITATION REPORT

FORM NDE-UT-4

Revision 1

Component/Weld ID: 1ND38-1		Item No: B09.011.104		Remarks:	
<input checked="" type="checkbox"/> NO SCAN <input type="checkbox"/> LIMITED SCAN		SURFACE <input checked="" type="checkbox"/> 1 <input type="checkbox"/> 2		BEAM DIRECTION <input type="checkbox"/> 1 <input checked="" type="checkbox"/> 2 <input type="checkbox"/> cw <input type="checkbox"/> ccw	
FROM L _____ to L _____		INCHES FROM WO _____ C/L _____ to _____ Beyond _____		Valve Configuration	
ANGLE: <input type="checkbox"/> 0 <input type="checkbox"/> 45 <input checked="" type="checkbox"/> 60 <input type="checkbox"/> Other _____		FROM _____ 0 DEG to _____ 360 DEG			
<input type="checkbox"/> NO SCAN <input type="checkbox"/> LIMITED SCAN		SURFACE <input type="checkbox"/> 1 <input type="checkbox"/> 2		BEAM DIRECTION <input type="checkbox"/> 1 <input type="checkbox"/> 2 <input type="checkbox"/> cw <input type="checkbox"/> ccw	
FROM L _____ to L _____		INCHES FROM WO _____ to _____			
ANGLE: <input type="checkbox"/> 0 <input type="checkbox"/> 45 <input type="checkbox"/> 60 <input type="checkbox"/> Other _____		FROM _____ DEG to _____ DEG			
<input type="checkbox"/> NO SCAN <input type="checkbox"/> LIMITED SCAN		SURFACE <input type="checkbox"/> 1 <input type="checkbox"/> 2		BEAM DIRECTION <input type="checkbox"/> 1 <input type="checkbox"/> 2 <input type="checkbox"/> cw <input type="checkbox"/> ccw	
FROM L _____ to L _____		INCHES FROM WO _____ to _____			
ANGLE: <input type="checkbox"/> 0 <input type="checkbox"/> 45 <input type="checkbox"/> 60 <input type="checkbox"/> Other _____		FROM _____ DEG to _____ DEG			
<input type="checkbox"/> NO SCAN <input type="checkbox"/> LIMITED SCAN		SURFACE <input type="checkbox"/> 1 <input type="checkbox"/> 2		BEAM DIRECTION <input type="checkbox"/> 1 <input type="checkbox"/> 2 <input type="checkbox"/> cw <input type="checkbox"/> ccw	
FROM L _____ to L _____		INCHES FROM WO _____ to _____			
ANGLE: <input type="checkbox"/> 0 <input type="checkbox"/> 45 <input type="checkbox"/> 60 <input type="checkbox"/> Other _____		FROM _____ DEG to _____ DEG			
Prepared By: Jay A. Eaton <i>[Signature]</i>		Level: III Date: 5/2/2002		Sketch(s) attached <input checked="" type="checkbox"/> yes <input type="checkbox"/> no Sheet <u>2</u> of <u>4</u>	
Reviewed By: <i>[Signature]</i>		Date: 5-4-02		Authorized Inspector: <i>[Signature]</i> Date: 5-8-02	

DUKE POWER COMPANY
UT PROFILE/PLOT SHEET


NDE-UT-5

Revision 1

EXAMINATION SURFACE 1 - ^{S/S} VALVE

WELD

S/S PIPE - EXAMINATION SURFACE 2



Component ID/Weld No. IND38-1

Remarks:

Examiner:

Reviewed By:

Authorized Inspector:

Item No: B09.011.104


Level: III

Date: 5/1/02

Level: IV

Date: 5-4-02

Date: 5-8-02





DUKE POWER COMPANY Limited Examination Coverage Worksheet	NDE-91-1
	Revision 0

Examination Volume/Area Defined	
<input checked="" type="checkbox"/> Base Metal <input checked="" type="checkbox"/> Weld <input type="checkbox"/> Near Surface <input type="checkbox"/> Bolting <input type="checkbox"/> Inner Radius	
Area Calculation	Volume Calculation
0.375" X 1.5" = 0.563 SQ. IN.	0.563 X 40.1" = 22.58 CU.IN.

Coverage Calculations							
Scan #	Angle	Beam Direction	Area Examined (sq.in.)	Length Examined (in.)	Volume Examined (cu.in.)	Volume Required (cu.in.)	Percent Coverage
1	45°	CW	0.563	40.1	22.58	22.58	100.00
2	45°	CCW	0.563	40.1	22.58	22.58	100.00
3	60°	S1	0.253	40.1	10.14	22.58	44.91
4	60°	S2	0	0	0	22.58	0.00
		Total	Aggregate	Coverage	55.3	90.32	61.23
		60°L Wave	Supplement	Coverage			
3	60°L	S1	0.309	40.1	12.391	22.58	54.88

54.88% of 1 scan (25%) = 13.72% of total weld.

		Item No:	B09.011.104
Prepared By: Jay A. Eaton		Level: III	Date: 5/1/2002
Reviewed By: 		Level: IB	Date: 5-4-02

PS 4 of 4

DUKE POWER COMPANY

RADIOGRAPHIC EXAMINATION REPORT / TECHNIQUE

Weld / Component ID. 1BRHRHX-5-9 Project Catawba Nuclear Station
 Procedure No./Rev. NDE 12/11 Acceptance/Reporting Standards ASME
 Radiographer Roger L. Gantt Level II Date 05-04-02 Code Reference ASME Sec. XI
 R.L. Gantt

Material: CS ☒ SS ☐ Diameter 43.75" Thickness .875"
 Source: Ir-192 Size: .142" Curies: 91 Estimated Weld Build-Up .0625" SFD 21.937"
 IQI: Film Side ☒ Source Side ☐ 20 Size(s) IQI Design: Standard Hole-Type
 Film View: Single ☒ Composite ☐ Number of Film Per Cassette: 2 Film Stand Off NA
 Film Brand/Type: Front Fuji 80 Center NA Back Fuji 80 Shim Size(s): NA
 Screen Thickness: Front .010" Center NA Back .010" (Ug = Ft/D) Actual Ug: .006"
 Exposure Time: Hrs. NA Min. *SEE ATTACHED Thicker member used as shim: ☒

TECHNIQUE SET UP

A 	C 	E 	F 	G 	H 	<input checked="" type="checkbox"/> I Other SEE ATTACHED SKETCH Draw Skc
B	D	Offset Single Wall View	Offset Double Wall View	Superimposed Double Wall View	Single Wall Exposure, Film Inside Pipe	

FILM REVIEW

Interval	Date	Indication	Length/Size	Reviewer	Level	Date	Accept	Reject	Report	Reshoot
0-1	05-04-02	8,12		OKT	III	05-04-02	✓			
1-2	05-04-02	8		OKT	III	05-04-02	✓			
2-3	05-04-02	8		OKT	III	05-04-02	✓			
3-4	05-04-02	8,12		OKT	III	05-04-02	✓			
4-5	05-04-02	8		OKT	III	05-04-02	✓			
5E-6	05-04-02			OKT	III	05-04-02	✓			
6-7	05-04-02	8		OKT	III	05-04-02	✓			
7-8	05-04-02			OKT	III	05-04-02	✓			
8X-9	05-04-02			OKT	III	05-04-02	✓			
9-10	05-04-02	12		OKT	III	05-04-02	✓			
10-0R	05-04-02			OKT	III	05-04-02	✓			

Indication and flaw types:	1. Incomp. Fusion	4. Unconsumed Insert	7. Undercut	10. Convexity	13. Surface
	2. Incomp. Pen.	5. Crack	8. Porosity	11. Concavity	14. Inclusion
	3. Excessive Pen.	6. Slag	9. Tungsten	12. Film Artifact	15.

Exam Limitations: ☒ Yes: 55.878% Examined ☐ No: (100% Examined)

Comments:

Second Review Robert M. Gantt Level III Date 05-04-02
 ANI/ANII Review Robert M. Gantt Date 5-6-02
 Item No. C01.010.002

REQUEST FOR RELIEF #02-002 REV. 1 ATTACHMENT E




ASH
6/14/02

1BRHRHX-5-9
 COI-010.002

RADIOGRAPHIC TECHNIQUE I

Date: 5-4-02


Approved: *T. L. Tuck*
 RT Level III




Exposure Times

0-1	<u>3 min.</u>
1-2	<u>3 min.</u>
2-3	<u>3 min.</u>
3-4	<u>3 min.</u>
4-5	<u>3 min.</u>
5E-6	<u>8 min.</u>
6-7	<u>5 min 50 sec.</u>
7-8	<u>5 min 50 sec.</u>
8X-9	<u>5 min 50 sec.</u>
9-10	<u>5 min 50 sec.</u>
10-OR	<u>10 min 50 sec.</u>

DUKE POWER COMPANY						NDE-91-1	
Limited Examination Coverage Worksheet						Revision 0	
Examination Volume/Area Defined							
Base Metal <input checked="" type="checkbox"/>		Weld <input checked="" type="checkbox"/>		Near Surface <input type="checkbox"/>		Bolting <input type="checkbox"/>	
Inner Radius <input type="checkbox"/>							
Area Calculation				Volume Calculation			
Required exam Area = 258.45 Area examined = 144.47 $144.47 \div 258.45 \times 100 = 55.898\%$ * See note below							
Coverage Calculations							
Scan #	Angle	Beam Direction	Area Examined (sq.in.)	Length Examined (in)	Volume Examined (cu.in.)	Volume Required (cu.in.)	Percent Coverage
<p>* Notes</p> <p>1. Required area calculation: weld length = 137.84" weld width = .875" Base metal = 1" (.5" each side)</p> <p style="margin-left: 40px;">$137.84 \times 1.875 = 258.45 \text{ sq.in.}$</p> <p>2. Area examined calculation: The area examined was determined from measurements taken on each radiographic interval</p> <p>3. Limitation due to configuration. 100% of base metal on the flange side and a portion of the weld was not examined.</p>							
						Item No: C01.010.002	
Prepared BY: <u>TL Turner</u>		Level: <u>III</u>		Date: <u>5-4-02</u>			
Reviewed By: <u>James K. Ford</u>		Level: <u>III</u>		Date: <u>5-4-02</u>			



NOTE - SAME AS J-2267-1
EXCEPT AS NOTED



ELEV. J-2267.3 (4) REQ'D
NOTE: SAME AS J-2267.1
EXCEPT AS NOTED

7-2627-30	RS-707	546-AAZ-215-35C-D	BHNRHS2	ODP
7-2627-3C	RS-707	546-AAZ-215-35C-D	BHNRHS1	ODP
7-2627-3B	RS-707	546-AAZ-215-35S-BHNRHS2	ODP	
7-2627-3A	RS-707	546-AAZ-215-35S-BHNRHS1	ODP	
7-2627-HH	RS-653	546-AAZ-215-354-BHNRHS2	CDE	
7-2627-GH	RS-653	546-AAZ-215-354-BHNRHS1	CDE	
7-2627-HF	RS-653	546-AAZ-215-353-BHNRHS2	CCC	
7-2627-HG	RS-653	546-AAZ-215-353-BHNRHS1	CCC	
7-2627-I	RS-653	546-AAZ-215-353-BHNRHS1	CCC	
7-2627-C	RS-653	546-AAZ-215-353-BHNRHS1	CCC	
7-2627-B	RS-653	546-AAZ-215-353-BHNRHS1	CCC	
7-2627-A	RS-653	546-AAZ-215-353-BHNRHS1	CCC	
7-2627-JB	RS-653	546-AAZ-215-351-BHNRHS2	CAR	
7-2627-H	RS-653	546-AAZ-215-351-BHNRHS1	CAR	
CDT JOB NO	FEW NO	W.E.P.O. NO	SPIN NO	PLANT

NOZZLE SCHEDULE					
MARK	SIZE	SCH	RATING	PURPOSE	REMARKS
A	18" 1/4	STD	150 WMS	TUBE IN	B.O.E.
B	36" 1/4	STD	150 WMS	TUBE OUT	B.O.E.
C	18"	STD	150 WMS	SHELL IN	
D	18"	STD	150 WMS	SHELL OUT	
E	36"	STD	3000*	SHELLWELD	THIRD CPL
F	36"	NPT	IN T.S.	SHELL ORDN	
G	36"	STD	3000*	TUBE ORDN	SW CLIP ORDN
H	36"	STD	3000* 3/4 SIZE	TUBE VENT	(3) REQ'D

* - WELD PREP IS FOR 14" SCH 40 PIPE

NOTES:


[illegible]

0100	REVISED RADIO PROCEDURES ADPENDED SPINNOGS ADDED DWG #5142 + ELEV E ORIENT FOR RS-1027 CDR ELEV 1405 5142	FMCA	not
0115	SHIRT WAS SA-505 TO MECH A NOTES ELEV WAS SA-006 REVISED PER PAR 22(1-21-75)	FMCA	not
0130	NOZZ FLGS WERE 1140-1050 (OR) CORRECTED T.S. HYDRO TEST PRESSURE ADDED ITEM NOS. 5142 WAS X4 DURMAN T.S. 5142 WAS X4 ADP. 5138. ADDED S-ELEV ELEV CGR HYDRO TEST PROCEDURES REVISED DWG PER PAR 08	FMCA	not
DATE	REVISION	CHKD	APPROV

DESIGN DATA	SHELL SIDE	TUBE SIDE
DESIGN AND FABRICATION	ASME SECT III CL-3 1974	ASME SECT I CL-2 1974 TENS. R
DESIGN PRESSURE	150 PSI	600 PSI
DESIGN TEMPERATURE	200° F	400° F
CORROSION ALLOWANCE	1/8"	005" OUTSIDE
WELDING	PER CODE	PER CODE
FLANGE FACE FINISH	25AA SHELL	25AA TUBE
RADIOGRAPHIC EXAMINATION	SPOT	FULL
HEAT TREATMENT		
TEST PROCEDURE	PER CODE	PER CODE
FINAL TEST PRESSURE	225 PSI	803 PSI


MATERIAL		
SHELL	SA-285-C	SA-240-304
HEADS	SA-515-70	SA-240-304
SHELL AND END FLANGES	SA-105-A	SA-182F304
NOZZLE NECKS	SA-53B	SA-240-304
NOZZLE FLANGES	SA-105-A	
MANIFOLD NECK		
CONNECTING PLATES	SA-515-70	SA-182F304
SUPPORTS (SKIRT)		SA-A-36
TIE SHEETS	SA-515-70 W/	SA-182F304
TUBES		SA-240-304
RAFFLES		
SPACERS	SA-53-A	
TIE-RODS	SA-36	
PARTITION PLATES		SA-240-304
COVERINGS	SA-105-A	SA-182F304
GASKETS	SPECIAL ORDER	SPECIAL ORDER
BOLTS OR STUDS	SA-A193-B7	SA-A193-B7
NUTS	SA-A194-24	SA-A194-24
DOWNY TUBES	SA-53-A	
ELBOWS		SA-182F304
DRAIN PIPES		SA-312-304
1" TIE SUPPLY	SA-36	

WEIGHT EMPTY 27,000 * BUNDLE - 14,500 *
WEIGHT FULL OF WATER 45,000 *
PAINTING COMMERCIAL ELASTIC CLEAN PER SSPC-SP6
63, PAINT-DIEMETACATE STEEL PRIMER #2 (15 TO
20 MILS DFT) ALL EXTERNAL C.S SURFACES
INSPECTION CAT UNDERWRITER & WESTINGHOUSE
STAMPING SHALL SIDE-SECTION CL3 TUNG SIDE-SECTION CL2
UNLESS OTHERWISE NOTED:
ALL BOTTOM NOZZLES SHALL BE FLUSH WITH INSIDE
OF VESSEL. OTHER NOZZLES SHALL BE FLUSH

	JOSEPH OAT CORPORATION CHEMICAL ENGINEERS/DESIGNERS/FABRICATORS		
	651. 1700 CAMDEN, NEW JERSEY 08104		
VERTICAL RESIDUAL HEAT EXCHANGER ASSEMBLY & DETAILS			
FOR: WESTINGHOUSE ELECTRIC CORP. PWRD PITTSBURGH, PA			
REF. NO. P.O. NO. SEE DATA BLOCK		JOB NO. J-2267-16'S SEE DATA BLOCK	
DRAWN: FMeA DATE: 08-28-66		DRAWING NO. REV.	
CHECKED: DATE:		5619 3	
APPROVED: [Signature] DATE: 08-28-66			


CO1.010.002

RFR 02-002 REV. 1
ATTACHMENT 1
SHEET 1



DETAIL A - DIVIDER PLATES

SCALE: NONE




DETAIL B - FLANGE TO SHELL WELD

ISI ITEM NO. CO1.010.002

SCALE: FULL

1: WELD PREP PER PWRSD DWG 271C900



MATERIAL	
ITEM	W ^{PO3} / ONG N ^o ASME N ^o
1	2656A90 SA-533 GR A CLASS 2
2	393A708 SA-508 CLASS 2 or 2 1/2
3	2656A96 SA-182 GRADE F-316L
4	398A009 SA-213 GRADE TP 304
5	SS-CLADDING
6	INCONEL WELD

WESTINGHOUSE PROPRIETARY CLASS 2

THIS DOCUMENT IS THE PROPERTY OF, AND CONTAINS PROPRIETARY INFORMATION OWNED BY, THE TAMPA DIVISION OF WESTINGHOUSE ELECTRIC CORPORATION AND IS MADE AVAILABLE TO YOU UNDER A CONFIDENTIAL RELATIONSHIP AND SUBJECT TO THE FOLLOWING UNDERSTANDING: CONDITIONS AND RESTRICTIONS, NO PERMISSION IS GRANTED TO PHOTOCOPY, USE, REPRODUCE, TRANSMIT OR DISCLOSE TO ANOTHER THIS DOCUMENT OR ANY INFORMATION CONTAINED THEREIN WITHOUT THE EXPRESS WRITTEN PERMISSION OF SAID DEPARTMENT IN ADVANCE.

S.O.	D.S.		CHANGE # 366	1
ITEM			NO 10077 PUMP UNIT J-2 PUMP UNIT J-2 PUMP UNIT J-2 PUMP UNIT J-2 PUMP UNIT J-2	2
LAST NUMBER USED				
ITEM	PARTS LIST			
QOS				
ISSUE DATE				
ENGINEER REC'D				
DRAWING				
Westinghouse Electric Corporation				
TAMPA DIVISION TAMPA FLA.				
APPARATUS PRESSURIZER (84 SERIES)				
TITLE SAFETY & RELIEF NOZ DET (FAB HD) 4A				
DTU J.E. SIMON	E.I.C.	WEDG E.H.G.	W.D.W.	EDSK
CIRD	E.I.C.	M.F.A.	A.P.	379443B
DESIGN	E.I.C.	O.U.A.	G.T.B.	
DATE 10/1/77	10/1/77	10/1/77	10/1/77	
WELD FOR REN	10/1/77	DRAWING NOT TO SCALE		SHEET NO OF SHEETS

872C799001

RFR #02-002 REV. 1
ATTACHMENT 2..