

May 19, 2003

Mr. Mike Bellamy  
Site Vice President  
Entergy Nuclear Operations, Inc.  
Pilgrim Nuclear Power Station  
600 Rocky Hill Road  
Plymouth, MA 02360

SUBJECT: PILGRIM NUCLEAR POWER STATION - PARTIAL WITHDRAWAL OF AN  
AMENDMENT REQUEST (TAC NO. MB7318)

Dear Mr. Bellamy:

By application dated January 23, 2003, as supplemented by letters dated February 24 and April 17, 2003, you applied for an amendment to the Pilgrim Nuclear Power Station, Facility Operating License No. DPR-35. Your application requested changes to the Pilgrim Technical Specifications (TSs) pertaining to requirements for the emergency core cooling system (ECCS) during shutdown conditions. In the April 17, 2003, letter, you withdrew a portion of the amendment request pertaining to the proposed change to Note (1) of TS Table 3.2.B. Accordingly, this portion of the request was not considered in the U.S. Nuclear Regulatory Commission (NRC or Commission) staff's Safety Evaluation dated April 22, 2003.

On April 22, 2003, the NRC issued License Amendment No. 200 which revised the TSs for ECCS requirements during shutdown conditions. The change modified the core spray and low pressure injection system's TS requirements to be applicable during the Run, Startup, and Hot Shutdown Modes. The change also modified the high drywell pressure instrumentation TSs to require the instrumentation to be Operable during the Run, Startup and Hot Shutdown Modes. Unnecessary TS requirements were removed based on the plant's operating Mode. Other changes were administrative in nature.

The Commission has filed the enclosed Notice of Partial Withdrawal of Application for Amendment to Facility Operating License with the Office of the Federal Register for publication.

Sincerely,

*/RA/*

Travis L. Tate, Project Manager, Section 2  
Project Directorate I  
Division of Licensing Project Management  
Office of Nuclear Reactor Regulation

Docket No. 50-293

Enclosure: Notice of Partial Withdrawal

cc w/encl: See next page

Pilgrim Nuclear Power Station

cc:

Resident Inspector  
U. S. Nuclear Regulatory Commission  
Pilgrim Nuclear Power Station  
Post Office Box 867  
Plymouth, MA 02360

Chairman, Board of Selectmen  
11 Lincoln Street  
Plymouth, MA 02360

Chairman, Duxbury Board of Selectmen  
Town Hall  
878 Tremont Street  
Duxbury, MA 02332

Office of the Commissioner  
Massachusetts Department of  
Environmental Protection  
One Winter Street  
Boston, MA 02108

Office of the Attorney General  
One Ashburton Place  
20th Floor  
Boston, MA 02108

Dr. Robert M. Hallisey, Director  
Radiation Control Program  
Commonwealth of Massachusetts  
Executive Offices of Health and  
Human Services  
174 Portland Street  
Boston, MA 02114

Regional Administrator, Region I  
U. S. Nuclear Regulatory Commission  
475 Allendale Road  
King of Prussia, PA 19406

John M. Fulton  
Assistant General Counsel  
Pilgrim Nuclear Power Station  
600 Rocky Hill Road  
Plymouth, MA 02360-5599

Mr. C. Stephen Brennon  
Licensing Superintendent  
Pilgrim Nuclear Power Station  
600 Rocky Hill Road  
Plymouth, MA 02360-5599

Mr. Jack Alexander  
Manager, Reg. Relations and  
Quality Assurance  
Pilgrim Nuclear Power Station  
600 Rocky Hill Road  
Plymouth, MA 02360-5599

Mr. David F. Tarantino  
Nuclear Information Manager  
Pilgrim Nuclear Power Station  
600 Rocky Hill Road  
Plymouth, MA 02360-5599

Ms. Jane Perlov  
Secretary of Public Safety  
Executive Office of Public Safety  
One Ashburton Place  
Boston, MA 02108

Mr. Stephen J. McGrail, Director  
Attn: James Muckerheide  
Massachusetts Emergency Management  
Agency  
400 Worcester Road  
Framingham, MA 01702-5399

Chairman  
Nuclear Matters Committee  
Town Hall  
11 Lincoln Street  
Plymouth, MA 02360

Mr. William D. Meinert  
Nuclear Engineer  
Massachusetts Municipal Wholesale  
Electric Company  
P.O. Box 426  
Ludlow, MA 01056-0426

May 19, 2003

Mr. Mike Bellamy  
Site Vice President  
Entergy Nuclear Operations, Inc.  
Pilgrim Nuclear Power Station  
600 Rocky Hill Road  
Plymouth, MA 02360

SUBJECT: PILGRIM NUCLEAR POWER STATION - PARTIAL WITHDRAWAL OF AN  
AMENDMENT REQUEST (TAC NO. MB7318)

Dear Mr. Bellamy:

By application dated January 23, 2003, as supplemented by letters dated February 24 and April 17, 2003, you applied for an amendment to the Pilgrim Nuclear Power Station, Facility Operating License No. DPR-35. Your application requested changes to the Pilgrim Technical Specifications (TSs) pertaining to requirements for the emergency core cooling system (ECCS) during shutdown conditions. In the April 17, 2003, letter, you withdrew a portion of the amendment request pertaining to the proposed change to Note (1) of TS Table 3.2.B. Accordingly, this portion of the request was not considered in the U.S. Nuclear Regulatory Commission (NRC or Commission) staff's Safety Evaluation dated April 22, 2003.

On April 22, 2003, the NRC issued License Amendment No. 200 which revised the TSs for ECCS requirements during shutdown conditions. The change modified the core spray and low pressure injection system's TS requirements to be applicable during the Run, Startup, and Hot Shutdown Modes. The change also modified the high drywell pressure instrumentation TSs to require the instrumentation to be Operable during the Run, Startup and Hot Shutdown Modes. Unnecessary TS requirements were removed based on the plant's operating Mode. Other changes were administrative in nature.

The Commission has filed the enclosed Notice of Partial Withdrawal of Application for Amendment to Facility Operating License with the Office of the Federal Register for publication.

Sincerely,

*/RA/*

Travis L. Tate, Project Manager, Section 2  
Project Directorate I  
Division of Licensing Project Management  
Office of Nuclear Reactor Regulation

Docket No. 50-293  
Enclosure: Notice of Partial Withdrawal  
cc w/encl: See next page

**DISTRIBUTION:**

|           |         |               |            |
|-----------|---------|---------------|------------|
| Public    | CHolden | JBobiak, RI   | FArner, RI |
| JClifford | OGC     | CAnderson, RI | TTate      |
| PDI-2 R/F | ACRS    | CRaynor       |            |

ADAMS Accession Number: ML031350186

|        |          |          |                      |
|--------|----------|----------|----------------------|
| OFFICE | PDI-2/PM | PDI-2/LA | PDI-2/SC             |
| NAME   | TTate    | CRaynor  | JBoska for JClifford |
| DATE   | 5/16/03  | 5/16/03  | 5/19/03              |

**OFFICIAL RECORD COPY**

UNITED STATES NUCLEAR REGULATORY COMMISSIONENERGY NUCLEAR GENERATION COMPANYENERGY NUCLEAR OPERATIONS, INC.DOCKET NO. 50-293NOTICE OF PARTIAL WITHDRAWAL OF APPLICATION FORAMENDMENT TO FACILITY OPERATING LICENSE

The U.S. Nuclear Regulatory Commission (NRC or Commission) has granted the request of Entergy Nuclear Operations, Inc. (the licensee), to withdraw a portion of its January 23, 2003, application for amendment to Facility Operating License No. DPR-35 for the Pilgrim Nuclear Power Station, located in Plymouth County, Massachusetts. The licensee's application was supplemented by letters dated February 24 and April 17, 2003.

The Commission had previously issued a Notice of Consideration of Issuance of Amendment published in the FEDERAL REGISTER on March 18, 2003 (68 FR 12952). However, by letter dated April 17, 2003, the licensee withdrew a portion of the original amendment request pertaining to the proposed change to Note (1) of Technical Specification (TS) Table 3.2.B.

The Commission issued License Amendment No. 200 on April 22, 2003, which revised the TSs pertaining to requirements for the emergency core cooling system during shutdown conditions. The change modified the core spray and low pressure injection system's TS requirements to be applicable during the Run, Startup, and Hot Shutdown Modes. The change also modified the high drywell pressure instrumentation TSs to require the instrumentation to be Operable during the Run, Startup and Hot Shutdown Modes. Unnecessary TS requirements were removed based on the plant's operating Mode. Other changes were administrative in nature.

For further details with respect to this action, see the application for amendment dated January 23, 2003, as supplemented February 24, 2003; and the licensee's April 17, 2003, letter that withdrew a portion of the application for license amendment. Documents may be examined, and/or copied for a fee, at the NRC's Public Document Room (PDR), located at One White Flint North, Public File Area O1 F21, 11555 Rockville Pike (first floor), Rockville, Maryland. Publicly available records will be accessible electronically from the Agencywide Documents Access and Management Systems (ADAMS) Public Electronic Reading Room on the internet at the NRC Web site, <http://www.nrc.gov/reading-rm/adams/html>. Persons who do not have access to ADAMS, or who encounter problems in accessing the documents located in ADAMS, should contact the NRC PDR reference staff by telephone at 1-800-397-4209, or 301-415-4737, or by email to [pdr@nrc.gov](mailto:pdr@nrc.gov).

Dated at Rockville, Maryland, this        day of May 2003.

FOR THE NUCLEAR REGULATORY COMMISSION

*/RA/*

Travis L. Tate, Project Manager, Section 2  
Project Directorate I  
Division of Licensing Project Management  
Office of Nuclear Reactor Regulation