

## 5.5 Programs and Manuals

---

### 5.5.1 Offsite Dose Calculation Manual (ODCM) (continued)

markings in the margin of the affected pages, clearly indicating the area of the page that was changed, and shall indicate the date (i.e., month and year) the change was implemented.

### 5.5.2 Primary Coolant Sources Outside Containment

This program provides controls to minimize leakage from those portions of systems outside containment that could contain highly radioactive fluids during a serious transient or accident to levels as low as practicable. The systems include the Core Spray, High Pressure Coolant Injection, Residual Heat Removal, Reactor Core Isolation Cooling, Reactor Water Cleanup, process sampling, and Standby Gas Treatment. The program shall include the following:

- a. Preventive maintenance and periodic visual inspection requirements; and
- b. Integrated leak test requirements for each system at 24 month intervals or less.

The provisions of SR 3.0.2 and SR 3.0.3 are applicable to the 24 month Frequency for performing integrated leak test activities.

### 5.5.3 Not Used

---

(continued)