



Entergy Nuclear Northeast  
Entergy Nuclear Operations, Inc.  
James A. Fitzpatrick NPP  
P.O. Box 110  
Lycoming, NY 13093  
Tel 315 349 6024 Fax 315 349 6480

T.A. Sullivan  
Vice President, Operations-JAF

May 14, 2003  
JAFP-03-0068

U. S. Nuclear Regulatory Commission  
ATTN: Document Control Desk  
Mail Station O-P1-17  
Washington, DC 20555

**SUBJECT: James A. FitzPatrick Nuclear Power Plant**  
**Docket No. 50-333**  
**Revision to March 2003 Monthly Operating Report**

Reference: Entergy letter to NRC dated April 14, 2003 (JAFP-03-0050) regarding  
"March 2003 Monthly Operating Report"

Dear Sir:

This letter transmits a revised copy of the James A. FitzPatrick 's Monthly Operating Report for March 2003. Previous submittal, dated April 14, 2003, contained discrepancies in reported data appearing in the table of unit shutdowns. Revised report areas are identified by a revision bar.

Should you have any questions concerning this report, please direct them to Mr. Mick Baker, Thermal Performance Engineer, at (315) 349-6181.

Very truly yours,

  
T. A. SULLIVAN

TAS:MB:dr  
Enclosure

IE24

cc: Regional Administrator  
U.S. Nuclear Regulatory Commission  
475 Allendale Road  
King of Prussia, PA 19406

Office of the Resident Inspector  
James A. FitzPatrick Nuclear Power Plant  
U.S. Nuclear Regulatory Commission  
P.O. Box 136  
Lycoming, NY 13093

Mr. Guy Vissing, Project Manager  
Project Directorate I  
Division of Licensing Project Management  
U.S. Nuclear Regulatory Commission  
Mail stop OWFN 8C2  
Washington, DC 20555

Mr. R. Toole  
ENN BWR SRC Operations Subcommittee Chairman  
605 West Horner Street  
Ebensburg, PA 15931

Mr. Paul Eddy  
Public Service Commission  
Office of Electricity and the Environment  
3 Empire Plaza  
Albany, NY 12223

JENG JAFP Files  
RMS (JAF)  
RMS (WPO)



**ENTERGY NUCLEAR NORTHEAST  
JAMES A. FITZPATRICK NUCLEAR POWER PLANT  
OPERATING DATA REPORT**

**REPORT MONTH: MARCH 2003, REVISION 1**

Docket No.:	50-333
Unit Name:	FitzPatrick
Date:	May 6, 2003
Completed By:	M. Baker
Telephone:	(315) 349-6181

<b>DAY</b>	<b>NET AVERAGE DAILY POWER LEVEL</b>	<b>DAY</b>	<b>NET AVERAGE DAILY POWER LEVEL</b>
1	847.54	17	847.63
2	847.54	18	847.71
3	847.54	19	784.46
4	847.00	20	128.71
5	672.29	21	0.00
6	442.21	22	0.00
7	442.04	23	0.00
8	443.92	24	0.00
9	787.88	25	0.00
10	845.96	26	0.00
11	847.17	27	522.88
12	847.13	28	841.42
13	825.25	29	847
14	847.29	30	847
15	847.42	31	847.42
16	847.58		

**REPORT MONTH: MARCH 2003, REVISION 1**

Docket No.:	50-333
Unit Name:	FitzPatrick
Date:	May 6, 2003
Completed By:	M. Baker
Telephone:	(315) 349-6181

**UNIT SHUTDOWNS**

NO.	DATE	TYPE	DURATION HOURS	REASON	METHOD OF SHUTTING DOWN THE REACTOR	LICENSEE EVENT REPORT NO.	SYSTEM CODE	COMPONENT CODE	CAUSE and CORRECTIVE ACTION TO PREVENT RECURRENCE
1	03/19/03	F	172.1	B	1	N/A	N/A	N/A	N/A

F: FORCED  
S: SCHEDULED

**REASON:**  
 A. Equipment failure (explain)  
 B. Maintenance or Test  
 C. Refueling  
 D. Regulatory Restriction  
 E. Operator training and license examination  
 F. Administrative  
 G. Operational error (explain)  
 H. Other (explain)

**METHOD:**  
 1. Manual  
 2. Manual Scram  
 3. Automatic Scram  
 4. Continued  
 5. Reduced load  
 9. Other

**EXHIBIT G:** Instructions for preparation of data entry sheets for Licensee Event Report (LER) file (NUREG-0161)

## REPORT MONTH: MARCH 2003, REVISION 1

Docket No.:	50-333
Unit Name:	FitzPatrick
Date:	May 6, 2003
Completed By:	M. Baker
Telephone:	(315) 349-6181

### OPERATIONAL SUMMARY

The FitzPatrick plant operated at or near rated power for the duration of the month of March 2003 with the exception of the following:

Note: This list does not include minor derates for rod pattern adjustments. (<20% reduction in average power level for the preceding 24 hours)

- March 5, 2003 – 1318 Commenced scheduled down power to remove “B” Reactor Feed Pump from service to perform pump seal replacement and to perform a control rod sequence exchange. For this evolution, reactor power was reduced to approximately 55% on March 5, 2003 – 1425 hours.
- March 9, 2003 – 0200 Reactor power was maintained at approximately 55% power until March 9, 2003 at 0200 hours when reactor power was raised following repair of the pump seal. Reactor was returned to full power on March 9, 2003 – 1050 hours.
- March 13, 2003 – 0410 Reactor power was reduced to approximately 82% power for a rod pattern adjustment.
- March 19, 2003 – 0803 Commenced forced shutdown to repair a steam leak in the Feedwater System. The plant staff executed the existing forced outage schedule, performed maintenance on valves, replaced the ‘A’ RFP outboard seal, and added balancing weights to reduce vibration of “B” RFP Turbine. For this evolution, the reactor mode switch was taken to SHUTDOWN on March 20, 2003 – 0718 hours.
- March 24, 2003 – 1247 Commenced reactor start-up. On March 25, 2003 – 0054 the “B” Reactor Feed Pump Turbine experienced high vibration while increasing speed. Reduced power to repair vibration issue.
- March 25, 2003 – 1508 Commenced reactor shutdown to repair high vibration of “B” Reactor Feed Pump Turbine. Mode Switch in SHUTDOWN position on March 25, 2003 – 1935 hours.
- March 26, 2003 – 0113 Placed mode switch in STARTUP. Commenced reactor start-up. While commencing Main Turbine roll at approximately 20% reactor power the Turbine Intercept Valve failed to open. Remained at approximately 20% power until the valve was repaired. Commenced Main Turbine roll on March 27, 2003 – 0515. Reactor was returned to full power on March 27, 2003 – 2353 hours