



CP&L

A Progress Energy Company

MAY 12 2003

SERIAL: BSEP 03-0069

U. S. Nuclear Regulatory Commission
ATTN: Document Control Desk
Washington, DC 20555-0001

BRUNSWICK STEAM ELECTRIC PLANT, UNIT NO. 2
DOCKET NO. 50-324/LICENSE NO. DPR-62
WITHDRAWAL OF INSERVICE INSPECTION PROGRAM RELIEF REQUEST FOR
SERVICE WATER SYSTEM PIPING NON-CODE REPAIR (NRC TAC NO. MB3498)

Ladies and Gentlemen:

On November 28, 2001 (Serial: BSEP 01-0135), Progress Energy Carolinas, Inc. (PEC) submitted a request for relief from the requirements of the American Society of Mechanical Engineers (ASME) Boiler and Pressure Vessel Code, Section XI, for the Brunswick Steam Electric Plant (BSEP), Unit 2. The relief request was submitted in accordance with 10 CFR 50.55a(g)(5)(iii) and NRC Generic Letter 90-05, "Guidance For Performing Temporary Non-Code Repair of ASME Code Class 1, 2, and 3 Piping." The relief request related to the requirements of subparagraph IWA-4000(a) regarding the repair of a through-wall leak identified on Service Water line 2-SW-103-24-157.

Repair of line 2-SW-103-24-157, in accordance with the ASME Code, Section XI, was completed during BSEP Unit 2 Refueling Outage 15 (i.e., B216R1). A copy of the Form NIS-2A, "Repair/Replacement Certification Record," for the repair is enclosed. Based on completion of this repair, PEC withdraws the relief request dated November 28, 2001.

Please refer any questions regarding this submittal to Mr. Leonard R. Beller, Supervisor - Licensing/Regulatory Programs, at (910) 457-2073.

Sincerely,

Edward T. O'Neil
Manager - Support Services
Brunswick Steam Electric Plant

Document Control Desk
BSEP 03-0069 / Page 2

WRM/wrm

Enclosure: Form NIS-2A, "Repair/Replacement Certification Record"

cc (with enclosure):

U. S. Nuclear Regulatory Commission, Region II
ATTN: Mr. Luis A. Reyes, Regional Administrator
Sam Nunn Atlanta Federal Center
61 Forsyth Street, SW, Suite 23T85
Atlanta, GA 30303-8931

U. S. Nuclear Regulatory Commission
ATTN: NRC Resident Inspector
8470 River Road
Southport, NC 28461-8869

U. S. Nuclear Regulatory Commission **(Electronic Copy Only)**
ATTN: Ms. Brenda L. Mozafari (Mail Stop OWFN 8G9)
11555 Rockville Pike
Rockville, MD 20852-2738

Ms. Jo A. Sanford
Chair - North Carolina Utilities Commission
P.O. Box 29510
Raleigh, NC 27626-0510

Division of Boiler and Pressure Vessel
North Carolina Department of Labor
ATTN: Mr. Jack Given, Assistant Director of Boiler & Pressure Vessels
4 West Edenton Street
Raleigh, NC 27601-1092

BSEP 03-0069
Enclosure

BRUNSWICK STEAM ELECTRIC PLANT, UNIT NO. 2
DOCKET NO. 50-324/LICENSE NO. DPR-62
WITHDRAWAL OF INSERVICE INSPECTION PROGRAM
RELIEF REQUEST FOR SERVICE WATER SYSTEM PIPING
NON-CODE REPAIR (NRC TAC NO. MB3498)

Form NIS-2A, "Repair/Replacement Certification Record"

ATTACHMENT 5
Page 1 of 1
NIS-2A FORM

FORM NIS-2A REPAIR/REPLACEMENT CERTIFICATION RECORD	
I certify that the <u>REPAIR</u> represent by Repair/Replacement <u>repair or replacement</u>	<input checked="" type="checkbox"/> Code Case N-416-1 <input type="checkbox"/> Code Case N-513 <input type="checkbox"/> Code Case N-523-1 <input type="checkbox"/> Code Case N-547 <input type="checkbox"/> Code Case N-573
Plan number <u>191267-01</u> conforms to the requirements of Section XI.	
Type Code Symbol Stamp <u>N/A</u>	
Certification of Authorization No. <u>N/A</u> Expiration Date <u>N/A</u>	
Signed <u><i>Raymond N. Acosta</i></u> ISI Program Manager Date <u>3/16/2003</u> <u>Owner or Owner's Designee, Title</u>	
Unit: 2 System: 4060 - SW Equipment Tag: 2-SW-103-24-157 Inspection Interval / Period: 3-2	
<p>I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspector and the State or Province of North Carolina and employed by Hartford Steam Boiler Inspection and Insurance Company of Hartford, Connecticut have inspected the items described in Repair/Replacement</p> <p>Plan number <u>191267-01</u> during the period <u>2/11/2002</u> to <u>3/16/2003</u>, and state that</p> <p>to the best of my knowledge and belief, the Owner has performed all the activities described in the Repair/Replacement Plan in accordance with the requirement of Section XI.</p> <p>By signing this certificate neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the activities described in the Repair/Replacement Plan. Furthermore, neither the Inspector or his employer shall be liable in any manner for any personnel injury or property damage or loss of any kind arising from or connected with this inspection.</p> <p><u><i>Raymond N. Acosta</i></u> Commissions <u>NC-1433 A N I B C</u> Inspector Signature National Board, State, Province, and Endorsements</p> <p>Date <u>3/16/03</u></p> <p style="font-size: small;">This form (E00126) may be obtained from the Order Dept. ASME, 22 Law Drive, Box 2300, Fairfield, NJ 07007-2300</p>	