

2.C.(6) Deleted

2.C.(7) Additional Conditions

The Additional Conditions contained in Appendix B, as revised through Amendment No. 251 are hereby incorporated into this license. NMC shall operate the facility in accordance with the Additional Conditions.

2.C.(8) The licensee is authorized to revise the Updated Final Safety Analysis Report by deleting the footnote for Section 9.1.4.4.5 which states: "\*\*The NRC has not endorsed the reactor building crane as single-failure proof (Reference 9)," and by deleting Reference 9 of the references for Section 9.1.

D. This license is effective as of the date of issuance and shall expire at midnight February 21, 2014.

FOR THE ATOMIC ENERGY COMMISSION

*Original signed by Roger Boyd for*  
A. Giambuso, Deputy Director  
for Reactor Projects  
Directorate of Licensing'

Enclosures:

Appendix A Technical Specifications

Appendix B Additional Conditions

Date of Issuance: February 22, 1974