



MAY 15 2003

SERIAL: HNP-03-063

United States Nuclear Regulatory Commission  
ATTENTION: Document Control Desk  
Washington, DC 20555

SHEARON HARRIS NUCLEAR POWER PLANT  
DOCKET NO. 50-400/LICENSE NO. NPF-63  
15 DAY SPECIAL REPORT - STEAM GENERATOR TUBES PLUGGED

Ladies and Gentlemen:

In accordance with Technical Specification 4.4.5.5.a. for the Harris Nuclear Plant, Progress Energy Carolinas, Inc. (also known as Carolina Power & Light Company) is providing the enclosed Special Report. This report identifies no steam generator tubes plugged as a result of the recent Steam Generator Tube Inservice Inspection conducted during Refueling Outage No. 11.

The complete results of the Steam Generator Tube Inservice Inspection will be submitted to the NRC within 12 months of completion as required by Technical Specification 4.4.5.5.b.

If you have any questions regarding this matter, please contact me at (919) 362-3137.

Sincerely,

A handwritten signature in black ink that reads 'John R. Caves'.

John R. Caves  
Supervisor, Licensing/Regulatory Programs  
Harris Nuclear Plant

MGW

Enclosure

c: Mr. J. B. Brady (NRC Senior Resident Inspector, HNP)  
Mr. C. P. Patel (NRR Project Manager, HNP)  
Mr. L. A. Reyes (NRC Regional Administrator, Region II)

Progress Energy Carolinas, Inc.  
Harris Nuclear Plant  
P.O. Box 165  
New Hill, NC 27562

IE22

Document Control Desk  
SERIAL: HNP-03-063

HARRIS NUCLEAR PLANT  
SPECIAL REPORT PER TECHNICAL SPECIFICATION 4.4.5.5.a.

STEAM GENERATOR TUBE INSERVICE INSPECTION (RFO11)  
NUMBER OF TUBES PLUGGED

<u>Steam Generator</u>	<u>A</u>	<u>B</u>	<u>C</u>
Current (RFO11)	0	0	0
Cumulative	*1	*1	0

\* One tube plugged each in Steam Generator A and B during manufacturing process and prior to being placed in service.