



MAY 14 2003

L-2003-120  
10 CFR 50.36

U. S. Nuclear Regulatory Commission  
Attn: Document Control Desk  
Washington, D. C. 20555

Re: Turkey Point Units 3 and 4  
Docket Nos. 50-250 and 50-251  
Monthly Operating Report - April 2003

In accordance with the requirements of Turkey Point Units 3 and 4 Technical Specification 6.9.1.5, and the guidance of Generic Letter 97-02, attached are the April 2003 Operating Data Reports and Summaries of Operating Experience for Turkey Point Units 3 and 4.

Very truly yours,

A handwritten signature in black ink that reads "Terry O. Jones". The signature is written in a cursive, flowing style.

Terry O. Jones  
Vice President  
Turkey Point Plant

DRL

Attachments

NRC Regulatory Issue Summary 2001-05 waived the requirements that multiple copies of documents be submitted to the NRC.

IE24

DOCKET NO.: 50-250  
 UNIT: Turkey Point Unit 3  
 DATE: 5/5/2003  
 COMPLETED BY: David Lafleur  
 TELEPHONE: (305) 246-7150

Reporting Period April, 2003

**OPERATING DATA REPORT**

Design Electrical Rating (MWe-Net)	720		
Maximum Dependable Capacity (MWe-Net)	693		
	Month	Year-to-date	Cumulative
No. of hours reactor was critical	668.2	2149.4	196689.2
No. of hours generator was on line (service hours)	668.2	2115.8	194324.3
Unit reserve shutdown hours	0	0	121.8
Net Electrical Energy (MWH)	478762	1393410	126752487

**UNIT SHUTDOWNS**

No.	Date	Type F=Forced S=Scheduled	Duration (hours)	Reason (1)	Method of Shutting Down (2)	Corrective Action/ Comments
20030012	04/28/03	F	50.8	A	1	Unit 3 manual reactor shutdown due to letdown valve CV-3-200B out of service.

**(1) Reason**

- A - Equipment Failure (Explain)
- B - Maintenance or Test
- C - Refueling
- D - Regulatory Restriction
- E - Operator Training/License Examination
- F - Administrative
- G - Operational Error (Explain)
- H - Other

**(2) Method**

- 1 - Manual
- 2 - Manual Trip/Scram
- 3 - Automatic Trip/Scram
- 4 - Continuation
- 5 - Other (Explain)

**Summary Of Monthly Operating Experience**

Unit 3 returned to power operation from its cycle 20 refueling outage on 3/28/03, and completed its power ascension to 100% on 4/1/03. Unit 3 then remained at essentially 100% power until 4/28/2003. On 4/28/03, Unit 3 performed a manual reactor shutdown to repair CV-3-200B and remained shutdown for the remainder of the month of April 2003.

DOCKET NO.: 50-251  
 UNIT: Turkey Point Unit 4  
 DATE: 5/5/2003  
 COMPLETED BY: David Lafleur  
 TELEPHONE: (305) 246-7150

Reporting Period April, 2003

Design Electrical Rating (MWe-Net)	720		
Maximum Dependable Capacity (MWe-Net)	693		
	Month	Year-to-date	Cumulative
No. of hours reactor was critical	719	2879	194241.7
No. of hours generator was on line (service hours)	719	2879	189824.2
Unit reserve shutdown hours	0	0	577.2
Net Electrical Energy (MWH)	502708	2023267	124982357

**UNIT SHUTDOWNS**

No.	Date	Type F=Forced S=Scheduled	Duration (hours)	Reason (1)	Method of Shutting Down (2)	Corrective Action/ Comments
N/A	N/A	N/A	N/A	N/A	N/A	N/A

**(1) Reason**

- A - Equipment Failure (Explain)
- B - Maintenance or Test
- C - Refueling
- D - Regulatory Restriction
- E - Operator Training/License Examination
- F - Administrative
- G - Operational Error (Explain)
- H - Other

**(2) Method**

- 1 - Manual
- 2 - Manual Trip/Scram
- 3 - Automatic Trip/Scram
- 4 - Continuation
- 5 - Other (Explain)

**Summary Of Monthly Operating Experience**

Unit 4 operated at essentially 100% power for the month of April 2003, except for a unit reduction of power on 4/10/03 for turbine valve testing. Unit 4 returned to 100% power on 4/11/03 and remained at essentially 100% for the remainder of the month of April 2003.