

MAY 14 2003



LR-N03-0224

U. S. Nuclear Regulatory Commission
Document Control Desk
Washington, DC 20555

Gentlemen:

**MONTHLY OPERATING REPORT
SALEM GENERATING STATION UNIT 2
DOCKET NO. 50-311**

In compliance with Section 6.9, Reporting Requirements for the Salem Unit 2 Technical Specifications, the operating statistics for **April 2003** are being forwarded.

Sincerely,

A handwritten signature in black ink, appearing to read "Lon Waldinger", written in a cursive style.

Lon Waldinger
Operations Director

JCN
Attachments

C Distribution

IE24

DOCKET NO.: 50-311
 UNIT: Salem 2
 DATE: 5/5/03
 COMPLETED BY: F. Todd
 TELEPHONE: (856) 339-1316

Reporting Period April 2003

OPERATING DATA REPORT

Design Electrical Rating (MWe-Net) **1131**
 Maximum Dependable Capacity (MWe-Net) **1092**
 No. of hours reactor was critical **717**
 No. of hours generator was on line (service hours) **705**
 Unit reserve shutdown hours **0**
 Net Electrical Energy (MWH) **781894**

Month	Year-to-date	Cumulative
	2810	123226
	2797	119755
	0	0
	3137839	122326814

UNIT SHUTDOWNS

NO.	DATE	TYPE F=FORCED S=SCHEDULED	DURATION (HOURS)	REASON (1)	METHOD OF SHUTTING DOWN THE REACTOR (2)	CORRECTIVE ACTION/ COMMENT
1	4/1/03 - 3/31/03	F	14	H	4	Multiple circulators o/s due to high grass levels

(1) Reason

- A - Equipment Failure (Explain)
- B - Maintenance or Test
- C - Refueling
- D - Regulatory Restriction
- E - Operator Training/License Examination
- F - Administrative
- G - Operational Error (Explain)
- H - Other

(2) Method

- 1 - Manual
- 2 - Manual Trip/Scram
- 3 - Automatic Trip/Scram
- 4 - Continuation
- 5 - Other (Explain)

DOCKET NO.: 50-311
UNIT: Salem 2
DATE: 5/5/03
COMPLETED BY: J. Nagle
TELEPHONE: (856) 339-3171

Summary Of Monthly Operating Experience

- On April 1 the Unit returned to power from a shutdown due to 4 circulators out of service.