

June 10, 2003

Mr. Roy A. Anderson
President & Chief Nuclear Officer
PSEG Nuclear, LLC - X04
Post Office Box 236
Hancocks Bridge, NJ 08038

SUBJECT: HOPE CREEK GENERATING STATION - RE: REVISION TO TECHNICAL
SPECIFICATIONS BASES PAGE (TAC NO. MB8906)

Dear Mr. Anderson:

By letter dated April 28, 2003, PSEG Nuclear, LLC, provided changes to the Technical Specification (TS) Bases for the Hope Creek Generating Station. Specifically, the change revises TS Bases page B 3/4 4-5 (the bases for TS 3/4.4.6 "Pressure/Temperature Limits") to explicitly state that the maximum specified heatup and cooldown rates apply to reactor coolant temperature. The U.S. Nuclear Regulatory Commission staff has no objection to the changes.

The enclosed page is being distributed for inclusion in your TS Bases section. If you have any questions, please contact me at (301) 415-1420.

Sincerely,

/RA/

Richard B. Ennis, Senior Project Manager, Section 2
Project Directorate I
Division of Licensing Project Management
Office of Nuclear Reactor Regulation

Docket No. 50-354

Enclosures: 1. TS Bases Change Instructions
2. TS Bases Page

cc w/encls: See next page

June 10, 2003

Mr. Roy A. Anderson
President & Chief Nuclear Officer
PSEG Nuclear, LLC - X04
Post Office Box 236
Hancocks Bridge, NJ 08038

SUBJECT: HOPE CREEK GENERATING STATION - RE: REVISION TO TECHNICAL SPECIFICATIONS BASES PAGE (TAC NO. MB8906)

Dear Mr. Anderson:

By letter dated April 28, 2003, PSEG Nuclear, LLC, provided changes to the Technical Specification (TS) Bases for the Hope Creek Generating Station. Specifically, the change revises TS Bases page B 3/4 4-5 (the bases for TS 3/4.4.6 "Pressure/Temperature Limits") to explicitly state that the maximum specified heatup and cooldown rates apply to reactor coolant temperature. The U.S. Nuclear Regulatory Commission staff has no objection to the changes.

The enclosed page is being distributed for inclusion in your TS Bases section. If you have any questions, please contact me at (301) 415-1420.

Sincerely,

/RA/

Richard B. Ennis, Senior Project Manager, Section 2
Project Directorate I
Division of Licensing Project Management
Office of Nuclear Reactor Regulation

Docket No. 50-354

Enclosures: 1. TS Bases Change Instructions
2. TS Bases Page

cc w/encls: See next page

DISTRIBUTION:

PUBLIC	CHolden	OGC	GMeyer, RGN-I
PDI-2 R/F	JClifford	CRaynor	GHill (2)
ACRS	GMiller	REnnis	WBeckner

ADAMS Accession Number: ML031470791

OFFICE	PDI-2/PM	PDI-2/PM	PDI-2/LA	PDI-2/SC
NAME	GMiller	REnnis	CRaynor	JClifford
DATE	6/9/03	6/9/03	6/9/03	6/9/03

OFFICIAL RECORD COPY

Hope Creek Generating Station

cc:

Jeffrie J. Keenan, Esquire
PSEG Nuclear - N21
P.O. Box 236
Hancocks Bridge, NJ 08038

Hope Creek Resident Inspector
U.S. Nuclear Regulatory Commission
Drawer 0509
Hancocks Bridge, NJ 08038

Mr. David F. Garchow
Vice President - Projects and Licensing
PSEG Nuclear - N28
P.O. Box 236
Hancocks Bridge, NJ 08038

Mr. Gabor Salamon
Manager - Nuclear Safety and Licensing
PSEG Nuclear - N21
P.O. Box 236
Hancocks Bridge, NJ 08038

Regional Administrator, Region I
U.S. Nuclear Regulatory Commission
475 Allendale Road
King of Prussia, PA 19406

Dr. Jill Lipoti, Asst. Director
Radiation Protection Programs
NJ Department of Environmental
Protection and Energy
CN 415
Trenton, NJ 08625-0415

Richard Hartung
Electric Service Evaluation
Board of Regulatory Commissioners
2 Gateway Center, Tenth Floor
Newark, NJ 07102

Lower Alloways Creek Township
c/o Mary O. Henderson, Clerk
Municipal Building, P.O. Box 157
Hancocks Bridge, NJ 08038

Mr. Timothy J. O'Connor
Vice President - Operations
PSEG Nuclear - X15
P.O. Box 236
Hancocks Bridge, NJ 08038

Mr. John T. Carliln
Vice President - Engineering
PSEG Nuclear - N10
P.O. Box 236
Hancocks Bridge, NJ 08038

TECHNICAL SPECIFICATIONS BASES CHANGE INSTRUCTIONS

FACILITY OPERATING LICENSE NO. NPF-57

DOCKET NO. 50-354

Replace the following page of the Appendix A, Technical Specifications Bases, with the attached revised page.

Remove
B 3/4 4-5

Insert
B 3/4 4-5