

PLANT SYSTEMS

CONDENSATE STORAGE TANK

LIMITING CONDITION FOR OPERATION

3.7.1.3 A condensate storage tank system (CST) shall be OPERABLE with a level of at least 240,000 gallons of water.

APPLICABILITY: MODES 1, 2 and 3,
MODE 4 when steam generator is relied upon for heat removal.

ACTION:

With the condensate storage tank system inoperable, within 4 hours either:

- a. Restore the CST to OPERABLE status or be in at least HOT STANDBY within the next 6 hours and in HOT SHUTDOWN within the following 12 hours without reliance on steam generator for heat removal, or
- b. Verify by administrative means OPERABILITY of the Essential Raw Cooling Water System as a backup supply to the auxiliary feedwater pumps* and restore the condensate storage tank to OPERABLE status within 7 days or be in at least HOT STANDBY within the next 6 hours and in HOT SHUTDOWN within the following 12 hours without reliance on steam generator for heat removal.

SURVEILLANCE REQUIREMENTS

4.7.1.3.1 The condensate storage tank system shall be demonstrated OPERABLE at least once per 12 hours by verifying the level is within its limits when the tank is the supply source for the auxiliary feedwater pumps.

* OPERABILITY shall be verified once per 12 hours following initial verification.