

May 29, 2003

Mr. Michael R. Kansler, President  
Entergy Nuclear Operations, Inc.  
440 Hamilton Avenue  
White Plains, NY 10601

SUBJECT: REQUEST FOR ADDITIONAL INFORMATION REGARDING REQUEST FOR  
RELAXATION FROM ORDER ESTABLISHING INTERIM INSPECTION  
REQUIREMENTS OF REACTOR VESSEL HEADS, INDIAN POINT NUCLEAR  
GENERATING UNIT NO. 3 (TAC NO. MB8163)

Dear Mr. Kansler:

In a letter dated March 27, 2003, Entergy Nuclear Operations, Inc. (ENO) requested a relaxation from certain requirements in an Order issued by the U.S. Nuclear Regulatory Commission (NRC) on February 11, 2003 (EA-03-009). Specifically, ENO requested a relaxation for Indian Point Nuclear Generating Unit No. 3 from the inspection coverage when performing ultrasonic testing of each reactor vessel head penetration nozzle from 2 inches above the J-groove weld to the bottom of the nozzle, as specified in Section IV.C(2)(b)(i) of the Order.

The NRC staff is reviewing the information provided in the March 27 submittal and has determined that additional information is needed to complete its review. The specific questions are found in the enclosed request for additional information (RAI). During a telephone call on May 20, 2003, the ENO staff indicated that a response to the RAI would be provided within 90 days.

If you should have any questions, please do not hesitate to call me.

Sincerely,

*/RA/*

Patrick D. Milano, Sr. Project Manager, Section 1  
Project Directorate 1  
Division of Licensing Project Management  
Office of Nuclear Reactor Regulation

Docket No. 50-286

Enclosure: RAI

cc w/encl: See next page

May 29, 2003

Mr. Michael R. Kansler, President  
Entergy Nuclear Operations, Inc.  
440 Hamilton Avenue  
White Plains, NY 10601

SUBJECT: REQUEST FOR ADDITIONAL INFORMATION REGARDING REQUEST FOR  
RELAXATION FROM ORDER ESTABLISHING INTERIM INSPECTION  
REQUIREMENTS OF REACTOR VESSEL HEADS, INDIAN POINT NUCLEAR  
GENERATING UNIT NO. 3 (TAC NO. MB8163)

Dear Mr. Kansler:

In a letter dated March 27, 2003, Entergy Nuclear Operations, Inc. (ENO) requested a relaxation from certain requirements in an Order issued by the U.S. Nuclear Regulatory Commission (NRC) on February 11, 2003 (EA-03-009). Specifically, ENO requested a relaxation for Indian Point Nuclear Generating Unit No. 3 from the inspection coverage when performing ultrasonic testing of each reactor vessel head penetration nozzle from 2 inches above the J-groove weld to the bottom of the nozzle, as specified in Section IV.C(2)(b)(i) of the Order.

The NRC staff is reviewing the information provided in the March 27 submittal and has determined that additional information is needed to complete its review. The specific questions are found in the enclosed request for additional information (RAI). During a telephone call on May 20, 2003, the ENO staff indicated that a response to the RAI would be provided within 90 days.

If you should have any questions, please do not hesitate to call me.

Sincerely,

*/RA/*

Patrick D. Milano, Sr. Project Manager, Section 1  
Project Directorate 1  
Division of Licensing Project Management  
Office of Nuclear Reactor Regulation

Docket No. 50-224 and 50-286

Enclosure: RAI

cc w/encl: See next page

DISTRIBUTION

PUBLIC	R. Laufer	S. Little	S. Bloom
PDI-1 Reading	P. Milano	P. Eselgroth, RGN-I	OGC
C. Holden	T. Chan	E. Reichelt	ACRS

Accession Number: ML031490691

OFFICE	PDI-1:PM	PDI-1:LA	EMCB:SC	PDI-1:SC	
NAME	PMilano	SLittle	TChan	RLaufer	
DATE	5/21/03	5/22/03	5/22/03	5/28/03	

OFFICIAL RECORD COPY

Indian Point Nuclear Generating Unit No. 3

cc:

Mr. Jerry Yelverton  
Chief Executive Officer  
Entergy Operations  
1340 Echelon Parkway  
Jackson, MS 39213

Mr. John Herron  
Senior Vice President and  
Chief Operating Officer  
Entergy Nuclear Operations, Inc.  
440 Hamilton Avenue  
White Plains, NY 10601

Mr. Fred Dacimo  
Vice President - Operations  
Entergy Nuclear Operations, Inc.  
Indian Point Nuclear Generating Unit 3  
295 Broadway, Suite 1  
P. O. Box 308  
Buchanan, NY 10511-0308

Mr. Dan Pace  
Vice President Engineering  
Entergy Nuclear Operations, Inc.  
440 Hamilton Avenue  
White Plains, NY 10601

Mr. James Knubel  
Vice President Operations Support  
Entergy Nuclear Operations, Inc.  
440 Hamilton Avenue  
White Plains, NY 10601

Mr. Joseph DeRoy  
General Manager Operations  
Entergy Nuclear Operations, Inc.  
Indian Point Nuclear Generating Unit 3  
295 Broadway, Suite 3  
P. O. Box 308  
Buchanan, NY 10511-0308

Mr. John Kelly  
Director - Licensing  
Entergy Nuclear Operations, Inc.  
440 Hamilton Avenue  
White Plains, NY 10601

Ms. Charlene Faison

Licensing  
Entergy Nuclear Operations, Inc.  
440 Hamilton Avenue  
White Plains, NY 10601

Mr. Harry P. Salmon, Jr.  
Director of Oversight  
Entergy Nuclear Operations, Inc.  
440 Hamilton Avenue  
White Plains, NY 10601

Mr. James Comiotes  
Director, Nuclear Safety Assurance  
Entergy Nuclear Operations, Inc.  
Indian Point Nuclear Generating Unit 3  
295 Broadway, Suite 3  
P.O. Box 308  
Buchanan, NY 10511-0308

Mr. John McCann  
Manager, Licensing and Regulatory Affairs  
Entergy Nuclear Operations, Inc.  
Indian Point Nuclear Generating Unit 2  
295 Broadway, Suite 1  
P. O. Box 249  
Buchanan, NY 10511-0249

Resident Inspector's Office  
U.S. Nuclear Regulatory Commission  
295 Broadway, Suite 3  
P.O. Box 337  
Buchanan, NY 10511-0337

Regional Administrator, Region I  
U.S. Nuclear Regulatory Commission  
475 Allendale Road  
King of Prussia, PA 19406

Mr. John M. Fulton  
Assistant General Counsel  
Entergy Nuclear Operations, Inc.  
440 Hamilton Avenue  
White Plains, NY 10601

Indian Point Nuclear Generating Unit No. 3

cc:

Ms. Stacey Lousteau  
Treasury Department  
Entergy Services, Inc.  
639 Loyola Avenue  
Mail Stop: L-ENT-15E  
New Orleans, LA 70113

Mr. William M. Flynn, President  
New York State Energy, Research, and  
Development Authority  
17 Columbia Circle  
Albany, NY 12203-6399

Mr. J. Spath, Program Director  
New York State Energy, Research, and  
Development Authority  
17 Columbia Circle  
Albany, NY 12203-6399

Mr. Paul Eddy  
Electric Division  
New York State Department  
of Public Service  
3 Empire State Plaza, 10<sup>th</sup> Floor  
Albany, NY 12223

Mr. Charles Donaldson, Esquire  
Assistant Attorney General  
New York Department of Law  
120 Broadway  
New York, NY 10271

Mayor, Village of Buchanan  
236 Tate Avenue  
Buchanan, NY 10511

Mr. Ray Albanese  
Executive Chair  
Four County Nuclear Safety Committee  
Westchester County Fire Training Center  
4 Dana Road  
Valhalla, NY 10592

Mr. Ronald Schwartz  
SRC Consultant  
64 Walnut Drive  
Spring Lake Heights, NJ 07762

Mr. Ronald J. Toole  
SRC Consultant  
Toole Insight  
605 West Horner Street  
Ebensburg, PA 15931

Mr. Charles W. Hehl  
SRC Consultant  
Charles Hehl, Inc.  
1486 Matthew Lane  
Pottstown, PA 19465

Mr. Alex Matthiessen  
Executive Director  
Riverkeeper, Inc.  
25 Wing & Wing  
Garrison, NY 10524

Mr. Paul Leventhal  
The Nuclear Control Institute  
1000 Connecticut Avenue NW  
Suite 410  
Washington, DC, 20036

Mr. Karl Copeland  
Pace Environmental Litigation Clinic  
78 No. Broadway  
White Plains, NY 10603

Jim Riccio  
Greenpeace  
702 H Street, NW  
Suite 300  
Washington, DC 20001

REQUEST FOR ADDITIONAL INFORMATION

REGARDING RELAXATION FROM NRC ORDER EA-03-009

INDIAN POINT NUCLEAR GENERATING UNIT NO. 3 (IP3)

DOCKET NO. 50-286

In a letter dated March 27, 2003, Entergy Nuclear Operations, Inc. (the licensee) requested relaxation from the performing ultrasonic testing (UT) of each reactor pressure vessel head penetration nozzle (i.e., nozzle base material), from 2 inches above the J-groove weld to the bottom of the nozzle. The licensee stated that the bottom 0.75 inch of the nozzle is threaded and designed to accommodate the installation of guide funnels. Due to the threads, the licensee stated that meaningful UT test data cannot be obtained in this region, due to dispersion of the UT signal. The licensee proposes to perform UT from 2 inches above the J-groove weld to the top of the threaded region, which is approximately 0.75 inch above the bottom of the nozzle.

The U.S. Nuclear Regulatory Commission (NRC) staff has the following questions regarding the information provided in the relaxation request:

1. The licensee stated that a structural evaluation was performed for the IP3 nozzles.

Provide the applicable technical data (i.e., operating stress levels, crack growth analysis, hoop stresses, etc.) which supports the conclusion that the area in the threaded region is insignificant.

2. The licensee stated that if cracking is detected above the threaded region, and extends into the threaded area, other nondestructive examination (NDE) methods would be used to determine the extent of cracking.

Identify the particular NDE methods that would be utilized, and provide the justification why this additional NDE would not be proposed/performed as an alternative to the requirements in the Order.

Enclosure