

# **RIC 2003**

## **Emergent Technical Issues**

### **Session T2**

---

## **Regulatory Processes for Emergent Issues**

**Brian W. Sheron**  
**Associate Director for Project Licensing**  
**and Technical Analysis**  
**Office of Nuclear Reactor Regulation**  
**April 17, 2003**



# Recent Agency Communications on Material Issues

- **Steam Generator Tube Issues**
  - IN 2002-02, Supp. 1; Experience with plugged SG tubes
  - IN 2002-21; Degradation of thermally treated Alloy 600 SG tubing
  - Draft Generic Communication on SG tubesheet inspections

# Recent Agency Communications on Material Issues (cont.)

- **Reactor Pressure Vessel Issues**
  - Bulletin 2001-01; Inspect RPV penetrations
  - Bulletin 2002-01; Davis-Besse experience
  - Bulletin 2002-02; Supplemental Inspection information and techniques
  - 2-11-03 Order; Established interim inspection requirements

# Future Agency/Industry Actions

- Over past several years, the NRC has had to take regulatory actions via generic communications to assure plant safety.
- Future agency actions will depend on extent industry proactively addresses issues in a timely manner.
- Without timely industry initiatives to address emergent issues, the NRC will likely continue to use generic communications (e.g., GLs, Bulletins, Orders) to ensure adequate protection of public health and safety.