

June 10, 2003

MEMORANDUM TO: Marsha Gamberoni, Deputy Director  
New Reactor Licensing Project Office  
Office of Nuclear Reactor Regulation

FROM: John P. Segala, Senior Project Manager */RA/*  
New Reactor Licensing Project Office  
Office of Nuclear Reactor Regulation

SUBJECT: APRIL 29, 2003, AP1000 TELEPHONE CONFERENCE CALL  
SUMMARY

On Tuesday, April 29, 2003, a telephone conference call was held with Westinghouse Electric Company (Westinghouse) representatives and Nuclear Regulatory Commission (NRC) staff to discuss AP1000 design questions the staff had regarding inspections, tests, analyses and acceptance criteria (ITAAC) and the amount of hydrogen generation from a zirconium-water reaction. A list of call participants is included in Attachment 1.

The following is a brief summary of the discussions regarding the staff's questions:

The NRC staff discussed their question regarding the equipment hatch hoist system and the maintenance hatch hoist system being classified as single-failure-proof systems in the AP1000 Design Control Document (DCD) Tier 2 Section 9.1.5, "Overhead Heavy Load Handling Systems," but not being tested as single failure proof in the ITAAC. Westinghouse understood the staff's comment and it was agreed to make this inconsistency an open item in Section 14.3 of the staff's draft safety evaluation report (DSER).

The NRC staff discussed their question regarding why the Atmospheric Dispersion Factors (X/Q) for the control room were not provided in DCD Tier 1 Table 5.0-1, "Site Parameters." Westinghouse understood the staff's question and agreed to research the basis for not providing the control room X/Q values in the table. It was also agreed that this issue would become an open item in the staff's DSER.

The NRC staff discussed their question regarding whether Westinghouse calculated the 788 kg of hydrogen in DCD Tier 2 Appendix 19D by using 100 percent of the active fuel clad oxidation or by using the total zirconium in the core. Westinghouse clarified that they used the total zirconium in the core to calculate the 788 kg of Hydrogen discussed in the DCD. This clarification resolved the staff's question.

Docket No. 52-006

Attachments: As stated

cc w/atts: See next page

June 10, 2003

MEMORANDUM TO: Marsha Gamberoni, Deputy Director  
New Reactor Licensing Project Office  
Office of Nuclear Reactor Regulation

FROM: John P. Segala, Senior Project Manager */RA/*  
New Reactor Licensing Project Office  
Office of Nuclear Reactor Regulation

SUBJECT: APRIL 29, 2003, AP1000 TELEPHONE CONFERENCE CALL  
SUMMARY

On Tuesday, April 29, 2003, a telephone conference call was held with Westinghouse Electric Company (Westinghouse) representatives and Nuclear Regulatory Commission (NRC) staff to discuss AP1000 design questions the staff had regarding inspections, tests, analyses and acceptance criteria (ITAAC) and the amount of hydrogen generation from a zirconium-water reaction. A list of call participants is included in Attachment 1.

The following is a brief summary of the discussions regarding the staff's questions:

The NRC staff discussed their question regarding the equipment hatch hoist system and the maintenance hatch hoist system being classified as single-failure-proof systems in the AP1000 Design Control Document (DCD) Tier 2 Section 9.1.5, "Overhead Heavy Load Handling Systems," but not being tested as single failure proof in the ITAAC. Westinghouse understood the staff's comment and it was agreed to make this inconsistency an open item in Section 14.3 of the staff's draft safety evaluation report (DSER).

The NRC staff discussed their question regarding why the Atmospheric Dispersion Factors (X/Q) for the control room were not provided in DCD Tier 1 Table 5.0-1, "Site Parameters." Westinghouse understood the staff's question and agreed to research the basis for not providing the control room X/Q values in the table. It was also agreed that this issue would become an open item in the staff's DSER.

The NRC staff discussed their question regarding whether Westinghouse calculated the 788 kg of hydrogen in DCD Tier 2 Appendix 19D by using 100 percent of the active fuel clad oxidation or by using the total zirconium in the core. Westinghouse clarified that they used the total zirconium in the core to calculate the 788 kg of Hydrogen discussed in the DCD. This clarification resolved the staff's question.

Docket No. 52-006

Attachments: As stated

cc w/atts: See next page

Distribution:

Hard Copy

NRLPO R/F

JLyons

MGamberoni

JSegala

E-mail

PUBLIC

RBorchardt

JMoore, OGC

MRubin

HWalker

LBrown

ADrozd

RWeisman, OGC

JSegala

JColaccino

JStarefos

JWilson

RDennig

ACCESSION NUMBER: ML031500614

OFFICE	NRLPO/PM	SPSB/SC	SPSB/SC	NRLPO/DD
NAME	JSegala	BDennig	MRubin	MGamberoni
DATE	5/30/03	6/4/03	6/4/03	6/9/03

APRIL 29, 2003  
TELEPHONE CONFERENCE CALL SUMMARY  
LIST OF PARTICIPANTS

Nuclear Regulatory Commission

John Segala  
Harold Walker  
Leta Brown  
Andre Drozd  
Jerry Wilson  
Joelle Starefos

Westinghouse

Mike Corletti  
Dale Wiseman  
Jim Scoble  
Jim Grover

AP 1000

cc:

Mr. W. Edward Cummins  
AP600 and AP1000 Projects  
Westinghouse Electric Company  
P.O. Box 355  
Pittsburgh, PA 15230-0355

Mr. H. A. Sepp  
Westinghouse Electric Company  
P.O. Box 355  
Pittsburgh, PA 15230

Lynn Connor  
Doc-Search Associates  
2211 SW 1<sup>ST</sup> Ave - #1502  
Portland, OR 97201

Barton Z. Cowan, Esq.  
Eckert Seamans Cherin & Mellott, LLC  
600 Grant Street 44<sup>th</sup> Floor  
Pittsburgh, PA 15219

Mr. Ed Rodwell, Manager  
Advanced Nuclear Plants' Systems  
Electric Power Research Institute  
3412 Hillview Avenue  
Palo Alto, CA 94304-1395

Charles Brinkman, Director  
Washington Operations  
Westinghouse Electric Company  
12300 Twinbrook Parkway, Suite 330  
Rockville, MD 20852

Mr. R. Simard  
Nuclear Energy Institute  
1776 I Street NW  
Suite 400  
Washington, DC 20006

Mr. Thomas P. Miller  
U.S. Department of Energy  
Headquarters - Germantown  
19901 Germantown Road  
Germantown, MD 20874-1290

Mr. David Lochbaum  
Nuclear Safety Engineer  
Union of Concerned Scientists  
1707 H Street NW, Suite 600  
Washington, DC 20006-3919

Mr. Paul Gunter  
Nuclear Information & Resource Service  
1424 16th Street, NW., Suite 404  
Washington, DC 20036

Mr. Tom Clements  
6703 Guide Avenue  
Takoma Park, MD 20912

Mr. James Riccio  
Greenpeace  
702 H Street, NW, Suite 300  
Washington, DC 20001

Mr. James F. Mallay, Director  
Regulatory Affairs  
FRAMATOME, ANP  
3315 Old Forest Road  
Lynchburg, VA 24501

Mr. Ed Wallace, General Manager  
Project Management  
Lake Buena Vista Bldg., 3<sup>rd</sup> Floor  
1267 Gordon Hood Avenue  
Centurion 0046  
Republic of South Africa  
PO Box 9396 Centurion 0046

Mr. Vince Langman  
Licensing Manager  
Atomic Energy of Canada Limited  
2251 Speakman Drive  
Mississauga, Ontario  
Canada L5K 1B2

Mr. Gary Wright, Manager  
Office of Nuclear Facility Safety  
Illinois Department of Nuclear Safety  
1035 Outer Park Drive  
Springfield, IL 62704

Dr. Gail H. Marcus  
U.S. Department of Energy  
Room 5A-143  
1000 Independence Ave., SW  
Washington, DC 20585

Mr. Edwin Lyman  
Nuclear Control Institute  
1000 Connecticut Avenue, NW  
Suite 410  
Washington, DC 20036

Mr. Jack W. Roe  
SCIENTECH, INC.  
910 Clopper Road  
Gaithersburg, MD 20878

Patricia Campbell  
Winston & Strawn  
1400 L Street, NW  
Washington, DC 20005

Mr. David Ritter  
Research Associate on Nuclear Energy  
Public Citizens Critical Mass Energy  
and Environmental Program  
215 Pennsylvania Avenue, SE  
Washington, DC 20003

Mr. Michael M. Corletti  
Passive Plant Projects & Development  
AP600 & AP1000 Projects  
Westinghouse Electric Company  
P. O. Box 355  
Pittsburgh, PA 15230-0355