

From: Kenneth Chang
To: Skm1
Date: 6/10/03 12:43PM
Subject: RNP Telecon Summary on 6/9/03

S.K.,

The following summarizes our telephone conference with Roger Steward of RNP:

1. The staff is concerned regarding when we will be able to receive Robinson's responses to metal fatigue TLAA and AMP questions on the fw-aux.fw tee and the pressurizer surge line/nozzle discussed in the audit conducted on 5/28 and 5/29 at the Robinson site. Roger responded that the write-up is currently in the review and approval process and will be submitted on 6/13 as promised. He can send a draft copy within the day, which was accepted by the staff.

2. Roger also clarified that the spent fuel (7110) system referred in the AMP Table for structural/components requiring one-time inspection is the "spent fuel cooling system" described in LRA section 2.3.3.9. There is only one system describing "spent fuel".

Ken Chang

CC: Yueh-Li Li

Accession Number: ML031611018