

NRC 2003-0054

GL 97-02


June 09, 2003

U.S. Nuclear Regulatory Commission
ATTN: Document Control Desk
Washington, D.C. 20555

DOCKETS 50-266 AND 50-301
POINT BEACH NUCLEAR PLANT, UNITS 1 AND 2
MONTHLY OPERATING REPORTS

Attached are monthly operating reports for Units 1 and 2 of the Point Beach Nuclear Plant for the calendar month of May 2003.

Sincerely,



A. J. Cayia
Site Vice President

KML

Attachment

cc: J. D. Loock, PSCW
NRC Regional Administrator
NRC Resident Inspector
NRC Project Manager

JEAY

UNIT SHUTDOWNS

DOCKET NO. 50-266
 UNIT NAME: Point Beach, Unit 1
 DATE: 6/06/2003
 COMPLETED BY: Kim M. Locke
 TELEPHONE: 755-6420

REPORTING PERIOD: May 2003
 (Month/Year)

NO.	DATE	TYPE	DURATION (HOURS)	REASON (1)	METHOD OF SHUTTING DOWN (2)	CAUSE/CORRECTIVE ACTIONS
		F: FORCED S: SCHEDULED				COMMENTS
N/A	N/A	N/A	N/A	N/A	N/A	N/A

(1) Reason

- A. Equipment Failure (Explain)
- B. Maintenance or Test
- C. Refueling
- D. Regulatory Restriction
- E. Operator Training/license Examination
- F. Administrative
- G. Operational Error (Explain)
- H. Other (Explain)

(2) Method

- 1 Manual
- 2 Manual Trip/Scram
- 3 Automatic Trip/Scram
- 4 Continuation
- 5 Other (Explain)

SUMMARY:

Unit 1 average daily power for the month of May was 513.6 MWe.
 No Significant Operating Event occurred on Unit 1 in May.
 There were no LER's on Unit 1 in the month of May.

OPERATING DATA REPORT

DOCKET NO. 50-266
UNIT NAME POINT BEACH NUCLEAR PLANT - UNIT 1
DATE 06/03/03
COMPLETED BY Kim M. Locke
TELEPHONE 920-755-6420

REPORTING PERIOD May - 2003

1. DESIGN ELECTRICAL RATING (MWE-NET) 522.0
2. MAXIMUM DEPENDABLE CAPACITY (MWE-NET) 516.0

	<u>MONTH</u>	<u>YEAR TO DATE</u>	<u>CUMULATIVE</u>
3. NUMBER OF HOURS REACTOR WAS CRITICAL	744.0	3,623.0	235,222.4
4. NUMBER OF HOURS THE GENERATOR WAS ON LINE	744.0	3,623.0	231,681.5
5. UNIT RESERVED SHUTDOWN HOURS	0.0	0.0	846.9
6. NET ELECTRICAL ENERGY (MWH)	382,114.5	1,849,246.0	107,400,555.0

DATA REPORTED AND FACTORS CALCULATED AS REQUESTED IN NRC GENERIC LETTER 97-02 DATED MAY 15, 1997

UNIT SHUTDOWNS

DOCKET NO. 50-301
 UNIT NAME: Point Beach, Unit 2
 DATE: 6/06/2003
 COMPLETED BY: Kim M. Locke
 TELEPHONE: 755-6420

REPORTING PERIOD: May 2003
 (Month/Year)

NO.	DATE	TYPE	DURATION (HOURS)	REASON (1)	METHOD OF SHUTTING DOWN (2)	CAUSE/CORRECTIVE ACTIONS
		F: FORCED S: SCHEDULED				COMMENTS
N/A	N/A	N/A	N/A	N/A	N/A	N/A

(1) Reason

- A. Equipment Failure (Explain)
- B. Maintenance or Test
- C. Refueling
- D. Regulatory Restriction
- E. Operator Training/license Examination
- F. Administrative
- G. Operational Error (Explain)
- H. Other (Explain)

(2) Method

- 1 Manual
- 2 Manual Trip/Scram
- 3 Automatic Trip/Scram
- 4 Continuation
- 5 Other (Explain)

SUMMARY:

Unit 2 average daily power for the month of May was 485.1 MWe.

The following Significant Operating Event occurred on Unit 2 in May:

Steam Leak from 2P-28A, Steam Generator Feed Pump casing.

The following LER's were sent to the NRC in the month of May:

- 2003-002-00 - TS Required shutdown due to TSAC 3.1.6.B.2 not met
- 2003-001-00 - Containment Accident Fan Backdraft Damper Fan Failure
- 2003-003-00 - Failure to place instrument channel in trip as specified by LCO 3.3.1

OPERATING DATA REPORT

DOCKET NO. 50-301
UNIT NAME POINT BEACH NUCLEAR PLANT - UNIT 2
DATE 06/03/03
COMPLETED BY Kim M. Locke
TELEPHONE 920-755-6420

REPORTING PERIOD May - 2003

1. DESIGN ELECTRICAL RATING (MWE-NET) 522.0
2. MAXIMUM DEPENDABLE CAPACITY (MWE-NET) 518.0

	<u>MONTH</u>	<u>YEAR TO DATE</u>	<u>CUMULATIVE</u>
3. NUMBER OF HOURS REACTOR WAS CRITICAL	744.0	3,577.0	229,330.1
4. NUMBER OF HOURS THE GENERATOR WAS ON LINE	744.0	3,535.4	226,301.1
5. UNIT RESERVED SHUTDOWN HOURS	0.0	0.0	302.2
6. NET ELECTRICAL ENERGY (MWH)	360,884.5	1,785,159.0	106,572,962.5

DATA REPORTED AND FACTORS CALCULATED AS REQUESTED IN NRC GENERIC LETTER 97-02 DATED MAY 15, 1997