

**B. Primary Coolant Sources Outside Containment**

This program provides controls to minimize leakage from those portions of systems outside containment that could contain highly radioactive fluids during a serious transient or accident to levels as low as practicable. The systems include Core Spray, High Pressure Coolant Injection, Residual Heat Removal, Reactor Core Isolation Cooling, Combustible Gas Control, process sampling, and Standby Gas Treatment. The program shall include the following:

1. Preventive maintenance and periodic visual inspection requirements; and
2. Integrated leak test requirements for each system at refueling cycle intervals or less.

The provisions of Specification 4.0.B are applicable.

A program acceptable to the Commission was described in a letter dated December 31, 1979, from L O Mayer, NSP, to Director of Nuclear Reactor Regulation, "Lessons Learned Implementation."

**C. (Deleted)**