

Duke Energy Corporation 526 South Church Street P.O. Box 1006 Charlotte, NC 28201-1006

June 16, 2003

U.S. Nuclear Regulatory Commission Attention: Document Control Desk Washington, D.C. 20555

Subject: Duke Energy Corporation Oconee Nuclear Station, Units 1, 2, and 3 Docket Numbers 50-269, 50-270 and 50-287 Monthly Performance and Operation Status-May, 2003

Please find attached information concerning the performance and operation status of the Oconee Nuclear Station for the month of May, 2003 and Revision 1 of the Personnel Exposure page for the month of April, 2003. Please be advised the year-to-date and cumulative values for the gross thermal energy generated (MWH) has been in error from June, 1999 to April, 2003 for units 2 and 3. Please advise if these reports submitted in this timeframe should be resubmitted. However this specific data element was omitted for reporting per Generic Letter 97-02 issued May 15, 1997.

Any questions or comments may be directed to Roger A. Williams at (704) 382-5346.

Sincerely,

M. S. Tucken

M. S. Tuckman Executive Vice President Nuclear Generation Duke Power

Attachment XC:

L. A. Reyes, Regional Administrator USNRC, Region II

Dave LaBarge, Project Manager USNRC, ONRR

TEad

INPO Records Center

# **Operating Data Report**

		Docket No. Date	<u>50-269</u> June 16,2003
		Completed By	Roger Williams
		Telephone	704-382-5346
<b>Operating State</b>	<u>us</u>		
1. Unit Name:	Oconee 1		
2. Reporting Period:	May 1, 2003 - May 31, 2003		
3. Licensed Thermal	Power (MWt):	2568	Notes: Year-to-date
4. Nameplate Rating	(Gross MWe):	934	and cumulative
5. Design Electrical I	Rating (Net Mwe):	886	capacity factors are
6. Maximum Depend	able Capacity (Gross MWe):	886	weighted average for
7. Maximum Depend	able Capacity(Net MWe):	846	maximum dependable
8. If Changes Occure	d in Capacity Ratings (Items Number 3-7) Since L	ast Report, Give Reasons:	capacity.

## 9. Power Level To Which Restricted, If Any (Net MWe):

10. Reason for Restrictions, If any:

	This Month	YTD	Cumulative
11. Hours in Reporting Period	744.0	3623.0	261888.0
12. Number of Hours Reactor was Critical	744.0	3623.0	207186.1
13. Reactor Reserve Shutdown Hours	0.0	0.0	0.0
14. Hours Generator On-Line	744.0	3623.0	203683.1
15. Unit Reserve Shutdown Hours	0.0	0.0	0.0
16. Gross Thermal Energy Generated (MWH)	1884707	9209671	504412325
17. Gross Electrical Energy Generated (MWH)	661958	3237652	174488959
18. Net Electrical Energy Generated (MWH)	633666	3103874	165977920
19. Unit Service Factor	100.0	100.0	77.8
20. Unit Availability Factor	100.0	100.0	77.8
21. Unit Capacity Factor (Using MDC Net)	100.7	101.3	74.2
22. Unit Capacity Factor (Using DER Net)	96.1	96.7	71.5
23. Unit Forced Outage Rate	0.0	0.0	9.1
04 Obustieren Ostestala d'Oues Mart ( Martin (Truss Data and D			

24. Shutdown Scheduled Over Next 6 Months (Type, Date and Duration of Each)

#### 25. If ShutDown At End Of Report Period, Estimated Date of Startup

26. Units in Test Status (Prior to Commercial Operation)

	Forcast	Achieved
Initial Criticality		
Initial Electricity		· · · · · · · · · · · · · · · · · · ·
Commercial Operation		

NRC Calculated from Generator Nameplate Data: 1 037 937 KVA x 0.90 Pf=934 MW

## UNIT SHUTDOWNS

DOCKET NO. <u>50-269</u> UNIT NAME: Oconee 1 DATE: June 16, 2003 COMPLETED BY: Roger Williams TELEPHONE: 704-382-5346

REPORT MONTH: May, 2003

No.	Date:	Туре	Duration	(1) Reason	(2) Method of	Licensed	Cause and Corrective Action to Prevent Recurrence
		F - Forced	Hours		Shutdown R/X	Event Report	rt
		S - Scheduled			· · · · · · · · · · · · · · · · · · ·	No.	
			No	Outages	for the Month		
Summar	y:	•					
1							
(1) Reas	on	<u> </u>	<u></u>				(2) Method
A - Equi	oment failure (	(Explain)	E - Operato	r Training/Lice	ense Examination		1 - Manual 2 - Manual Trip/Scram

- A Equipment failure (Explain)
- B Maintenance or Test
- C Refueling
- D Regulatory restriction
- F Administrative

1

- G Operator Error (Explain)
- H Other (Explain)

- 1 Manual
- 2 Manual Trip/Scram
- 3 Automatic Trip/Scram 4 Continuation
- 5 Other (Explain)

#### MONTHLY REFUELING INFORMATION REQUEST

- 1. Facility name: Oconee Unit 1
- 2. Scheduled next refueling shutdown: September 2003
- 3. Scheduled restart following refueling: December 2003

THE PROJECT MANAGER HAS BEEN ADVISED BY SEPARATE COMMUNICATION OF ANY T.S. CHANGE OR LICENSE AMENDMENT. THEREFORE, QUESTIONS 4 THROUGH 6 WILL NO LONGER BE MAINTAINED IN THIS REPORT.

4. Will refueling or resumption of operation thereafter require a technical specification change or other license amendment?

If yes, what will these be?

If no, has reload design and core configuration been reviewed by Safety Review Committee regarding unreviewed safety questions?

- 5. Scheduled date(s) for submitting proposed licensing action and supporting information.
- 6. Important licensing considerations (new or different design or supplier, unreviewed design or performance analysis methods, significant changes in design or new operating procedures).
- 7. Number of Fuel assemblies
- (a) in the core: 177
- (b) in the spent fuel pool: <u>926\*</u>

DATE: June 16, 2003

- (c) in the ISFSI: 1800\*\*\*\*
- Present licensed fuel pool capacity: <u>1312</u>
  Size of requested or planned increase: <u>\*\*</u>
- 9. Projected date of last refueling which can be accommodated by present capacity: <u>January 2005</u>\*\*\*

DUKE POWER COMPANY

Name of Contact: R. A. Williams Phone: (704) - 382-5346

- Represents the combined total for Units 1 and 2
- \*\* On March 29, 1990, received a site specific license for ISFSI which will store 2112 assemblies (88 modules). Forty (40) site specific modules were constructed and loaded.
- In 1999 Oconee transitioned to its general license. Forty-four (44) general license modules were installed and 30 modules have now been loaded.
  Additional modules will be installed on an as-needed basis.
- \*\*\*\* Represents the combined total for Units 1, 2, and 3

# **Operating Data Report**

~.		Docket No. Date Completed By Telephone	<u>50-270</u> June 16,2003 Roger Williams 704-382-5346	
<b>Operating Status</b>				
1. Unit Name: Ocon	ee 2			
2. Reporting Period: May	1, 2003 - May 31, 2003			
3. Licensed Thermal Power (M	[Wt):	2568	Notes: Year-to-date	
4. Nameplate Rating (Gross M	We):	934	and cumulative	
5. Design Electrical Rating (N	et Mwe):	886	capacity factors are	
6. Maximum Dependable Capa	city (Gross MWe):	886	weighted average for	
7. Maximum Dependable Capa	city(Net MWe):	846	maximum dependable	
8. If Changes Occured in Capa	city Ratings (Items Number 3-7) Since La	ast Report, Give Reasons:	capacity.	

9. Power Level To Which Restricted, If Any (Net MWe):

10. Reason for Restrictions, If any:

	This Month	YTD	Cumulative
11. Hours in Reporting Period	744.0	3623.0	251808.0
12. Number of Hours Reactor was Critical	744.0	3623.0	204708.8
13. Reactor Reserve Shutdown Hours	0.0	0.0	0.0
14. Hours Generator On-Line	744.0	3623.0	202129.7
15. Unit Reserve Shutdown Hours	0.0	0.0	0.0
16. Gross Thermal Energy Generated (MWH)	1910592	9297187	499850742
17. Gross Electrical Energy Generated (MWH)	674201	3281363	171934347
18. Net Electrical Energy Generated (MWH)	646336	3149934	163876252
19. Unit Service Factor	100.0	100.0	80.3
20. Unit Availability Factor	100.0	100.0	80.3
21. Unit Capacity Factor (Using MDC Net)	102.7	102.8	76.3
22. Unit Capacity Factor (Using DER Net)	98.1	98.1	73.5
23. Unit Forced Outage Rate	0.0	0.0	8.5
24 Shadow Sabadalad Own Need (Marthe Three Date and Derich	· CT 1- )		

24. Shutdown Scheduled Over Next 6 Months (Type, Date and Duration of Each)

25. If ShutDown At End Of Report Period, Estimated Date of Startup

26. Units in Test Status (Prior to Commercial Operation)

	Forcast	Achieved
Initial Criticality		
Initial Electricity		
Commercial Operation		

NRC Calculated from Generator Nameplate Data: 1 037 937 KVA x 0.90 Pf=934 MW

## **UNIT SHUTDOWNS**

## DOCKET NO. <u>50-270</u> UNIT NAME: <u>Oconee 2</u> DATE: <u>June 16, 2003</u> COMPLETED BY: <u>Roger Williams</u> TELEPHONE: <u>704-382-5346</u>

## REPORT MONTH: May, 2003

No.	Date:	Туре	Duration	(1) Reason	(2) Method of	Licensed	Cause and Corrective Action to Prevent Recurrence
		F - Forced	Hours		Shutdown R/X	Event Report	
		S - Scheduled				No.	
			No	Outages	for the Month		
Summar	<b>;y:</b>						
L							

- (1) Reason
- A Equipment failure (Explain)
- B Maintenance or Test
- C Refueling
- D Regulatory restriction
- F Administrative

E - Operator Training/License Examination

- G Operator Error (Explain)
- H Other (Explain)

- (2) Method
- 1 Manual
- 2 Manual Trip/Scram
- 3 Automatic Trip/Scram 4 Continuation
- 5 Other (Explain)

#### MONTHLY REFUELING INFORMATION REQUEST

- 1. Facility name: <u>Oconee Unit 2</u>
- 2. Scheduled next refueling shutdown: March, 2004
- 3. Scheduled restart following refueling: June, 2004

#### THE PROJECT MANAGER HAS BEEN ADVISED BY SEPARATE COMMUNICATION OF ANY T.S. CHANGE OR LICENSE AMENDMENT. THEREFORE, QUESTIONS 4 THROUGH 6 WILL NO LONGER BE MAINTAINED IN THIS REPORT.

4. Will refueling or resumption of operation thereafter require a technical specification change or other license amendment?

If yes, what will these be?

If no, has reload design and core configuration been reviewed by Safety Review Committee regarding unreviewed safety questions?

- 5. Scheduled date(s) for submitting proposed licensing action and supporting information.
- 6. Important licensing considerations (new or different design or supplier, unreviewed design or performance analysis methods, significant changes in design or new operating procedures).
- 7. Number of Fuel assemblies
- (a) in the core: 177
- (b) in the spent fuel pool: <u>926\*</u>
- (c) in the ISFSI: See unit 1 \*\*\*\*

DATE: June 16, 2003

- Present licensed fuel pool capacity: <u>1312</u>
  Size of requested or planned increase: <u>\*\*</u>
- 9. Projected date of last refueling which can be accommodated by present capacity: January 2005\*\*\*

DUKE POWER COMPANY

Name of Contact: R. A. Williams Phone: (704) - 382-5346

- Represents the combined total for Units 1 and 2
- \*\* See footnote on Unit 1
- In 1999 Oconee transitioned to its general license. Forty-four (44) general license modules were installed and 30 modules have now been loaded.
  Additional modules will be installed on an as-needed basis.
- \*\*\*\* See footnote on Unit 1

# **Operating Data Report**

		Docket No.	<u>50-287</u>	
		Date	<u>June 16,2003</u>	
		Completed By	Roger Williams	
		Telephone	<u>704-382-5346</u>	
Operating Status	S			
1. Unit Name:	Oconee 3			
2. Reporting Period:	May 1, 2003 - May 31, 2003			
3. Licensed Thermal P	ower (MWt):	2568	Notes: Year-to-date	
4. Nameplate Rating (	Gross MWe):	934	and cumulative	
5. Design Electrical Ra	ting (Net Mwe):	886	capacity factors are	
6. Maximum Dependal	ble Capacity (Gross MWe):	886	weighted average for	
7. Maximum Dependal	ble Capacity(Net MWe):	846	maximum dependable	
8. If Changes Occured	in Capacity Ratings (Items Number 3-7) Since I	Last Report, Give Reasons:	capacity.	

## 9. Power Level To Which Restricted, If Any (Net MWe):

10. Reason for Restrictions, If any:

	This Month	YTD	Cumulative
11. Hours in Reporting Period	744.0	3623.0	249455.0
12. Number of Hours Reactor was Critical	0.0	2763.0	197815.9
13. Reactor Reserve Shutdown Hours	0.0	0.0	0.0
14. Hours Generator On-Line	0.0	2761.0	195167.1
15. Unit Reserve Shutdown Hours	0.0	0.0	0.0
16. Gross Thermal Energy Generated (MWH)	0 -	6851629	488111289
17. Gross Electrical Energy Generated (MWH)	0	2414136	168963411
18. Net Electrical Energy Generated (MWH)	0	2310915	161210560
19. Unit Service Factor	0.0	76.2	78.2
20. Unit Availability Factor	0.0	76.2	78.2
21. Unit Capacity Factor (Using MDC Net)	0.0	75.4	75.7
22. Unit Capacity Factor (Using DER Net)	0.0	72.0	72.9
23. Unit Forced Outage Rate	0.0	0.0	8.9
A DI AL DI LI AD NI ACME A MILL DATA IDENTITA	、		

24. Shutdown Scheduled Over Next 6 Months (Type, Date and Duration of Each)

## 25. If ShutDown At End Of Report Period, Estimated Date of Startup

26. Units in Test Status (Prior to Commercial Operation)

	Forcast	Achieved
Initial Criticality		
Initial Electricity		
Commercial Operation		

NRC Calculated from Generator Nameplate Data: 1 037 937 KVA x 0.90 Pf=934 MW

## **UNIT SHUTDOWNS**

## DOCKET NO. <u>50-287</u> UNIT NAME: <u>Oconee 3</u> DATE: <u>June 16, 2003</u> COMPLETED BY: <u>Roger Williams</u> TELEPHONE: <u>704-382-5346</u>

REPORT MONTH: May, 2003

No.	Date:	Type F - Forced S - Scheduled	Duration Hours	(1) Reason	(2) Method of Shutdown R/X	Licensed Event Report No.	Cause and Corrective Action to Prevent Recurrence
1	05/01/03	S	744.00	С	4		END-OF-CYCLE 20 REFUELING OUTAGE
C							

#### Summary:

The unit began the month of May in end-of-cycle 20 refueling outage. The unit remained in the outage the remainder of the month.

(1) Reason

- A Equipment failure (Explain)
- B Maintenance or Test
- C Refueling
- D Regulatory restriction
- E Operator Training/License Examination
- F Administrative
- G Operator Error (Explain)
- H Other (Explain)

- (2) Method
- 1 Manual
- 2 Manual Trip/Scram
- 3 Automatic Trip/Scram 4 Continuation
- 5 Other (Explain)

### MONTHLY REFUELING INFORMATION REQUEST

- 1. Facility name: Oconee Unit 3
- 2. Scheduled next refueling shutdown: Currently Refueling
- 3. Scheduled restart following refueling: June 2003

THE PROJECT MANAGER HAS BEEN ADVISED BY SEPARATE COMMUNICATION OF ANY T.S. CHANGE OR LICENSE AMENDMENT. THEREFORE, QUESTIONS 4 THROUGH 6 WILL NO LONGER BE MAINTAINED IN THIS REPORT.

4. Will refueling or resumption of operation thereafter require a technical specification change or other license amendment?

If yes, what will these be?

If no, has reload design and core configuration been reviewed by Safety Review Committee regarding unreviewed safety questions?

- 5. Scheduled date(s) for submitting proposed licensing action and supporting information.
- 6. Important licensing considerations (new or different design or supplier, unreviewed design or performance analysis methods, significant changes in design or new operating procedures).
- 7. Number of Fuel assemblies
- (a) in the core: 177
- (b) in the spent fuel pool: 476
- (c) in the ISFSI: See Unit 1 \*\*\*\*
- Present licensed fuel pool capacity: <u>825</u>
  Size of requested or planned increase: <u>\*\*</u>
- 9. Projected date of last refueling which can be accommodated by present capacity: January 2005\*\*\*

DUKE POWER COMPANY		DATE:	June 16, 2003
Name of Contact:	R. A. Williams	Phone:	(704) - 382-5346

- \*\* See footnote of Unit 1
- In 1999 Oconee transitioned to its general license. Forty-four (44) general license modules were installed and 30 modules have now been loaded.
  Additional modules will be installed on an as-needed basis.
- \*\*\*\* See footnote on Unit 1

## OCONEE NUCLEAR STATION

## MONTHLY OPERATING STATUS REPORT

## APRIL 2003

## 1. Personnel Exposure -

The total station liquid release for APRIL has been compared with the Technical Specifications maximum annual dose commitment and was less than 10 percent of this limit.

The total station gaseous release for APRIL has been compared with the Technical Specifications maximum annual dose commitment and was less than 10 percent of this limit.

## Revision 1

## OCONEE NUCLEAR STATION

## MONTHLY OPERATING STATUS REPORT

## MARCH 2003

### 1. Personnel Exposure -

The total station liquid release for MARCH has been compared with the Technical Specifications maximum annual dose commitment and was less than 10 percent of this limit.

The total station gaseous release for MARCH has been compared with the Technical Specifications maximum annual dose commitment and was less than 10 percent of this limit.