

TABLE 2.2-1 (Continued)

REACTOR TRIP SYSTEM INSTRUMENTATION TRIP SETPOINTS

<u>FUNCTIONAL UNIT</u>	<u>TRIP SETPOINT</u>	<u>ALLOWABLE VALUES</u>
13. Steam Generator Water Level--Low-Low	≥ 14.0% of narrow range instrument span-each steam generator	≥ 13.0% of narrow range instrument span-each steam generator
14. Deleted		
15. Undervoltage-Reactor Coolant Pumps	≥ 2900 volts-each bus	≥ 2850 volts-each bus
16. Underfrequency-Reactor Coolant Pumps	≥ 56.5 Hz - each bus	≥ 56.4 Hz - each bus
17. Turbine Trip		
A. Low Trip System Pressure	≥ 45 psig	≥ 45 psig
B. Turbine Stop Valve Closure	≤ 15% off full open	≤ 15% off full open
18. Safety Injection Input from ESF	Not Applicable	Not Applicable
19. Reactor Coolant Pump Breaker Position Trip	Not Applicable	Not Applicable

TABLE 3.3-4 (continued)
ENGINEERED SAFETY FEATURE ACTUATION SYSTEM INSTRUMENTATION
TRIP SETPOINTS

<u>FUNCTIONAL UNIT</u>	<u>TRIP SETPOINT</u>	<u>ALLOWABLE VALUES</u>
5. TURBINE TRIP AND FEEDWATER ISOLATION		
A. Steam Generator Water Level -- High-High	≤ 67% of narrow range instrument span each steam generator	≤ 68% of narrow range instrument span each steam generator
6. SAFEGUARDS EQUIPMENT CONTROL SYSTEM (SEC)	Not Applicable	Not Applicable
7. UNDERVOLTAGE, VITAL BUS		
a. Loss of Voltage	≥ 70% of bus voltage	≥ 65% of bus voltage
b. Sustained Degraded Voltage	≥ 94.6% of bus voltage for ≤ 13 seconds	≥ 94% of bus voltage for ≤ 15 seconds
8. AUXILIARY FEEDWATER		
a. Automatic Actuation Logic	Not Applicable	Not Applicable
b. NOT USED		
c. Steam Generator Water Level-- Low-Low	≥ 14.0% of narrow range instrument span each steam generator	≥ 13.0% of narrow range instrument span each steam generator
d. Undervoltage - RCP	≥ 70% RCP bus voltage	≥ 65% RCP bus voltage
e. S.I.	See 1 above (All S.I. setpoints)	
f. Trip of Main Feedwater Pumps	Not Applicable	Not Applicable
g. Station Blackout	See 6 and 7 above (SEC and Undervoltage, Vital Bus)	

TABLE 2.2-1 (Continued)

REACTOR TRIP SYSTEM INSTRUMENTATION TRIP SETPOINTS

<u>FUNCTIONAL UNIT</u>	<u>TRIP SETPOINT</u>	<u>ALLOWABLE VALUES</u>
13. Steam Generator Water Level--Low-Low	$\geq 14.0\%$ of narrow range instrument span-each steam generator	$\geq 13.0\%$ of narrow range instrument span-each steam generator
14. Deleted		
15. Undervoltage-Reactor Coolant Pumps	≥ 2900 volts-each bus	≥ 2850 volts-each bus
16. Underfrequency-Reactor Coolant Pumps	≥ 56.5 Hz - each bus	≥ 56.4 Hz - each bus
17. Turbine Trip		
A. Low Trip System Pressure	≥ 45 psig	≥ 45 psig
B. Turbine Stop Valve Closure	$\leq 15\%$ off full open	$\leq 15\%$ off full open
18. Safety Injection Input from ESF	Not Applicable	Not Applicable
19. Reactor Coolant Pump Breaker Position Trip	Not Applicable	Not Applicable

TABLE 3.3-4

ENGINEERED SAFETY FEATURE ACTUATION SYSTEM INSTRUMENTATION

TRIP SETPOINTS

<u>FUNCTIONAL UNIT</u>	<u>TRIP SETPOINT</u>	<u>ALLOWABLE VALUES</u>
7. UNDervOLTAGE, VITAL BUS		
a. Loss of Voltage	≥ 70% of bus voltage	≥ 65% of bus voltage
b. Sustained Degraded Voltage	≥ 94.6% of bus voltage for ≤13 seconds	≥ 94% of bus voltage for ≤ 15 seconds
8. AUXILIARY FEEDWATER		
a. Automatic Actuation Logic	Not Applicable	Not Applicable
b. NOT USED		
c. Steam Generator Water Level-- Low-Low	≥ 14.0% of narrow range instrument span each steam generator	≥ 13.0% of narrow range instrument span each steam generator
d. Undervoltage - RCP	≥ 70% RCP bus voltage	≥ 65% RCP bus voltage
e. S.I.	See 1 above (all S.I. setpoints)	
f. Trip of Main Feedwater Pump	Not Applicable	Not Applicable
g. Station Blackout	See 6 and 7 above (SEC and Undervoltage, Vital Bus)	
9. SEMIAUTOMATIC TRANSFER TO RECIRCULATION		
a. RWST Low Level	15.25 ft. above Instrument taps	15.25 \pm 1 ft. above instrument taps
b. Automatic Actuation Logic	Not Applicable	Not Applicable