

June 26, 2003

MEMORANDUM TO: James W. Clifford, Chief, Section 2  
Project Directorate I  
Division of Licensing Project Management  
Office of Nuclear Reactor Regulation

FROM: Victor Nerses, Sr. Project Manager, Section 2 */RA/*  
Project Directorate I  
Division of Licensing Project Management  
Office of Nuclear Reactor Regulation

SUBJECT: SEABROOK STATION, UNIT NO. 1, FACSIMILE TRANSMISSION,  
DRAFT REQUEST FOR ADDITIONAL INFORMATION (TAC NO.  
MB6615)

The attached draft RAI was transmitted by facsimile on June 26, 2003, to Mr. Mike O'Keefe of FPL Energy Seabrook, LLC (the licensee). This draft RAI was transmitted to facilitate the technical review being conducted by NRR staff. The RAI was related to the licensee's October 11, 2002, submittal concerning changes to Technical Specifications associated with nuclear instrumentation. Review of the RAI would allow the licensee to determine and agree upon a schedule to respond to the RAI. This memorandum and the attachment do not convey or represent an NRC staff position regarding the licensee's request.

Docket No. 50-443

Attachment: Draft RAI

June 26, 2003

MEMORANDUM TO: James W. Clifford, Chief, Section 2  
Project Directorate I  
Division of Licensing Project Management  
Office of Nuclear Reactor Regulation

FROM: Victor Nerses, Sr. Project Manager, Section 2 */RA/*  
Project Directorate I  
Division of Licensing Project Management  
Office of Nuclear Reactor Regulation

SUBJECT: SEABROOK STATION, UNIT NO. 1, FACSIMILE TRANSMISSION,  
DRAFT REQUEST FOR ADDITIONAL INFORMATION(TAC NO.  
MB6615)

The attached draft RAI was transmitted by facsimile on June 26, 2003, to Mr. Mike O'Keefe of FPL Energy Seabrook, LLC (the licensee). This draft RAI was transmitted to facilitate the technical review being conducted by NRR staff. The RAI was related to the licensee's October 11, 2002, submittal concerning changes to Technical Specifications associated with nuclear instrumentation. Review of the RAI would allow the licensee to determine and agree upon a schedule to respond to the RAI. This memorandum and the attachment do not convey or represent an NRC staff position regarding the licensee's request.

Attachment: Draft RAI

DISTRIBUTION

PUBLIC

J. Clifford      V. Nerses      S. Mazumdar      PDI-2 Reading

Accession Number: ML031770342

OFFICE	PDI-2/PM	EEIB/SC
NAME	VNerses	Nlqbal for EMarinos
DATE	6/25/03	6/26/03

OFFICIAL RECORD COPY

# DRAFT

REQUEST FOR ADDITIONAL INFORMATION  
BY THE OFFICE OF NUCLEAR REACTOR REGULATION  
FACILITY OPERATING LICENSE NO. NPF-86  
FPL ENERGY SEABROOK, LLC  
SEABROOK STATION  
DOCKET NO. 50-443  
TAC NO. MB6615

By revising Table Notations (1) for Table 4.3-1, Reactor Trip System Instrumentation Surveillance Requirements, the licensee proposes to increase the operational test (ACOT) interval from 31 days to 92 days for Functional Unit 6, Source Range, Neutron Flux. In next to the last paragraph of page 7, Section I, of the licensee's submittal dated October 11, 2002, the licensee stated that this requested change was made based on historical data on ACOTs performed. This by itself is not sufficient to justify this proposed TS change, and the staff considers additional information would be needed. as noted in a call with the licensee on June 25, 2003 (between Nerses/Mazumdar and O'Keefe/Mumford). Please provide the additional information.