

Public Meeting

Between USNRC Oversight Panel and FirstEnergy Nuclear Operating Company July 9, 2003



PURPOSES OF THIS MEETING

• Discuss Licensee's Progress on Implementing the Return to Service Plan

• Inform the Public of the NRC's Oversight Panel Activities

AGENDA

- Introduction and Opening Remarks
- Summary of June 3rd Public Meetings
- Discussion of Significant NRC Activities Since June 3rd
 Public Meeting
- Licensee Presentation on the Status of Their Return to Service Plan
- Public Comments and Questions of NRC
- Adjourn Meeting



*SUMMARY OF JUNE 3, 2003 PUBLIC MEETING

Topics Discussed

- Completion of 50 and 250 psi Reactor Coolant System Leak Checks
- Management and Human Performance Plan Update
- Engineering Issues Update
- Corrective Action Program Update
- Quality Assessment Update
- Restart Schedule Milestones

*Transcripts of the June 3, 2003 meetings are available on our web site. http://www.nrc.gov/

- Adequacy of Root Cause Determinations
 - Penetration cracking and reactor pressure vessel corrosion
 - Organizational, programmatic and human performance issues

- Adequacy of Safety Significant Structures, Systems, and Components
 - Reactor Pressure Vessel HeadReplacement
 - Containment Vessel Restoration
 Following Reactor Pressure Vessel
 Head Replacement

- Adequacy of Safety Significant Structures, Systems, and Components
 - Structures, Systems, and Components
 Inside Containment
 - Emergency Core Cooling System and Containment Spray System Sump

- Adequacy of Safety Significant Structures, Systems, and Components
 - Extent of Condition of Boric Acid in Systems Outside Containment
 - High Pressure Injection Pump
 Internal Clearance/Debris Resolution

- Adequacy of Safety Significant Programs
 - Corrective Action Program
 - Operating Experience Program
 - Quality Audits and Self-Assessments of Programs

- Adequacy of Safety Significant Programs
 - Boric Acid Corrosion ManagementProgram
 - Reactor Coolant System Unidentified
 Leakage Monitoring Program
 - In-service Inspection Program

- Adequacy of Safety Significant Programs
 - Modification Control Program
 - Radiation Protection Program
 - Process for Ensuring Completeness and Accuracy of Required Records and Submittals

- Adequacy of Organizational Effectiveness and Human Performance
 - Adequacy of Corrective Action Plan
 - Effectiveness of Corrective Actions

- Readiness for Restart
 - Review of Licensee's Restart Action
 Plan
 - Systems Readiness for Restart
 - Operations Readiness for Restart
 - Test Program Development and Implementation

- Licensing and Confirmatory Action Letter Resolution
 - Resolve ASME Code Relief Requests
 - Relocate Specific System Testing from Technical Specification to USAR
 - Meet with the NRC to Obtain Restart
 Approval

PUBLIC MEETING U.S. NUCLEAR REGULATORY COMMISSION PORT CLINTON, OHIO

July 9th, 2003, 7:00 pm EDT

Purpose of Meeting:

Inform the Public of the NRC's Oversight Panel Activities

GOALS

- Brief Public With Results of Afternoon Meeting with FENOC
- Receive Comments and Questions From Public

To ensure we hear all comments, please limit comments or questions to 5 minutes each. We will follow the format from previous meetings where we start with local members of the public.