



Entergy Operations, Inc.  
1448 S.R. 333  
Russellville, AR 72801  
Tel 501-858-4888

Craig Anderson  
Vice President  
Operations ANO

1CAN060302

June 30, 2003

U.S. Nuclear Regulatory Commission  
Attn: Document Control Desk  
Washington, DC 20555

**SUBJECT:** License Amendment Request to Add a New Control Room Emergency  
Ventilation System Surveillance Requirement  
Arkansas Nuclear One, Unit 1  
Docket No. 50-313  
License Number DPR-51

Dear Sir or Madam:

Pursuant to 10 CFR 50.90, Entergy Operations, Inc. (Entergy) hereby requests the following amendment to the Arkansas Nuclear One, Unit 1 (ANO-1). The proposed change will add a new Surveillance Requirement (SR) 3.7.9.5 to provide an appropriate testing range for 2VSF-9, one of two Control Room Emergency Ventilation System (CREVS) trains. SR 3.7.9.4, which was added during the conversion of the ANO-1 Technical Specifications (TSs) to the improved standard format, included a testing range based on the design parameters of VSF-9, the redundant fan in the CREVS. Due to design differences, the fans do not have the same makeup flow rate. The proposed change will designate that SR 3.7.9.4 is applicable to VSF-9. A justification of the change is provided in Attachment 1 and a marked up page of the TS is included as Attachment 2. Entergy will also be revising the applicable TS Bases when this amendment is implemented; a mark-up of the revised Bases pages is included in Attachment 3 for information only.

The proposed change has been evaluated in accordance with 10 CFR 50.91(a)(1) using criteria in 10 CFR 50.92(c) and it has been determined that this change involves no significant hazards considerations. The bases for these determinations are included in Attachment 1.

The proposed change does not include any new commitments.

Entergy requests approval of the proposed amendment by December 11, 2003. Although this request is neither exigent nor emergency, your prompt review is requested. Once approved, the amendment shall be implemented within 30 days.


AOO 1

Amendment 215 to the ANO-1 TSs which incorporated SR 3.7.9.4, was implemented July 8, 2002. In accordance with License Condition 2.C.(5) included in Amendment 215, SR 3.7.9.4, which has a frequency of 18 months, is not required to be performed until January 8, 2004. The proposed new SR 3.7.9.5 will be considered by ANO as a new surveillance implemented at the same time and, therefore, will be required to be performed for the first time by January 8, 2004.

If you have any questions or require additional information, please contact Dana Millar at 601-368-5445.

I declare under penalty of perjury that the foregoing is true and correct. Executed on June 30, 2003.

Sincerely,



CGA/dm

Attachments:

1. Analysis of Proposed Technical Specification Change
2. Proposed Technical Specification Changes (mark-up)
3. Changes to Technical Specification Bases Pages – For Information Only

cc: Mr. Thomas P. Gwynn  
Regional Administrator  
U. S. Nuclear Regulatory Commission  
Region IV  
611 Ryan Plaza Drive, Suite 400  
Arlington, TX 76011-8064

NRC Senior Resident Inspector  
Arkansas Nuclear One  
P. O. Box 310  
London, AR 72847

U. S. Nuclear Regulatory Commission  
Attn: Mr. John L. Minns  
MS O-7 D1  
Washington, DC 20555-0001

Mr. Bernard R. Bevill  
Director Division of Radiation  
Control and Emergency Management  
Arkansas Department of Health  
4815 West Markham Street  
Little Rock, AR 72205